

Annual Reliability and Compliance Workshop: Building Sustainable Programs

Day 2 Thursday, September 23, 2021 1:00 – 5:00 p.m. Eastern

PUBLIC



Welcome and Logistics

- This WebEx event is not being recorded.
- Please submit all questions through Slido instead of the WebEx chat.
- For your convenience, we will provide the workshop survey live at the end of event via Slido, so please stay on the call.
- Today's presentations will be emailed to all registrants and posted to RF website.

Join the conversation at Slido.com #RF2





Agenda

Presentation	Presenter(s)	Time
Opening Remarks	Brian Thiry, RF	1:00 – 1:05
Sustainability in Compliance Monitoring, Legal and Enforcement	Niki Schaefer, RF	1:05 – 1:20
Day 2 Keynote	Mark Hoog, Vector Academy	1:20 – 2:05
BREAK		2:05 – 2:15
Facility Ratings Regarding ERO Expectations and Lessons Learned	Joel Rogers, SERC	2:15 – 2:45
Facility Ratings Internal Controls	Joe Pilch, Duquesne Light Co.	2:45 – 3:15
BREAK		3:15 – 3:25
CIP-013 – Building a Sustainable Supply Chain Program	Scott Pelfrey, RF; Holly Peterson, WECC; Jordan Kethley, TexasRE; Lee Felter, MRO	3:25 – 4:10
CIP-014 Practice Guide Overview	Jamie Calderon, NERC	4:10 – 4:40
RF Community Appraisal Project	Brian Hallett, RF	4:40 - 4:55
Closing Remarks	Brian Thiry, RF	4:55 – 5:00



³ **PUBLIC**

Forward Together • ReliabilityFirst

RF Anti-Trust Statement

It is ReliabilityFirst's policy and practice to obey the antitrust laws and to avoid all conduct that unreasonably restrains competition. This policy requires the avoidance of any conduct which violates, or which might appear to violate, the antitrust laws. Among other things, the antitrust laws forbid any agreement between or among competitors regarding prices, availability of service, product design, terms of sale, division of markets, allocation of customers or any other activity that unreasonably restrains competition.

It is the responsibility of every ReliabilityFirst participant and employee who may in any way affect ReliabilityFirst's compliance with the antitrust laws to carry out this policy.



Trivia Giveaways

RF is offering the opportunity to win a \$100 Amazon gift card five times throughout each day of our Fall Workshop!

To Enter: Use Slido (Slido.com, Slido app or the QR code). At five different times during the workshop, we will announce that a content-based trivia question is coming. You will have one minute to enter your name into Slido before the question is asked. You must enter your first and last name; anonymous responders are not eligible to win.

To Win: A skill-based question will be visible in Slido. You must answer correctly and be the fastest respondent, as recorded in Slido, to win. We will announce the winners and who to email to provide an

address to receive the \$100 Amazon gift card.

5

PUBLIC

Join the conversation at Slido.com #RF2



NO COST TO ENTER. Governed by the rules of Ohio. Registrants and Entrants hold RF harmless from any associated claim and RF is not responsible nor may be held liable for any technical errors or events that may prevent the promotion from running smoothly. Must be over the age of 18 with a valid US address and not an Employee of ReliabilityFirst to win. Any resulting taxes are the responsibility of the winner.



Forward Together • ReliabilityFirst

Trivia Giveaway Question 1

Please log into Slido now for the opportunity to win a \$100 Amazon gift card!

- You have one minute from the time this slide is shown to enter your name into Slido before the question is asked.
- You must enter your first and last name; anonymous responders are not eligible to win.
- To Win, you must answer correctly and be the fastest respondent, as recorded in Slido.
- You can only win one time.

Slido.com #RF2







Sustainability in Compliance Monitoring, Legal and Enforcement

Niki Schaefer, Vice President & General Counsel Annual Reliability and Compliance Workshop September 23, 2021

PUBLIC



Background

- Family: 1 husband (Brian), 2 kids (Noah (12), Lane (10), 2 dogs (Artie and Moose)
- Home: born on Long Island, New York; raised in Shaker Heights, Ohio; live in Chagrin Falls, Ohio
- Education: Shaker Heights High School, Cornell University, Case School of Law
- Interests: running, snowboarding, wakeboarding, cooking and dining out, entertaining, traveling, fashion
- Volunteer work: The Gathering Place, American Heart Association
- Previous jobs: Counsel, Electrical Sector and Litigation at Eaton Corporation; RF enforcement; trial lawyer





8 **PUBLIC**

Elements of CMEP Sustainability





9 **PUBLIC**

Forward Together • ReliabilityFirst

Vision for Our CMEP Team

Risk-focused

- ➤ Thoughtful
- ➢ Reasonable
- ➢ Collaborative

Innovative





aware Illinois Indiana Kentucky Maryland Michigan NewJersey insylvania Ohio Tennessee Virginia Washington, DC West Virginia Wisconsin laware Illinois Indiana Kentucky NewJersey Michigan Maryland hio Pennsylvania Tennessee Virginia Washington, DC West Virginia Wisconsin elaware Illinois Indiana Michigan Maryland Kentucky New Jersey QUESTIONS & ANSWERS Wisconsin lentucky Illinois Indiana Marylar Delaware Michigan New Jersey Forward Together ReliabilityFirst Vest Virginia Pennsylvania Tennessee Virginia Washington, DC Ohio Wisconsin elaware Illinois Indiana Kentucky Maryland Michigan NewJersey rginia Pennsylvania Tennessee Ohio Washington, DC West Virginia Wisconsin laware Illinois Indiana Kentucky Maryland Michigan NewJersey o Pennsylvania Tennessee Virginia Washington, DC West Virginia Wisconsin Illinois Delaware Kentucky NewJersey Michigan Maryland na see Pennsylvania Washington, DC Virginia Ohio West Virginia Wisconsin

Trivia Giveaway Question 2

Please log into Slido now for the opportunity to win a \$100 Amazon gift card!

- You have one minute from the time this slide is shown to enter your name into Slido before the question is asked.
- You must enter your first and last name; anonymous responders are not eligible to win.
- To Win, you must answer correctly and be the fastest respondent, as recorded in Slido.
- You can only win one time.

Slido.com #RF2





12 **PUBLIC**

Forward Together • ReliabilityFirst

Keynote Speaker

Mark Hoog President, Vector Academy

Join the conversation at **Slido.com #RF2**



Forward Together • ReliabilityFirst

PUBLIC

PUBLIC



Annual Reliability Workshop

September 22-23, 2021

Building Sustainable Programs

RELIABILITY FIRST



There is history being made today...

By being here...you are a part of it!







Person... Questions







CONSCIOUS LEADERSHIP







Think of someone influential throughout history...

"1 word" tenet?







VISIONARY

VE

INSPIRING

CONSCIOUS LEADERSHIP SKILLS

RISK BASED

LISTEN/THINK

DISTINGUISH

THOUGHTFULNESS

UNDERSTANDING

CREDIBLE

INNOVATIVE

CONSISTENT

REASONABLE

CENTERED ON MISSION

COLLABORATIVE

TRANSPARENT

INVEST IN PEOPLE

SKILL & RELATIONSHIPS SUPPORT PEOPLE

VISION FOR FUTURE

RELATIONSHIPS



CONSCIOUS DECISIONS

TO MAKE

TODAY

CONSCIOUS DECISION #1:

FREESTYLE

WHAT ARE YOUR "3 BONES"?

BACKBONE?

FUNNY-BONE?



ABRAHAM MASLOW: SELF ACTUALIZATION

CONSCIOUS DECISION:

WHAT IS IT YOU MUST BECOME?

CONSCIOUS DECISION #2:

LEADERSHIP PARADIGM



CULTURE (SAFETY)?

How do you work along side Reliability First?

RELIABILITY, RESILIENCE AND SECURITY: DAILY OR JUST DURING AN AUDIT?

CONTINUOUS IMPROVEMENT?

BUILDING A SAFETY SYSTEM OR "HOPING" FOR SAFETY??

CULTIVATION?

ARE YOU TRAINING, ENCOURAGING AND EMPOWERING LEADERS?



LEADERSHIP PARADIGM

IT DOES NOT MATTER WHAT YOU WANT... IT MATTERS WHAT YOU ARE WILLING TO TRAIN.

Nould you fly with me at 50% safe? Nould you fly with me at 75% safe? Nould you fly with me at 99.9% safe?

> 1 accident every 4 days At 99.9% safe

Airline Safety Model

Safe Operations



CRM/TEM Skills Planning and Decision Making Leadership Effectiveness Situation Awareness Communication Monitor / Cross Check Workload Management Automation Management

Airline Safety Model

Safe Operations



CRM/TEM Skills Planning and Decision Making Leadership Effectiveness Situation Awareness Communication Monitor / Cross Check Workload Management Automation Management

Fatalities since safety system implemented in 1978?




2 questions



PEOPLE TALK ABOUT OTHER PEOPLE FOR 1 OF 4 REASONS...

WHY DO YOU GET TO STAY?



CAN YOU IMAGINE MEETING SOMEONE THAT "RAISED YOUR BAR" EVERYTIME YOU SAW THEM?

CAN YOU IMAGINE THAT PERSON...

BEING YOU?

DON'T MISS YOUR CHANCE... **TO INVITE OTHERS INTO THE GAME OF** LIFE!

TODAY IS <u>YOUR</u>, "UP-UNTIL-IT"





Thank you... for all you do!

RELIABILITY FIRST

Break

See you back at 2:15 for the presentation on Facility Ratings Regarding ERO Expectations and Lessons Learned from SERC's Joel Rogers!

Join the conversation at Slido.com #RF2





Forward Together • ReliabilityFirst



Facility Ratings Expectations and Lesson Learned

Joel Rogers, P.E., NCSO, CGAP SERC Senior Compliance Auditor



Agenda

- Analyzing Risk
- Facility Rating Reliability Standards
- Facility Rating Methodology
- Facility Rating Locations
- Facility Rating Database
- Trends and Violations
- Walk-down Checklist
- Internal Controls

Analyzing Risk

- High Risk Reliability Standards
- Inherent Risk
- Compliance History
- Internal Controls
- Compliance Culture
- Trends
- ERO and Regional Risk



FAC-008-3

- Purpose: To ensure that Facility Ratings used in the reliable planning and operation of the Bulk Electric System (BES) are determined based on technically sound principles. <u>A Facility Rating is</u> <u>essential for the determination of System</u> <u>Operating Limits.</u>
- Applicability
 - Transmission Owner (TO)
 - Generator Owner (GO)

System Operating Limit

SOL (System Operating Limit) – The value (such as MW, MVAR, amperes, frequency or volts) that satisfies the most limiting of the prescribed operating criteria for a specified system configuration to ensure operation within acceptable reliability criteria. System Operating Limits are based upon certain operating criteria. These include, but are not limited to:

- Facility Ratings (applicable pre-and post-Contingency Equipment Ratings or Facility Ratings)
- Transient stability ratings (applicable pre- and post-Contingency stability limits)
- Voltage stability ratings (applicable pre- and post-Contingency voltage stability)
- System voltage limits (applicable pre- and post-Contingency voltage limits)

SERC

Facility Rating / SOL Standards

- FAC-008-3 (Facility Ratings) confirm TO and GO have Facility Ratings consistent with FRM (Facilities Rating Methodology)
- FAC-014-2 (Establish and Communicate SOLs) confirm RC and TOP SOLs are consistent between EMS, State Estimator, and offline operations planning models
- FAC-014-2 (Establish and Communicate SOLs) confirm PC and TP SOLs are consistent between operations and planning models
- TOP-001-5 (Transmission Operations) and TOP-002-4 (Operations Planning) – confirm TOP SOLs are consistent between EMS, State Estimator, and offline operations planning models



Facility Rating Methodology

- Freedom to choose assumptions
- Based on technically sound principles
- Substation configuration
- Compliance to methodology



Facility Rating Locations



Facility Rating Locations



Facility Rating Data Flow



Generation and Transmission Owners

- Capturing Facility Ratings
- Quality assurance
- Periodic walk-down
- Sustainable program





Planning Models

- Planning Horizon
 - Near-term and Long-term
 - Short Circuit
 - Dynamic
- Operations Horizon
 - Next day to one year
- MOD-033-1 model validation





System Operations

• EMS

- Alarm points
- System topology
- Dynamic ratings
- State Estimator
 - RTCA
 - Power flow
 - Outage evaluation





Facility Ratings Database

- Official repository
- Data gathering and entry process
- Access controls
- Software application
- Review and approval





Trends

- Field
 - CTs
 - Jumpers
 - Connectors and bus
- Database
 - Equipment consolidation
 - Omissions
- Planning
 - Interconnections
- EMS and SE
 - System Operators unable to find correct location
 - Alarm point mismatch

SERC

- One-lines
 - No drawings
 - No ratings data
 - Does not match field topology

2020 – 2021 FAC-008-3 Violations

2021		FAC-00	8-3		Missed		Incorrect Facility	Incorrect	
Audit	Self-Report	Generation	Transmission Rec		Equipment	Nethodology	Rating	Equipment Rating	
				R3		X			
				R3		x			
				R6			x		
2020)	FAC-00	8-3					1	
				R6	Х				
				R6				x	
				R6	Х				
				R6	Х				
				R6	x				
				ВС	v				
				KO	^			×	
2020		EAC 000) 1	R6				Χ	
2020		FAC-003	7- I	D1			Y		
				R1			×		
				N1 D1			X		
				КI			Λ		
	0	0	6	R1	F		<u> </u>	2	
	2021 Audit 2020 2020 2020	2021 Audit Self-Report 2020 2020 2020 2020 2020 2020 2020 20	2021 FAC-00 Audit Self-Report Generation 2020 FAC-00 2020 FAC-00	2021 FAC-008-3 Audit Self-Report Generation Transmission 0 0 0 0 2020 FAC-008-3 0 2020 FAC-009-1 <	2021 FAC-008-3 Audit Self-Report Generation Transmission Req. Image: Constraint of the second s	2021 FAC-008-3 Missed Equipment Audit Self-Report Generation Transmission Req. Audit Self-Report Generation Ra Ra Audit Self-Report Ref X Audit FAC-008-3 Ref X Audit Generation Ref	2021 FAC-008-3 Missed Equipment Methodology Audit Self-Report Generation Transmission Req. Equipment Methodology Audit Self-Report Generation Transmission Req. X Image: Constraint of the second s	2021FAC-008-3Missed EquipmentMethodologyIncorrect Facility RatingAuditSelf-ReportGenerationTransmissionReq.MethodologyIncorrect Facility RatingImage: Construct of the second se	



Walk-Down Checklist

Planning the Walk-Down

Become Familiar With Your Company's Facility Ratings Methodology

Procure Binoculars and/or High Resolution Camera for Objects Out of Reach

Determine Personnel Protective Equipment (PPE) Requirements

Contact the Control Center and Security Personnel to Plan the Walk-down

Obtain Checklist, One-line, Equipment List, Computer App., etc. for Annotations

Review One-lines and Equipment List Prior to Walk-Down

Check Weather Forecast for the Day of the Walk-Down

Performing the Walk-Down

Establish a Walk-Down Leader and Discuss the Role of Each Participant

Conduct a Safety Briefing Prior to Entering the Substation or Plant

Ensure Participants Know Local First Responder Numbers and Physical Address

Ensure All Personnel Have Proper PPE

Discuss the Order in Which Facilities Will Be Reviewed

Discuss Who Will Open Breaker Cabinets and Access Other Equipment

Discuss Any Hazard Areas or Ongoing Work Area that Should Be Avoided

Contact the Control Center and Security Personnel Prior to Entry and After Exit

Internal Controls

- Periodic walk-downs
- Effective data capture
- Quality assurance review
- Periodic validation
- Access controls
- Management oversight

Link: CMEP Practice Guide - Evaluation of Facility Ratings and System Operating Limits



Summary

- Clearly defined and documented process with flowcharts
- Training on programs and processes
- Change management
- Internal controls
- Quality assurance review
- Periodic review



Questions

Link: SERC Facility Ratings E-Learning Module



Break

See you back at 2:15 for the presentation on Facility Ratings Regarding ERO Expectations and Lessons Learned from SERC's Joel Rogers!

Join the conversation at Slido.com #RF2





Forward Together • ReliabilityFirst

Trivia Giveaway Question 3

Please log into Slido now for the opportunity to win a \$100 Amazon gift card!

- You have one minute from the time this slide is shown to enter your name into Slido before the question is asked.
- You must enter your first and last name; anonymous responders are not eligible to win.
- To Win, you must answer correctly and be the fastest respondent, as recorded in Slido.

Slido.com #RF2





Duquesne Light Company FAC-008 Program Sustainability

Joe Pilch, Manager Transmission Planning & Interconnection



PUBLIC

DLC Company Profile

- Registered TO and DP, service territory is located in southwest Pennsylvania, surrounding the City of Pittsburgh.
 - ~ 650 miles of BES Facilities
 - ~ 120 BES Facilities
 - ~ 35 BES Substations
 - Both Rural and Urban Environments
- Transmission Voltages:
 - 345 kV
 - 138 kV
 - 69 kV





Challenges of FAC-008 Compliance





FAC-008 Program Background

- Transmission Planning group is the FAC-008 standard owner
- Maintains all Facility Ratings in the DLC Transmission System Equipment Ratings Database
 - Built using .sql database structure
 - Equipment ratings are maintained via web interface
 - Can be exported to MS Excel
- Ratings Database is populated from engineering drawings
 - Equipment single lines
 - Protection single lines
 - Circuit maps



Voltage: 138 Mile	s:9.74 Status: Activ	e								
(138, 4) Type: Primary Power Tak	e-Off: 0									
		Sum	mer 35C ((95F)	Spring	/Fall 200	(68F)	Win	ter 10C (50F)	
Туре	Class	Norm	Emrg	LD	Norm	Emrg	LD	Norm	Emrg	LD
T SS Wire (3.5in AL PIPE)	2A	2481	3121	3452	2845	3407	3707	3058	3581	3864
T SS Wire (Two (2) - 3.5in AL PIPE)	2A	4143	5212	5765	4751	5690	6191	5107	5980	6453
T SS Wire (3.5in AL PIPE)	2A	2481	3121	3452	2845	3407	3707	3058	3581	3864
T Disconnect (2000A)	1	2000	2000	2060	2000	2000	2060	2000	2000	2060
T SS Wire (853.7 ACAR 24/13)	2A	1074	1267	1334	1193	1362	1423	1264	1421	1478
T CT (2000/5MR)	1	2328	2328	2400	2328	2328	2400	2328	2328	2400
T Relay CT (50)	1	4656	4656	4800	4656	4656	4800	4656	4656	4800
T Relay CT (21/79)	1	3492	3492	3600	3492	3492	3600	3492	3492	3600
T Circuit Breaker (3000A)	1	3000	3000	3090	3000	3000	3090	3000	3000	3090
T Relay CT (50)	1	4656	4656	4800	4656	4656	4800	4656	4656	4800
T Relay CT (87)	1	3492	3492	3600	3492	3492	3600	3492	3492	3600
T CT (2000/5MR)	1	2328	2328	2400	2328	2328	2400	2328	2328	2400
T SS Wire (853.7 ACAR 24/13)	2A	1074	1267	1334	1193	1362	1423	1264	1421	1478
T Disconnect (2000A)	1	2000	2000	2060	2000	2000	2060	2000	2000	2060
(138, NA) Type: Primary Power Ta	ake-Off: 0									
		Sum	Summer 35C (95F)			/Fall 200	/Fall 20C (68F)		ter 10C (50F)
Туре	Class	Norm	Emrg	LD	Norm	Emrg	LD	Norm	Emrg	LD
T OH Wire (795 ACSR 45/7)	2A	919	1039	1117	1082	1181	1273	1177	1265	1368
T OH Wire (853.7 ACAR 24/13)	2A	932	1055	1129	1098	1199	1286	1193	1285	1380
T OH Wire (795 ACSS/TW 20/7)	2A	929	1050	1153	1094	1193	1314	1189	1277	1411
T OH Wire (853.7 ACAR 24/13)	2A	932	1055	1129	1098	1199	1286	1193	1285	1380
(138, 4) Type: Primary Power T	ake-Off: 0									
		Sum	mer 35C ((95F)	Spring	/Fall 200	: (68F)	Win	ter 10C (50F)
Туре	Class	Norm	Emrg	LD	Norm	Emrg	LD	Norm	Emrg	LD
T SS Wire (853.7 ACAR 24/13)	2A	1074	1267	1334	1193	1362	1423	1264	1421	1478
T Disconnect (2000A)	1	2000	2000	2060	2000	2000	2060	2000	2000	2060
T SS Wire (853.7 ACAR 24/13)	2A	1074	1267	1334	1193	1362	1423	1264	1421	1478
T CT (2000/5MR)	1	2328	2328	2400	2328	2328	2400	2328	2328	2400
T Relay CT (50)	1	4656	4656	4800	4656	4656	4800	4656	4656	4800
T Relay CT (21/79)	1	3492	3492	3600	3492	3492	3600	3492	3492	3600
T CT (2000/5MR)	1	3880	3880	4000	3880	3880	4000	3880	3880	4000
T Relay CT (87)	1	5820	5820	6000	5820	5820	6000	5820	5820	6000
T Circuit Breaker (3000A)	1	3000	3000	3090	3000	3000	3090	3000	3000	3090
T Relay CT (50)	1	4656	4656	4800	4656	4656	4800	4656	4656	4800
T Relay CT (87)	1	3492	3492	3600	3492	3492	3600	3492	3492	3600
T CT (2000/5MR)	1	2328	2328	2400	2328	2328	2400	2328	2328	2400
T Relay CT (87)	1	6208	6208	6400	6208	6208	6400	6208	6208	6400
T CT (2000/5MR)	1	3880	3880	4000	3880	3880	4000	3880	3880	4000
T SS Wire (853.7 ACAR 24/13)	2A	1074	1267	1334	1193	1362	1423	1264	1421	1478
T Disconnect (2000A)	1	2000	2000	2060	2000	2000	2060	2000	2000	2060

Ratings Database Controls

- Strict access controls to Ratings Database
 - Managed by internal access management group
 - Usernames and passwords are provided
 - Write access is only available to small group of engineers

• A comprehensive review of the Facility Rating is performed any time an equipment entry is added, removed, or modified (with some exceptions)

• All modifications are peer reviewed by a second engineer







Additional Ratings Database "Controls"

• Transmission System Equipment Library

Ratings Database equipment entry manual



Туре	Manufacturer	Model	Description
T SS Wire	Mitsubishi	GIS	3000A
T SS Wire	None	AL BAR	0.225in x 4.5in AL
T SS Wire	None	AL BAR	0.25in X 6in AL
T SS Wire	None	AL BAR	0.25in x 4in AL BAR
T SS Wire	None	AL BAR	0.313in x 3in AL
T SS Wire	None	AL BAR	0.375in x 4in AL
T SS Wire	None	AL BAR	0.375in x 6in AL
T SS Wire	None	AL BAR	0.438in x 3in AL
T SS Wire	None	AL BAR	0.438in x 4in AL
T SS Wire	None	AL BAR	0.5in x 3in AL
T SS Wire	None	AL BAR	0.5in x 4in AL
T SS Wire	None	AL BAR	0.5in x 5.5in AL
T SS Wire	None	AL BAR	0.5in x 6in AL
T SS Wire	None	AL BAR	0.5in x 7in AL
T SS Wire	None	AL BAR	0.75in X 4in AL
T SS Wire	None	AL BAR	0.75in x 5in AL 6061-T6
T SS Wire	None	AL BAR	0.75in x 6in AL
T SS Wire	None	AL BAR	0.938in x 6in AL
T SS Wire	None	AL BAR	1in X 4in AL
T SS Wire	None	AL BAR	1in X 8in AL
T SS Wire	None	AL BAR	3in x 3.5in AL
T SS Wire	None	AL CHANNEL	5in Channel 0.19in WebThick AL
T SS Wire	None	AL CHANNEL	6in Channel 0.225in WebThick AL
T SS Wire	None	AL CHANNEL	6in Channel 0.314in WebThick AL
T SS Wire	None	AL CHANNEL	6in Channel 0.437in WebThick Al
T SS Wire	None	CU BAR	0.25in X 4in CU
T SS Wire	None	CU BAR	0.25in x 6in CU
T SS Wire	None	CU BAR	0.5in x 4in CU
T SS Wire	None	CU BAR	0.5in x 6in CU
T SS Wire	None	CU BAR	0.75in X 6in CU
T SS Wire	None	CU PIPE	1.5in CU PIPE

Equip	quipment Ratings																					
[Creat	Create Rating]																					
	Summer 35C (95F)		30C (86F)		25C (77F)		Spring/Fall 20C (68F)		15C (59F)			Winter 10C (50F)		5C (41F)	0C (32F	,						
	Labe	el Class	Norm	Emrg	LD	Norm	Emrg	LD	Norm	Emrg	LD	Norm	Emrg	LD	Norm	Emrg	LD	Norm	Emrg	LD Norm Emrg L	D Norm Emrg	LD
? Edi	t	2A	1424	1745	1908	1493	1798	1955	1558	1849	2001	1619	1899	2045	1678	1946	2088	1735	1992 2	130 1789 2037 21	170 1840 2080	2209



Potential for New Ratings Database Software

- Presently investigating commercially available software to replace DLC's existing Ratings Database.
- Goals of new software include:
 - Increased vendor support through patching
 - Potential integrations with other DLC systems (i.e., work management program, energy management system/SCADA, etc.) for <u>enhanced controls</u>




Facility Energization Controls

- Post Construction Field Reviews
 - Required for all transmission projects
 - Engineering/Commissioning personnel physically inspect equipment with construction team to verify as-built conditions match prints
 - Any equipment that is grounded and cleared is inspected
- Operations Center Pre-Energization Checklist
 - Includes checks for Facility Rating updates
 - Facility is not energized until all pre-reqs have been met





INITIAL ENERGIZATION PROCEDURE					
<facility name=""></facility>					
At					
Substation					
Revision Date					

Verification of documents	Date Received	Initials	Verification of documents	Date Received	Initials
Circuit Maps			Updated Ratings Tfmr		
(Manager, GIS and Mapping)			(Senior Manager, System		
			Planning)		
Station Single Lines			Updated Ratings - Line		
(Manager, Substation			(Senior Manager, System		
Engineering & Manager			Planning)		
Substation Control					
Engineering)					
RT Maps			Reclosing Settings/Changes		
(Manager, Protection			(Manager, Protection		
Engineering)			Engineering)		
Customer Single Lines			Temporary Settings acquired		
(Manager, Substation			and approved		
Engineering & Manager			(Manager, Protection		
Substation Control			Engineering)		
Engineering)					
SCADA display updated			Equipment Marking signs		
(Manager, Operations			installed		
System)			(Supervisor, Substation		
			Protection and Control)		
SOC Mapboard updated			Key Interlocks installed and		
(Senior Manager,			functional		
Transmission Operations)			(Supervisor, Substation		
			Electrical Maintenance)		
State Estimator updated			Transmission Post-Construction		
(Senior Manager, System			field review		
Planning)			(Manager, Substation		
			Engineering)		
eDART cut-in flag			Transmission Planning		
(Manager, Control Room			Breaker replacement notified		
Operations)			(Senior Manager,		
			System Planning)		

Detective Controls

- Annual 10% Ratings Database Review
 - Comprehensive review of Facility Rating
 - Validate Ratings Database matches engineering drawings

	Summer 35C (95F)		(95F)	Spring/Fall 20C (68F)			Winter 10C (50F)			
Туре	Class	Norm	Emrg	LD	Norm	Emrg	LD	Norm	Emrg	LD
T SS Wire (4.0in AL PIPE)	2A	3263	4070	4479	3744	4443	4809	4025	4669	5012
T SS Wire (Two (2) - 3.0in AL PIPE)	2A	4160	5167	5678	4767	5641	6099	5124	5929	6358
T SS Wire (4.0in AL PIPE)	2A	3263	4070	4479	3744	4443	4809	4025	4669	5012
T Disconnect (2000A)	1	2000	2000	2060	2000	2000	2060	2000	2000	2060
T SS Wire (2000 AAC 91 str.)	2A	1850	2209	2335	2058	2375	2489	2182	2477	2584
T SS Wire (1in X 4in AL)	2A	3087	3754	4093	3499	4080	4386	3743	4280	4566
T CT (2000/5MR)	1	3880	3880	4000	3880	3880	4000	3880	3880	4000
T Relay CT (50)	1	7760	7760	8000	7760	7760	8000	7760	7760	8000
T Relay CT (21)	1	5820	5820	6000	5820	5820	6000	5820	5820	6000
T Circuit Breaker (3000A)	1	3000	3000	3090	3000	3000	3090	3000	3000	3090
T Relay CT (50)	1	7760	7760	8000	7760	7760	8000	7760	7760	8000
T Relay CT (87/79)	1	5820	5820	6000	5820	5820	6000	5820	5820	6000
T CT (2000/5MR)	1	3880	3880	4000	3880	3880	4000	3880	3880	4000
T SS Wire (1in X 4in AL)	2A	3087	3754	4093	3499	4080	4386	3743	4280	4566
T SS Wire (2000 AAC 91 str.)	2A	1850	2209	2335	2058	2375	2489	2182	2477	2584
T Disconnect (2000A)	1	2000	2000	2060	2000	2000	2060	2000	2000	2060



Detective Controls

- Annual 5% Field Review
 - Facilities are removed from service and physically inspected
 - Validate engineering drawings match field conditions
 - Outages are optimized to maximize inspections with a single outage





Cycle of Improvement

- Annual Field Review (control) detected drawing error
 - Element connected to a bus disconnect switch not included on the drawing
 - Extent of condition was performed
 - Drawings were updated to match field conditions
 - No change to Facility Rating
- Root Cause Analysis
 - Root cause analysis conducted for every near miss
 - Root cause indicated insufficient post-construction field review
- Improvements to Controls
 - Strengthened post construction field review process
 - Created job aid
 - Created role-based training / Qualified Engineer Process



Drawings, Field Modifications, Corrections, Ratings and Updates Manual CONFIDENTIAL DOCUMENT	Procedure Number: Revision Number: Effective Date:	EM-001 2.0			
Tile: Corrections, Ratings and Updates Manual CONFIDENTIAL DOCUMENT	Revision Number: Effective Date:	2.0	_		
CONFIDENTIAL DOCUMENT	Effective Date:				
APPENDIX 1: Post Construction Field Revi			-		
hat is verified as part of the post construction? or commention field review, the Qualified Di articipating in the review to follow the proce- interporting in the review to follow the proce- tion 3.5 of EALOO. The following equipme- erviewed as part of the post construction field Examinent Sintle Line: Check the information on the samepla- what is indicated on the drawings: a. Check the information on the samepla- what is indicated on the drawings: b. Power Transformate c. Check the information of the same b. Power Transformate c. Check the information of the same c. Check the information of the same c. Check the information of the same c. Check the information of the same same same c. Check the information of the same same same same same c. Check the information of the same same same same same same same sam	Teld review. If a discrepant (C Engineer housd instruc- ure in section 3.5.2.2 of Et al. post construction field revi at (as qualified by section 3 ld review: tes of the following pieces of	y is found during the the field personnal 4:001 so that the ew in accordance with 5:5 of EA4-001) should of equipment against	Field Modifications	Engineering Procedum Namber	Manual (EM)
g. Capacitor cans		Title: Correction	Field Modifications, s. Ratings and	Procedure Number:	EM-00
 Line Iraps For each stranded conductor identifies 	the conducto	Updates M	anual	Revision Number:	2.0
requesting the interpretation of the second seco	in outing they use as the associat Adamts as adard conclu- day DLC.	The following types of the Ratings Database: 1. Stranded overhel 2. Underground c. 3. Stranded overhel 4. Pipe box 5. Administratic types 5. Administratic types 6. Administratic types 7. Disconnect two 8. Disconnect two 9. Circuit strather 10. Circuit strather 11. Circuit Strather 12. Circuit Strather 13. Line trapps 14. Relays 15. Line trapps 15. Reactors 18. Reactors 18. Reactors 19. Reactors 19. Reactors 10. Reactors 10. Reactors 10. Reactors 11. Reactors 12. Reactors 13. Reactors 14. Reactors 15. Reactors 16. Reactors 17. Reactors 18. Reactors 19. Reactors 19. Reactors 10.	equipment are conside oble to be to a conductor or have or channels on conductor or channels on conductor of a constant of contragers and age and age and age and age and age and age and age age age age age age age age age age	end current carrying and are	captured explic

Training

- Annual training for engineering teams
 - Overview of standard
 - Actions/expectations of various groups
 - Communications between groups
- Annual refresher training for field personnel
 - Overview of standard
 - Expectations for field changes / red-lined drawings
 - Review specific examples of past oversights
- Annual Role-Based Training for different teams ("Module 2")
 - Engineering, Planning, Electrical Maintenance, P&C Technicians
 - Asset Mgmt, Project Management, Operations, etc.



Documentation

- Transmission Planning Manual FAC-008 Sections
 - Equipment rating methodologies
 - Requirements for ratings database maintenance
 - Ratings communications

DUQUESNE LIGHT CO.		Transmission Planning Manual			
Title:	System Patings Database	Procedure Number:	TPM-FAC-8-002		
	System Ratings Database	Revision Number:	1.9		
CONFIDENTIAL DOCUMENT		Effective Date:	December 18, 2019		

NERC Standard(s) Reference: FAC-008-3

- Engineering Manual
 - Requirements for information contained on drawings
 - Approval of field modifications
 - Post-construction field reviews

- 3.2.1. The equipment single line shall identify the following:
 - 3.2.1.1. All conductors (including type, size, and stranding).
 - 3.2.1.2. All other current carrying equipment by manufacturer, type or model, nameplate maximum continuous current rating, interrupting rating, and thermal rating factor (TRF), when applicable, including but not limited to:
 - 3.2.1.2.1. Current transformers (CTs), including its TRF.
 - 3.2.1.2.2. Primary voltage and secondary voltage autotransformer bushings.
 - 3.2.1.2.3. Circuit breaker bushings in instances where the nameplate rating is lower than the circuit breaker nameplate rating.
 - 3.2.1.3. Any custom bus bar or connector that was made by a fabrication shop shall be identified by physical dimension or other properties and type of material.



Planned Work vs. Emergent Work

• Controls still apply during emergency situations

Post-Construction Field Reviews

• Operations Center Check







Break

See you back at 3:25 for the CIP-013 Panel Discussion on Building a Sustainable Supply Chain Program!

Join the conversation at Slido.com #RF2





Forward Together • ReliabilityFirst



CIP-013 - Building a Sustainable Supply Chain Program

Scott Pelfrey – Principal Technical Auditor, RF Holly Peterson – Senior Compliance Auditor, WECC Lee Felter – Principal Risk Assessment and Mitigation Engineer for CIP, MRO Jordan Kethley – CIP Cyber and Physical Security Analyst, TexasRE Annual Reliability and Compliance Workshop September 23, 2021

PUBLIC



CIP-013 Supply Chain Program Panel Discussion



Scott Pelfrey Principal Technical Auditor, RF

Lee Felter

Principal Risk Assessment and Mitigation Engineer, CIP, MRO



The second second

Jordan Kethley CIP Cyber and Physical Security Analyst, TexasRE

Holly Peterson Senior Compliance Auditor, WECC





CIP-013 Supply Chain Resources

TexasRE June 2021 CIP Workshop

Joint CCC ERO Enterprise Webinar on Supply Chain

NERC Supply Chain Risk Mitigation Program

Series of Supply Chain E-Learning Modules from SERC/RF



aware Illinois Indiana Kentucky Maryland Michigan NewJersey insylvania Ohio Tennessee Virginia Washington, DC West Virginia Wisconsin laware Illinois Indiana Kentucky NewJersey Michigan Maryland hio Pennsylvania Tennessee Virginia Washington, DC West Virginia Wisconsin elaware Illinois Indiana Michigan Maryland Kentucky New Jersey QUESTIONS & ANSWERS Wisconsin lentucky Illinois Indiana Marylar Delaware Michigan New Jersey Forward Together ReliabilityFirst Vest Virginia Pennsylvania Tennessee Virginia Washington, DC Ohio Wisconsin elaware Illinois Indiana Kentucky Maryland Michigan NewJersey rginia Pennsylvania Tennessee Ohio Washington, DC West Virginia Wisconsin laware Illinois Indiana Kentucky Maryland Michigan NewJersey o Pennsylvania Tennessee Virginia Washington, DC West Virginia Wisconsin Illinois Delaware Kentucky NewJersey Michigan Maryland na see Pennsylvania Washington, DC Virginia Ohio West Virginia Wisconsin

Trivia Giveaway Question 4

Please log into Slido now for the opportunity to win a \$100 Amazon gift card!

- You have one minute from the time this slide is shown to enter your name into Slido before the question is asked.
- You must enter your first and last name; anonymous responders are not eligible to win.
- To Win, you must answer correctly and be the fastest respondent, as recorded in Slido.
- You can only win one time.

Slido.com #RF2





Forward Together • ReliabilityFirst

NERC

CIP-014-2

R1 Risk Assessments

Jamie Calderon, Senior Engineer Grid Planning and Operations Assurance RF 2021 Workshop September 23, 2021





Where We've Been



- Few R1 Risk Assessments to date
 - (Up to 30/60 months between)
- Summary of ERO Enterprise reviews of implementation
 - FERC-led audits, Region-led Audits, Workshops, etc.
- Objective-based Reliability Standard requirements
 - Built-in flexibility for what's appropriate for individual entities (not prescriptive)
 - Objectives require implementation of an intentional design (no checkbox)
- Strong culture of compliance supports continual incremental improvements



- R1 states the following:
 - "The initial and subsequent risk assessments shall consist of a transmission analysis or transmission analyses designed to identify the Transmission station(s) and Transmission substation(s) that if rendered inoperable or damaged could result in instability, uncontrolled separation, or Cascading within an Interconnection."
- An entity meeting this requirement should be able to clearly demonstrate, through its analysis, that instability, uncontrolled separation, and Cascading within the Interconnection was or was not identified within the Interconnection.
- <u>System Stability, uncontrolled separation, and Cascading cannot be sufficiently</u> <u>assessed through Steady-State studies alone.</u>



• What is power system "Stability"?



Adapted from IEEE/CIGRE ©2003



- What is "uncontrolled separation"?
- Consider relays and how to study their operation

Continge	ncy Event				
Separation Assessment					
Uncontrolled Separation	Controlled Separation				
 The unintended islanding of a portion of an electric system that includes generation or load Unplanned removal of a portion of the electric system due to operation of protection or control systems. Studies indicate that contingency causes unintended relay action resulting in some form of islanding. Separation events are considered uncontrolled until otherwise proven by study to be controlled through operation of protection systems, RAS, or other control systems intentionally used to separate portions of the system. 	 The intended islanding of a portion of an electric system that includes generation or load As-designed protection systems, RAS, or other control systems operating specifically to separate part of the BPS. Points of separation are planned ahead of time, and separated system studied to perform as expected. May involve large separated systems or small load pockets. Ensures integrity of the larger BPS by disconnecting potentially weak or unstable portions of the system. Does not include load lost as a consequence of the contingency May be accompanied by RAS or other control actions to balance generation-load equilibrium in the separated system(s) 				



- What is "Cascading"?
- Simulated in an iterative process
 - Base case solves
 - Contingency Event occurs
 - Effects on nearby system are studied in the time-domain and if/when the system reaches a Steady-State solution
 - Loop ~ The removal of overloaded elements, protection systems, RAS, etc. are simulated and the effects are studied ~ Loop
 - Thresholds/Criteria are applied to the resulting system impacts
- Similar to uncontrolled separation, the operation of relays must be considered in order to sufficiently study this adverse system condition



- Additional coordination and discussions must be had to ensure that R1 risk assessments are meeting the expectations of the ERO Enterprise and the objective of the requirement language.
- Documentation will be key!
 - Appropriate criteria and thresholds
 - Adequate technical rationale for risk assessment decisions are what support how the objective is met
 - Consider each of these 3 adverse system conditions and how the risk assessment has supporting technical material.
- CMEP Practice Guide for CIP-014-2 R1: Risk Assessments expected in Fall 2021



Questions and Answers



Trivia Giveaway Question 5

Please log into Slido now for the opportunity to win a \$100 Amazon gift card!

- You have one minute from the time this slide is shown to enter your name into Slido before the question is asked.
- You must enter your first and last name; anonymous responders are not eligible to win.
- To Win, you must answer correctly and be the fastest respondent, as recorded in Slido.
- You can only win one time.

Slido.com #RF2





Forward Together • ReliabilityFirst



Community Appraisal Project

Brian Hallett, Principal Reliability Consultant, Entity Engagement Carl Dister, Chief Innovation Manager, Continuous Improvement

> RF Fall Virtual Workshop September 23, 2021

PUBLIC



Project Aligns with RF Goals/Objectives

RF Strategic Objective: Be a Credible Regulator

- Partner with stakeholders to increase abilities to self-assess security, reliability and/or resilience posture and preparedness
 - Build relationships with Registered Entities, industry groups, national labs, academia, communities, etc. to drive awareness security, reliability and/or resilience
 - Develop, build and influence the industry use of **assessment tools** and methodologies
- Strengthen Entity, industry and regulator partnership/relationships





76 **PUBLIC**

Forward Together • ReliabilityFirst

Unique Partnerships

The Partners: RF and Ohio State University Extension (OSUE) have developed a Community Appraisal Project to help communities gain the technical and social capacity needed to mitigate impacts of a 7-21 day power outage.



Why the transdisciplinary approach?

Resilience is a Sociotechnical Grand Challenge! In this approach, the strengths of cutting edge Community Development are fused with contemporary practice in Systems Engineering.

RF

77 **PUBLIC**

What is a Community Appraisal?

Maturity Model Self-Assessment

- The team will guide participants through a web-based tool, interpret the results, and collaboratively develop initiatives and process improvements to foster a community's capacity to withstand prolonged power outages and build long-term community resilience.
- The tool captures community capabilities against a nine-proficiency maturity model developed by the team following the review of more than 50 different existing models and methods.
- The project aims to help communities develop an understanding of the risks they face, how they are related and where they can improve resilience.



78 **PUBLIC**

Forward Together • ReliabilityFirst

Flattening the Learning Curve

Interactive Learning through Gaming

 RF's system engineering experts and OSUE's Community Development professionals have built an engaged "game-based" approach to leading communities through an analysis of existing system limitations and developing a plan for targeted mitigation strategies.



Can Communities afford to "Play Games" to address resilience?

- As problems increase in complexity, and when money is tight, communities need to tap into the creative intelligence that exists inside of each member of the community.
- Game Play helps to bring out these creative ideas and collectively judge their worthiness to help. Modern tech can really accelerate this!



That's a Big Footprint! Where to Start?

Heat Map Development

RF has developed a heat map of its 13-state footprint that looks at the likelihood of a county to experience an extended blackout based on past reliability metrics and proximity to electric system infrastructure, combined with the county's ability to mitigate a significant blackout, should one occur.



(source: https://fema.maps.arcgis.com/apps/webappviewer/index.html?id=90c0c996a5e242a79345cdbc5f758fc6)



(source: https://phys.org/news/2019-12-small-small-world-network.html)

Long-Term, Small-World Network Propagation Approach

- We don't have resources to engage long term with every community.
- By strategically using our heat map as a compass, we can target seed communities in each large geographic cluster helping them build resilience, while also helping them build relationships with nearby "nodes" in their local hub area to spread the approach.



80

Why More Than a Two-day Blackout?

Don't most blackouts in a Community last one or two days at most?

- The President's National Infrastructure Advisory Council (NIAC) has found that existing national plans, response resources and coordination strategies will be outmatched by a catastrophic power outage. <u>https://www.c-span.org/video/?c4968269/user-clip-fema-time-delay-responding</u>
- Most communities think of blackouts as being contained within a few blocks, and power will be restored in a couple days. But the risks (weather, aging infrastructure, etc.) and complexity (automation, renewables, etc.) are creating the potential for longer duration outages on wider scales. This profound risk requires a new national focus.

Analysis and Coordination is Needed

 Significant public and private action is needed to prepare for and recover from a catastrophic outage that could leave the large parts of the nation without power for weeks or months, as well as cause service failures in other sectors, including water and wastewater, communications, transportation, healthcare and financial services.



What's Next?

> Tools + Process Development

• Final materials are being produced.

Outreach to Communities

• Outreach to communities to begin Q3 - Q4.

Feed Footprint Data into Regional Risk Assessment (RRA) Process

- As community appraisals are completed across the 13-state footprint, RF will learn more about the needs and limitations of the citizens whose livelihoods and quality of live depend upon the reliable supply of electricity.
- Identify open-source data, with spot validation, for inclusion into the RRA process to better understand the risks and local capabilities in the RF footprint.
- Possible to focus outreach to the Entities that serve most-at-risk load.



aware Illinois Indiana Kentucky Maryland Michigan NewJersey insylvania Ohio Tennessee Virginia Washington, DC West Virginia Wisconsin laware Illinois Indiana Kentucky NewJersey Michigan Maryland hio Pennsylvania Tennessee Virginia Washington, DC West Virginia Wisconsin elaware Illinois Indiana Michigan Maryland Kentucky New Jersey QUESTIONS & ANSWERS Wisconsin lentucky Illinois Indiana Marylar Delaware Michigan New Jersey Forward Together ReliabilityFirst Vest Virginia Pennsylvania Tennessee Virginia Washington, DC Ohio Wisconsin elaware Illinois Indiana Kentucky Maryland Michigan NewJersey rginia Pennsylvania Tennessee Ohio Washington, DC West Virginia Wisconsin laware Illinois Indiana Kentucky Maryland Michigan NewJersey o Pennsylvania Tennessee Virginia Washington, DC West Virginia Wisconsin Illinois Delaware Kentucky NewJersey Michigan Maryland na see Pennsylvania Washington, DC Virginia Ohio West Virginia Wisconsin

In a few words, what's your biggest actionable takeaway from today's presentations?

Join the conversation at **Slido.com #RF2**





Trivia Giveaway Winners

Thank you and Congrats to today's five trivia winners!

To claim your \$100 Amazon gift card, please email Jody Tortora at <u>Jody.Tortora@rfirst.org</u>.



Closing Remarks

Thank you for attending Day 2 of our Annual Reliability and Compliance Workshop! Your feedback is extremely important to us and allows RF to continuously improve our webinars, workshops and outreach efforts.

> Please take our post-event survey in Slido now at **Slido.com #RF2**.



