

Case Preparation for Studies

Paul Simoneaux
Principal Engineer
August 2026



Overview

Initial Case

Solution Parameters

Solve Settings

Basic Solution Check

Data Checks

TARA Studio

TARA

Initial Case: Choosing the Right Format in PSSE



SAV Format

Use when the study needs a repeatable operating point.

Preserves fully converged voltages, angles, dispatch, flows, and control settings. This ensures engineers start the analysis from the exact same solved state, eliminating initialization discrepancies.



RAW Format

Use when sharing or editing the power-flow model.

Contains clean, plain-text network topology data rather than the converged system state. Best for cross-platform model transfer, manual parameter editing, and direct topology adjustments.



Key Takeaway: Use .SAV for repeatable analysis from a known solved case. Use .RAW for flexible model transfer, making sure to solve and validate the system state before comparing results.

Solution Parameters in PSSE



Refer to the MMWG Manual
on the ERAG website

[ERAG | Eastern Interconnection |](#)
[MMWG | Reliability Assessment](#)



*Typical solution parameters
settings utilized in the MMWG
cases*

General Solution Parameters

Solution Parameters		
General Newton Gauss TYSL Short Circuit Node-Breaker / Contingency		
		Range
5.000	Largest voltage change threshold (BLOWUP)	> 0
0.700	Constant power characteristic threshold (PQBRAK)	(0, 2]
0.000100	Zero impedance line threshold (THRSHZ)	>= 0
0.0050	Automatic adjustment threshold tolerance (ADJTHR)	(0, 2]
1.000	Tap movement deceleration factor (ACCTAP)	(0, 2]
0.05000	Maximum ratio change (TAPLIM)	> 0
100.000	Percent of voltage band switched shunts (SWVBND)	> 0 <= 100
100	Max # of tap/switched shunt adjustment cycles (MXT PSS)	> 0
10	Max # of induction machine state switchings (MXSWIM)	> 0

OK Cancel

Newton Solution Parameters

Solution Parameters		
General Newton Gauss TYSL Short Circuit Node-Breaker / Contingency		
		Range
1.000	Acceleration factor (ACCN)	(0, 2]
1.000	Largest mismatch in MW and Mvar (TOLN)	>= 0
40	Iteration limit (ITMXN)	>= 0
0.990	Largest Delta V (DVLIM)	(.01, 1)
0.990	Non-divergent improvement factor (NDVFCT)	(.1, 1)
1.000	Controlled bus Q mismatch convergence tolerance (VCTOLQ)	> 0
0.000010	Controlled bus voltage error convergence tolerance (VCTOLV)	> 0

OK Cancel

Solve Settings: Area Interchange Control in PSSE

Tie Lines and Loads

Solves net interchange by factoring in both physical boundary tie lines and cross-area load assignments to correctly calculate Area Swing Bus generation.

Used for creating cases

Disabled

Suspends area interchange constraints, allowing the global swing bus to absorb mismatches and grid physics to dictate boundary line flows.

Used in transfer analysis

Tie Lines and Loads

The screenshot shows the 'Power Flow Solutions' dialog box with the 'Newton' tab selected. Under 'Solution method', 'Fixed slope decoupled Newton-Raphson' is selected. Under 'Solution options', 'Stepping' is selected for 'Tap adjustment' and 'Enable all' is selected for 'Switched shunt adjustments'. In the 'Area interchange control' section, 'Tie lines and loads' is selected and circled in red. The 'Do not flat start' dropdown is set to 'Do not flat start'. Under 'VAR limits', 'Apply at 1 iterations' is selected. At the bottom, there are 'Solve', 'Defaults', and 'Close' buttons.

Disabled

The screenshot shows the 'Power Flow Solutions' dialog box with the 'Newton' tab selected. Under 'Solution method', 'Fixed slope decoupled Newton-Raphson' is selected. Under 'Solution options', 'Stepping' is selected for 'Tap adjustment' and 'Enable all' is selected for 'Switched shunt adjustments'. In the 'Area interchange control' section, 'Disabled' is selected and circled in red. The 'Do not flat start' dropdown is set to 'Do not flat start'. Under 'VAR limits', 'Apply immediately' is selected. At the bottom, there are 'Solve', 'Defaults', and 'Close' buttons.

Solve Settings: VAR Limits in PSSE

Apply at 1 Iteration

A standard setting for general power flow planning.

MMWG standard practice

Apply Immediately

Use where the base case is already perfectly solved. Helps with processing automated scripts and analysis.

Apply at 1 Iteration


The screenshot shows the 'Power Flow Solutions' dialog box with the 'Newton' tab selected. The 'Solution method' is 'Fixed slope decoupled Newton-Raphson'. Under 'Solution options', 'Tap adjustment' is 'Stepping' and 'Switched shunt adjustments' is 'Enable all'. Under 'Area interchange control', 'Tie lines and loads' is selected. Under 'VAR limits', 'Apply at 1 Iteration' is selected and circled in red. The 'Show this window when using the Solve toolbar button' checkbox is unchecked. Buttons for 'Solve', 'Defaults', and 'Close' are at the bottom.

Apply Immediately

The screenshot shows the 'Power Flow Solutions' dialog box with the 'Newton' tab selected. The 'Solution method' is 'Fixed slope decoupled Newton-Raphson'. Under 'Solution options', 'Tap adjustment' is 'Stepping' and 'Switched shunt adjustments' is 'Enable all'. Under 'Area interchange control', 'Tie lines and loads' is selected. Under 'VAR limits', 'Apply immediately' is selected and circled in red. The 'Show this window when using the Solve toolbar button' checkbox is unchecked. Buttons for 'Solve', 'Defaults', and 'Close' are at the bottom.

Solve: What to Look For?

One-Line Diagram



When a case solves, review the **iteration history** and the **system mismatch summary** to confirm convergence and locate problem buses.

Iteration Mismatch History

ITER	DELTAP	BUS	DELTAQ	BUS	DELTA/V/	BUS	DELTAANG	BUS
0.0	130.4689(	93041	)	115.2604(	93096	)		
					0.00000(		28.13038(	93041
0.5	103.2894(	93048	)	112.6540(	93096	)		
					0.99000(	93118	)	0.00000(

Blown up after 0 iterations

Worst Bus Mismatches

PSSE Python Command Line:
psspy.list(1,1,1,0)

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS(R)E MON, JUL 20 2026 8:15
2025 SERIES, ERAG/MMWG BASE CASE LIBRARY. CEII DATA
2026 SUMMER PEAK LOAD CASE, FINAL
Worst Mismatches


BUS#-SCT	X--	NAME	--X	BASKV	MW	MVAR	MVA
93041	BUS_93041	34.500	-13046.89	-59.64	13047.02		
93096	BUS_93096	34.500	486.95	-11526.04	11536.32		
93001	BUS_93001	230.00	1592.85	-1430.41	2140.85		
64447	BUS_64447	161.00	-0.10	-0.38	0.40		
65455	BUS_65455	18.000	0.04	0.38	0.39		
64448	BUS_64448	161.00	-0.09	-0.37	0.38		
65456	BUS_65456	18.000	0.04	0.37	0.37		
93119	BUS_93119	0.5750	-0.07	-0.36	0.36		
64449	BUS_64449	161.00	-0.09	-0.34	0.36		
65457	BUS_65457	18.000	0.04	0.34	0.35		
63924	BUS_63924	161.00	0.18	-0.00	0.18		
83530	BUS_83530	0.6900	-0.03	-0.13	0.13		
82756	BUS_82756	345.00	0.02	0.13	0.13		
3WINDTR	* BUS		0.10	-0.00	0.10		
64062	BUS_64062	161.00	-0.09	0.05	0.10		
61325	BUS_61325	138.00	-0.03	-0.09	0.09		
61323	BUS_61323	138.00	-0.03	-0.09	0.09		
61317	BUS_61317	13.800	0.01	0.09	0.09		
61316	BUS_61316	13.800	0.01	0.09	0.09		
93118	BUS_93118	0.5750	-0.02	-0.08	0.08		
61327	BUS_61327	138.00	-0.02	-0.08	0.08		
61319	BUS_61319	13.800	0.01	0.08	0.08		
83517	BUS_83517	34.500	0.07	-0.00	0.07		
61326	BUS_61326	138.00	0.06	-0.00	0.06		
83523	BUS_83523	34.500	-0.05	0.00	0.05		

How to read it

- Iteration history lists the largest active (ΔP) and reactive (ΔQ) mismatches at each step.
- The summary ranks the buses with the worst remaining mismatches.
- Together they show where the solution is struggling to converge.

Solve: After Correction

One-Line Diagram



Once the problem has been corrected, review the **iteration history** and the **system mismatch summary** to confirm convergence.

Iteration Mismatch History

ITER	DELTAP	BUS	DELTAQ	BUS	DELTA/V/	BUS	DELTAANG	BUS
0.0	0.0046(	93041	)	0.0038(	65455	)		
			0.0044(	93001	)			
					0.00000(		0.00008(	93119
0.5	0.0026(	93041	)	0.0040(	65455	)		
			0.0044(	93001	)			
					0.00050(	93119	)	0.00000(
1.0	0.0046(	93041	)	0.0116(	63924	)		
					0.00000(		0.00008(	93119
1.5	0.0026(	93041	)	0.0118(	63924	)		
					0.00050(	93119	)	0.00000(
2.0	0.0046(	93041	)	0.0038(	65455	)		
			0.0044(	93001	)			

Worst Bus Mismatches

PSSE Python Command Line:
psspy.list(1,1,1,0)

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS(R)E							MON, JUL 20 2026 8:14
2025 SERIES, ERAG/MMWG BASE CASE LIBRARY, CEII DATA							WORST
2026 SUMMER PEAK LOAD CASE, FINAL							MISMATCHES
BUS#-SCT	X--	NAME	--X	BASKV	MW	MVAR	MVA
93041	BUS_93041	34.500	0.46	-0.01	0.46		
93001	BUS_93001	230.00	0.06	0.44	0.44		
64447	BUS_64447	161.00	-0.10	-0.38	0.40		
93096	BUS_93096	34.500	-0.39	0.00	0.39		
65455	BUS_65455	18.000	0.04	0.38	0.39		
64448	BUS_64448	161.00	-0.09	-0.37	0.38		
65456	BUS_65456	18.000	0.04	0.37	0.37		
93119	BUS_93119	0.5750	-0.07	-0.36	0.36		
64449	BUS_64449	161.00	-0.09	-0.34	0.36		
65457	BUS_65457	18.000	0.04	0.34	0.35		
63924	BUS_63924	161.00	0.18	-0.00	0.18		
83530	BUS_83530	0.6900	-0.03	-0.13	0.13		
82756	BUS_82756	345.00	0.02	0.13	0.13		
3WINDTR	* BUS		0.10	-0.00	0.10		
64062	BUS_64062	161.00	-0.09	0.05	0.10		
61325	BUS_61325	138.00	-0.03	-0.09	0.09		
61323	BUS_61323	138.00	-0.03	-0.09	0.09		
61317	BUS_61317	13.800	0.01	0.09	0.09		
61316	BUS_61316	13.800	0.01	0.09	0.09		
93118	BUS_93118	0.5750	-0.02	-0.08	0.08		
61327	BUS_61327	138.00	-0.02	-0.08	0.08		
61319	BUS_61319	13.800	0.01	0.08	0.08		
83517	BUS_83517	34.500	0.07	-0.00	0.07		
61326	BUS_61326	138.00	0.06	-0.00	0.06		
83523	BUS_83523	34.500	-0.05	0.00	0.05		

How to read it

- Iteration history lists the largest active (ΔP) and reactive (ΔQ) mismatches at each step.
- The summary ranks the buses with the worst remaining mismatches.
- Together they show where the solution is struggling to converge.

Data Check: PSSE Area Interchange

While in PSSE, check Area Interchange sums to zero.

PSSE Python Command Line: `psspy.area_2(0,1,1)`

Area Interchange Not Zero

X-- AREA --X	FROM GENE- RATION	-----AT FROM IND GENERATN	AREA TO IND MOTORS	BUSES----- TO LOAD	TO BUS SHUNT	TO GNE BUS DEVICES	TO LINE SHUNT	TO XFRMR MAGNE- TIZING	FROM CHARGING	TO LOSSES	-NET INTERCHANGE- TO TIE LINES	TO TIES + LOADS	DESIRED NET INT
1 CENTRAL	1423.9 312.8	2.0 -1.2	0.0 0.0	4163.9 1774.3	15.3 549.8	0.0 0.0	4.8 68.6	18.0 13.7	0.0 1072.7	24.1 326.0	-2800.2 -1348.0	-2800.2 -1348.0	-2800.0
2 EAST	1528.0 232.8	0.0 0.0	10.6 5.6	3057.9 1072.5	18.2 -762.4	0.0 0.0	0.0 -0.0	0.6 2.6	0.0 812.9	36.3 815.5	-1595.5 -88.1	-1595.5 -88.1	-1600.0
3 CENTRAL_DC	2990.7 898.6	0.0 0.0	0.0 0.0	0.0 0.0	0.0 -3457.8	0.0 0.0	0.0 -0.0	0.7 4.6	0.0 0.0	131.5 2377.4	2858.5 1974.5	2858.5 1974.5	2900.0
4 EAST_COGEN1	321.0 142.3	0.0 0.0	0.0 0.0	0.0 0.0	0.0 -0.0	0.0 0.0	0.0 -0.0	0.0 -0.0	0.0 0.0	41.8 142.3	279.2 0.0	279.2 0.0	0.0
5 WEST	1479.0 36.3	5.0 -2.9	1.1 0.6	513.1 205.9	0.0 -1.3	0.0 0.0	0.0 -0.0	0.5 4.1	0.0 52.2	32.2 414.7	937.0 -538.4	937.0 -538.4	900.0
6 EAST_COGEN2	321.0 142.3	0.0 0.0	0.0 0.0	0.0 0.0	0.0 -0.0	0.0 0.0	0.0 -0.0	0.0 -0.0	0.0 0.0	-0.0 142.3	321.0 0.0	321.0 0.0	300.0
COLUMN TOTALS	8063.5 1765.2	7.0 -4.1	11.6 6.2	7734.9 3052.7	33.5 -3671.8	0.0 0.0	4.8 68.6	19.8 24.9	0.0 1937.8	265.9 4218.4	0.0 0.0	0.0 0.0	-300.0

Area Interchange Corrected

X-- AREA --X	FROM GENE- RATION	-----AT FROM IND GENERATN	AREA TO IND MOTORS	BUSES----- TO LOAD	TO BUS SHUNT	TO GNE BUS DEVICES	TO LINE SHUNT	TO XFRMR MAGNE- TIZING	FROM CHARGING	TO LOSSES	-NET INTERCHANGE- TO TIE LINES	TO TIES + LOADS	DESIRED NET INT
1 CENTRAL	1423.9 312.8	2.0 -1.2	0.0 0.0	4163.9 1774.3	15.3 549.8	0.0 0.0	4.8 68.6	18.0 13.7	0.0 1072.7	24.1 326.0	-2800.2 -1348.0	-2800.2 -1348.0	-2800.0
2 EAST	1528.0 232.8	0.0 0.0	10.6 5.6	3057.9 1072.5	18.2 -762.4	0.0 0.0	0.0 -0.0	0.6 2.6	0.0 812.9	36.3 815.5	-1595.5 -88.1	-1595.5 -88.1	-1600.0
3 CENTRAL_DC	2990.7 898.6	0.0 0.0	0.0 0.0	0.0 0.0	0.0 -3457.8	0.0 0.0	0.0 -0.0	0.7 4.6	0.0 0.0	131.5 2377.4	2858.5 1974.5	2858.5 1974.5	2900.0
4 EAST_COGEN1	321.0 142.3	0.0 0.0	0.0 0.0	0.0 0.0	0.0 -0.0	0.0 0.0	0.0 -0.0	0.0 -0.0	0.0 0.0	41.8 142.3	279.2 0.0	279.2 0.0	300.0
5 WEST	1479.0 36.3	5.0 -2.9	1.1 0.6	513.1 205.9	0.0 -1.3	0.0 0.0	0.0 -0.0	0.5 4.1	0.0 52.2	32.2 414.7	937.0 -538.4	937.0 -538.4	900.0
6 EAST_COGEN2	321.0 142.3	0.0 0.0	0.0 0.0	0.0 0.0	0.0 -0.0	0.0 0.0	0.0 -0.0	0.0 -0.0	0.0 0.0	-0.0 142.3	321.0 0.0	321.0 0.0	300.0
COLUMN TOTALS	8063.5 1765.2	7.0 -4.1	11.6 6.2	7734.9 3052.7	33.5 -3671.8	0.0 0.0	4.8 68.6	19.8 24.9	0.0 1937.8	265.9 4218.4	0.0 0.0	0.0 0.0	0.0

MMWG: Power Flow Checker

- MMWG Representative has access to the PowerflowChecker.exe file
- Utilizes only .RAW files

All Power Flow Validation Checks

3W High Resistance	Gen Reactive Power at Limit	Node Voltage Regulation	Small Voltage Band Trans.
3W Overloads	Gen Terminal Voltage	Non-positive RMPCT	Trans. Default R
3W Rating Errors	GTAP Out Of Range	Non-Zero Voltage Band Shunt	Trans. Default V
Area Without Slack Units	High Resistance Branches	Owner Out Of Range	Trans. IO Code
Blank Voltage Fields	Invalid Branch Owner	Parallel 2W XF Circulating Current	Trans. Max below Min
Branch Overloads	Invalid GEN Owner	Parallel 3W XF Circulating Current	Trans. Max or Min at 0
Bus Number Out Of Range	Invalid LOAD Owner	PARS	Trans. Voltage Checks
Bus Voltage	Invalid LOAD Zone	PGEN Outside Range	Trans. with suspect Impedance Correction Table
CNTB Errors	Large Rsource	Poor Load Power Factor	Unique Branch Name
Code 2 Buses Without Machines	Load Region Mismatch	Rating Errors	Unrealistic P _{MAX} and P _{MIN}
Duplicate Bus Names	Machines On Code 1 Buses	Read RAW Line with Differing KV	Unrealistic Q _{MAX} and Q _{MIN}
Gen MBASE	Missing Block 1 Steps	Read RAW Trans. Winding Voltage Mismatch	Zero Impedance ID
Gen Reactive Limit Power Factor	Multiple Swing Buses	Small Voltage Band Shunts	Zone Out Of Range

MMWG: Power Flow Checker

Minimum checks for studies:

- Area interchange balanced
- Swing buses in tolerance
- Generator $P_{Gen} \leq P_{Max}$
- Generator Q_{Gen} in tolerance
- No machines on code 1 buses
- Review overloaded branches $\geq 100kV$
- Branch ratings: Rate B $\geq$ Rate A

MMWG: Power Flow Checker

Sample Rating Check

Area	Number	Name	kV	Area	Number	Name	kV	CKT	Type	Sample Case
100	11311	BUS_11311	230	100	11317	BUS_11317	230	1	Branch	Status: 1 Rating 1: 363.5 Rating 2: 0
100	11350	BUS_11350	161	100	11590	BUS_11590	161	1	Branch	Status: 1 Rating 1: 102.2 Rating 2: 0
100	11295	BUS_11295	230	100	11505	BUS_11505	161	1	2W Tran.	Status: 1 Rating 1: 66 Rating 2: 0
100	11296	BUS_11296	230	100	11528	BUS_11528	161	1	2W Tran.	Status: 1 Rating 1: 75 Rating 2: 0
200	13049	BUS_13049	230	200	13079	BUS_13079	230	1	Branch	Status: 1 Rating 1: 277.8 Rating 2: 0
300	87591	BUS_87591	345	300	88167	BUS_88167	345	1	Branch	Status: 0 Rating 1: 47 Rating 2: 0

MMWG: Power Flow Checker

Sample Branch Overload Check

Area	Number	Name	kV	Area	Number	Name	kV	CKT	Type	Sample Case
100	2849	BUS_2849	230	100	2851	BUS_2851	230	1	Branch	Flow: 455.539 Rating1: 438.2 Load1: 103.96 % Rating2: 438.2 Load2: 103.96 %
400	15677	BUS_15677	230	400	16920	BUS_16920	161	1	2W Tran.	Flow: 45.524 Rating1: 39 Load1: 116.73 % Rating2: 39 Load2: 116.73 %
400	15677	BUS_15677	230	400	16921	BUS_16921	161	1	2W Tran.	Flow: 45.525 Rating1: 39 Load1: 116.73 % Rating2: 39 Load2: 116.73 %
500	98256	BUS_98256	345	500	98257	BUS_98257	345	1	Branch	Flow: 204.935 Rating1: 169.3 Load1: 121.05 % Rating2: 254.2 Load2: 80.62 %

TARA Studio: Solve & Save

Optional step:

- Load RAW file in Tara Studio
- Solve in TARA Studio with Area Interchange set to: Tie lines and loads
- Solve several times getting the iterations down
- Save the RAW file for loading into TARA

Initial Solve

Total Shunts: Continuous=611 Discrete=6426																		
Nit	P_Mism	#bus	VoltMgn	VltAngl	Q_Mism	#bus	VoltMgn	VltAngl	arInterEr	AngChn	#bus	VoltMgn	VltAngl	VM_Chan	#bus	VoltMgn	VltAngl	DeAccFc
1p	-0.545	1569	1.0131	-1.088	425.000	15584	1.0145	-0.671	0.000	-0.00001	999947	1.0008	-1.578					
1q	7143.580	85333	1.0301	-0.931	38005.210	26374	1.0309	-2.162	0.000					0.05847	5839	1.0177	-1.378	
2p	136.102	15523	1.0386	-0.042	18.177	6076	0.9554	-1.843	0.000	0.28520	5870	1.0200	-1.036					
PARS summary: Total 10 PAR Viol. #contrFlows=79. At limit=1																		
2q	-738.698	23640	0.9977	-1.524	2478.623	15523	1.0386	-0.042	0.000					0.12478	16197	1.0263	-0.590	
3p	-734.773	23640	0.9874	-1.524	19.372	15489	1.0366	-0.604	0.000	-0.28425	5871	1.0341	-1.349					
PARS summary: Total 18 PAR Viol. #contrFlows=78. At limit=2																		
3q	-503.208	15822	0.9915	0.054	-47146.480	15533	0.9817	-0.054	0.000					-0.18981	16197	1.2161	-0.590	
4p	56.545	15374	1.0440	-0.067	60.104	16197	1.2161	-0.590	0.000	-0.04890	80536	1.1025	-2.901					
PARS summary: Total 15 PAR Viol. #contrFlows=78. At limit=2																		
4q	-47.078	80535	1.0919	-0.313	-133.239	85347	1.0000	-0.883	0.000					0.13402	15288	0.9800	-0.015	
5p	-46.105	15288	0.9800	-0.015	175.692	80535	1.1616	-0.313	0.000	0.05410	15288	0.9800	0.039					
5q	30.665	15517	1.0018	-0.000	300.803	15530	0.9969	0.005	0.000					0.15000	80535	1.0116	-0.336	0.929
6p	-33.774	80535	1.0116	-0.336	12.198	80535	1.0116	-0.336	0.000	0.04930	80535	1.0116	-0.287					
6q	-11.541	80535	1.0116	-0.287	84.625	16197	1.1905	-0.590	0.000					0.03585	16197	1.1547	-0.590	
7p	-11.564	15517	1.0001	0.000	-7.044	16197	1.1547	-0.590	0.000	-0.01124	15288	1.0051	0.026					
TAPS summary: Total 1 TAP Adjusted #LowVolt=49 #HighVolt=43																		
7q	-3.342	79479	1.0483	-0.221	9.668	16286	1.1496	-0.590	0.000					0.01550	79973	1.0503	-0.693	
Can't adjust dispatch by 0.5 MW for 63612 BUS_63612 13.8 358 806 .																		
Can't adjust dispatch by -0.5 MW for 75455 BUS_75455 25.0 403 403 .																		
Can't adjust dispatch by 0.1 MW for 75304 BUS_75304 13.8 409 409 .																		
8p	3.485	79479	1.0441	-0.221	-0.816	16197	1.1503	-0.590	0.000	0.00394	79973	1.0503	-0.689					
8q	1.522	79479	1.0441	-0.220	3.059	15288	1.0019	0.028	0.000					0.00544	15288	0.9964	0.028	
9p	-1.981	15288	0.9964	0.028	0.217	15288	0.9964	0.028	0.000	0.00219	15288	0.9964	0.030					
9q	-0.642	998266	0.9821	-0.376	-0.515	16286	1.1458	-0.590	0.000					0.00096	15311	0.9581	0.198	
10p	0.445	15374	1.0279	-0.065	0.246	79975	1.0522	-0.207	0.000	0.00037	15311	0.9581	0.199					
10q	-2.273	37911	1.0159	-0.943	0.422	37911	1.0159	-0.943	0.000					-0.00059	15288	0.9972	0.030	
11p	-2.353	37911	1.0159	-0.943	-0.179	15286	1.0085	0.370	0.000	0.00037	95798	1.0078	-1.505					
11q	-0.258	19455	1.0217	-1.270	-0.429	37911	1.0159	-0.943	0.000									

After Multiple Solves

Total Shunts: Continuous=611 Discrete=6426																		
Bit	P_Mism	#bus	VoltMgn	VltAngl	Q_Mism	#bus	VoltMgn	VltAngl	arInterEr	AngChn	#bus	VoltMgn	VltAngl	VM_chan	#bus	VoltMgn	VltAngl	DeAccFc
1p	0.130	61335	1.1292	-0.256	-0.173	61334	1.1251	-0.256	0.000	-0.00003	93273	1.0257	-0.289					
1q	0.085	91316	1.0014	-0.670	-0.240	61334	1.1251	-0.256	0.000					-0.00041	65664	0.9966	-0.310	
Can't adjust dispatch by 0.5 MW for 63612 BUS_63612 13.8 358 806 .																		
Can't adjust dispatch by -0.5 MW for 75455 BUS_75455 25.0 403 403 .																		
Can't adjust dispatch by 0.1 MW for 75304 BUS_75304 13.8 409 409 .																		
2p	-0.285	91125	1.0250	-0.499	-0.006	84298	0.9919	-0.411	0.000	-0.00023	90425	1.0000	-0.954					
2q	0.182	996124	1.0011	-0.671	0.204	65664	0.9966	-0.310	0.000									

TARA: Initial Solve When Loading PSSE RAW File

The **.RAW power-flow case** is imported and loaded into **TARA** to prepare the model for analysis.

TARA Command Window Log

```

C:\WINDOWS\system32\cmd.exe
WarnID-1045-5-164 Reg plant Q range too small for Switch Shunt Mode 3 - discrete shunt at bus [ 14361 BUS_14361 34.5 103 IESO 1108 SOUTH-WEST ] control
MVAR output at remote plant [ 14361 BUS_14361 34.5 ] - Ffixed
WarnID-1038-1-165 Reg bus is not a generator for Switch Shunt Mode 3 - discrete shunt at bus [ 76440 BUS_76440 34.5 416 TECO 416 GEN LOAD ] control
MVAR output at remote plant [ 76440 BUS_76440 34.5 ] - Ffixed
WarnID-1911-1-166 Switch shunt 489 BUS_489 115 101 ISO-NE 100 ISO-NE_CNP has mode 5 not supported by this version - fixed
Total Shunts: Continuous=011 Discrete=6426
Total 11 discrete shunts modeled as continuous during solution placed to the nearest step
Mit: P_Mism #bus VoltMgn VtAngl Q_Mism #bus VoltMgn VtAngl AngChn #bus VoltMgn VtAngl VM_Chn #bus VoltMgn VtAngl DeAccrc
1p -2433.028 31721 1.0050 -0.260 578.038 31883 1.0397 -0.606 0.00442 59114 0.9040 0.109 0.10302 61336 1.0601 -0.236
1q 7140.503 85333 1.0300 -0.926 37758.489 26374 1.0300 -2.156 0.10302 61336 1.0601 -0.236
2p 1057.764 15542 1.0180 0.787 18.206 6076 0.9554 -1.830 0.13326 2859 0.9437 -1.013 -0.12484 16197 1.0224 -0.598
2q 2630.704 1517 1.0429 -0.905 8458.210 1510 1.0429 -0.908 0.12484 16197 1.0224 -0.598
3p -154.265 15523 1.0004 -0.042 23.105 15489 1.0442 -0.676 -0.12479 2860 1.0189 -1.143 -0.19428 16197 1.2167 -0.598
3q -504.298 15822 0.9914 0.054 -47385.515 15533 0.9817 -0.054 -0.19428 16197 1.2167 -0.598
4p -57.011 15774 1.0442 -0.067 81.756 16197 1.2167 -0.598 0.05635 80536 1.1025 -2.099 -0.13335 15288 0.9791 -0.014
4q -47.076 80535 1.0919 -0.311 157.181 75953 1.0485 -0.291 0.13335 15288 0.9791 -0.014
5p 73.313 58583 1.0355 -0.215 175.689 80535 1.1616 -0.311 0.05393 15288 0.9791 0.040 0.15000 80535 1.0116 -0.334 0.929
5q 74.369 58583 1.0355 -0.212 300.546 15330 0.9969 0.005 0.03580 16197 1.1547 -0.598
6p -40.496 76497 1.0029 -0.201 12.196 80535 1.0116 -0.334 0.04876 80535 1.0116 -0.285 0.15000 80535 1.0116 -0.334 0.929
6q 32.508 76523 1.0119 -0.204 84.584 16197 1.1905 -0.598 -0.598 -0.01125 15288 1.0052 0.026 0.03580 16197 1.1547 -0.598
7p -11.550 15117 1.0001 0.000 -7.034 16197 1.1547 -0.598 -0.598 -0.01125 15288 1.0052 0.026 0.03580 16197 1.1547 -0.598
7q -11.550 15117 1.0001 0.000 -7.034 16197 1.1547 -0.598 -0.598 -0.01125 15288 1.0052 0.026 0.03580 16197 1.1547 -0.598
TAPS summary: Total 98 TAP Adjusted #LowVolt=54 #HighVolt=128
Discr Shunts summary: Total 1 Adjusted
7q -9.777 58584 1.0056 -0.218 184.574 12890 1.1103 -1.068 -0.03512 90324 0.9851 -0.485
8p -10.360 90326 0.9921 -0.513 -1.056 90324 0.9851 -0.485 -0.00585 90324 0.9851 -0.490 -0.02649 999681 1.1082 -1.072
TAPS summary: Total 62 TAP Adjusted #LowVolt=48 #HighVolt=180
8q -4.445 90326 0.9921 -0.514 178.766 12890 1.1099 -1.068 -0.02649 999681 1.1082 -1.072
9p -8.474 90326 0.9787 -0.514 1.024 90324 0.9603 -0.490 0.00318 90324 0.9603 -0.486 -0.02775 999681 1.2079 -1.072
TAPS summary: Total 38 TAP Adjusted #LowVolt=51 #HighVolt=73
9q -8.869 90326 0.9787 -0.513 190.165 12890 1.1094 -1.068 -0.02775 999681 1.2079 -1.072
10p -1.580 595 -0.0107 -1.787 -3.252 84360 1.0351 -0.465 -0.00269 84514 0.9942 -0.359 -0.02867 999681 1.2266 -1.072
TAPS summary: Total 22 TAP Adjusted #LowVolt=54 #HighVolt=58
10q -4.305 12890 1.1088 -1.068 -1.068 284.543 12890 1.1088 -1.068 -0.02867 999681 1.2266 -1.072
11p -25.601 90329 1.0176 -0.520 -42.459 90329 1.0176 -0.520 0.00186 90328 1.0171 -0.505 -0.03057 999681 1.2672 -1.072
TAPS summary: Total 10 TAP Adjusted #LowVolt=49 #HighVolt=48
11q 12.520 90330 1.0212 -0.521 221.243 12890 1.1079 -1.068 -0.03057 999681 1.2672 -1.072
12p -10.920 90330 1.0274 -0.521 -15.452 90329 1.0272 -0.518 -0.00211 94408 1.0803 -0.385 -0.03264 999681 1.2998 -1.073
TAPS summary: Total 3 TAP Adjusted #LowVolt=49 #HighVolt=43
12q -5.362 90330 1.0274 -0.521 239.312 12890 1.1072 -1.069 -0.03264 999681 1.2998 -1.073
13p -0.439 90329 1.0272 -0.519 -3.552 90329 1.0272 -0.519 0.00207 13269 1.1300 -1.136 -0.03438 999681 1.3342 -1.073
TAPS summary: Total 5 TAP Adjusted #LowVolt=49 #HighVolt=45
13q -5.561 999681 1.2998 -1.073 259.373 12890 1.1065 -1.069 -0.03438 999681 1.3342 -1.073
14p -1.587 13269 1.1485 -1.136 -2.987 84360 1.0266 -0.466 0.00192 13269 1.1485 -1.134 -0.03624 999681 1.3704 -1.073
TAPS summary: Total 3 TAP Adjusted #LowVolt=49 #HighVolt=43
14q -5.560 999681 1.3342 -1.073 281.737 12890 1.1068 -1.069 -0.03624 999681 1.3704 -1.073
15p -1.646 13269 1.1679 -1.134 -0.189 13269 1.1679 -1.134 0.00293 13269 1.1679 -1.132 -0.01944 5308 0.9322 -1.273
TAPS summary: Total 2 TAP Adjusted #LowVolt=49 #HighVolt=43
15q -0.372 12890 1.1840 -1.009 4.601 5333 0.9032 -1.247 0.01944 5308 0.9322 -1.273
16p -0.405 99826 0.9821 -0.375 -0.178 99826 0.9821 -0.375 -0.00015 13269 1.1684 -1.132 0.01901 5333 0.9252 -1.247
TAPS summary: Total 1 TAP Adjusted #LowVolt=49 #HighVolt=43
16q -0.338 64062 1.0311 -0.375 4.759 5333 0.9442 -1.247 0.01901 5333 0.9252 -1.247
17p -0.405 99826 0.9821 -0.375 0.210 65664 0.9969 -0.309 -0.00004 65664 0.9969 -0.309 0.01272 5333 0.9124 -1.247
TAPS summary: Total 1 TAP Adjusted #LowVolt=49 #HighVolt=43
17q -0.883 99826 0.9821 -0.375 3.207 5333 0.9252 -1.247 0.01272 5333 0.9124 -1.247
18p -1.582 99826 0.9821 -0.375 0.038 97720 1.0203 -1.000 -0.00005 65664 0.9975 -0.309 0.00210 65664 0.9954 -0.309
18q 0.784 64062 1.0311 -0.375 1.289 65664 0.9975 -0.309 0.00210 65664 0.9954 -0.309
19p 1.181 99826 0.9821 -0.375 -0.381 99826 0.9821 -0.375 0.00009 65664 0.9954 -0.308 0.00184 65664 0.9972 -0.309
19q 0.706 99826 0.9821 -0.375 1.112 65664 0.9954 -0.308 0.00184 65664 0.9972 -0.309
20p -0.528 99826 0.9821 -0.375 -0.325 65664 0.9972 -0.308 -0.00006 65664 0.9972 -0.309
20q 0.321 64062 1.0311 -0.375 0.348 65664 0.9972 -0.309
***_2026SUP_2025Series_Final.raw: Fast Dec LF solved in 28 iterations. LargMism(MV) P=0.3209 Q=0.3475 Toln=1.0000

Swing bus dispatch summary
Bus Bus Name Volt Area Areaname Zon ZoneName DispChan curPgen PrevPgen MinPgen MaxPgen curQgen MinQgen MaxQgen VtSched
94641 BUS_94641 13.8 667 MV 1652 NORTHEAST 0.15 98.62 98.47 6.00 102.00 30.64 63.00 63.00 1.0100
91810 BUS_91810 230 997 MIDC-NECC 1603 MAPA_1603 -0.00 19.32 19.32 -250.00 250.00 1.28 -250.00 250.00 1.0300

```

What this shows

- The .RAW case is read in record by record.
- Buses, branches, and other elements build the TARA model.

Why it matters

- Confirms the case imported cleanly before any studies run.
- Warnings listed here should be resolved before solving.

TARA: Initial Solve When Loading TARA Studio RAW File

The solved case from **TARA Studio** is loaded into **TARA** for contingency analysis.

TARA Command Window Log

```

C:\WINDOWS\system32\cmd.exe
[ control_MVAR output at remote plant [ 12677 BUS_12677 34.5 ]. Ffixed
WarnID-1945-3-163 Reg plant Q range too small for Switch Shunt Mode 3 - discrete shunt at bus [ 12680 BUS_12680 34.5 103 IESO 1185 EAST
[ control_MVAR output at remote plant [ 12680 BUS_12680 34.5 ]. Ffixed
WarnID-1945-4-164 Reg plant Q range too small for Switch Shunt Mode 3 - discrete shunt at bus [ 14358 BUS_14358 34.5 103 IESO 1188 SOUTH-WEST
[ control_MVAR output at remote plant [ 14358 BUS_14358 34.5 ]. Ffixed
WarnID-1945-5-165 Reg plant Q range too small for Switch Shunt Mode 3 - discrete shunt at bus [ 14361 BUS_14361 34.5 103 IESO 1188 SOUTH-WEST
[ control_MVAR output at remote plant [ 14361 BUS_14361 34.5 ]. Ffixed
WarnID-1938-1-166 Reg bus is not a generator for Switch Shunt Mode 3 - discrete shunt at bus [ 76440 BUS_76440 34.5 416 TECO 416 GEN LOAD
[ control_MVAR output at remote plant [ 76440 BUS_76440 34.5 ]. Ffixed
WarnID-1911-1-167 Switch shunt 489 BUS_489 115 101 ISO-NE 100 ISONE_ME_CMP has mode 5 not supported by this version - fixed
Total Shunts: Continuous=611 Discrete=6426
Mit P_Mism #bus VoltMgn VltAngl Q_Mism #bus VoltMgn VltAngl AngChn #bus VoltMgn VltAngl VM_Chn #bus VoltMgn VltAngl DeAccfc
1p -0.545 1569 1.0131 -1.088 425.000 15584 1.0145 -0.671 -0.00001 999947 1.0008 -1.578 0.05847 5839 1.0177 -1.378
1q 7143.580 85333 1.0381 -0.931 30085.219 26374 1.0309 -2.162
2p 136.102 15523 1.0386 -0.042 18.177 6076 0.9554 -1.843 0.28520 5870 1.0200 -1.036 0.05847 5839 1.0177 -1.378
PARS summary: Total 10 PAR Viol. #contrFlows=79. At limit=1
2q -738.698 23640 0.9977 -1.524 2478.623 15523 1.0386 -0.042
3p -734.773 23640 0.9874 -1.524 19.372 15480 1.0366 -0.084 -0.28425 5871 1.0341 -1.349 0.12478 16197 1.0263 -0.590
PARS summary: Total 18 PAR Viol. #contrFlows=78. At limit=2
3q -503.208 15822 0.9915 0.054-47146.480 15533 0.9817 -0.054
4p 56.545 15374 1.0440 -0.067 60.104 16197 1.2161 -0.590 -0.04890 80536 1.1025 -2.901 -0.18981 16197 1.2161 -0.590
PARS summary: Total 15 PAR Viol. #contrFlows=78. At limit=2
4q -47.078 80535 1.0019 -0.313 -133.239 85347 1.0000 -0.883
5p -46.105 15288 0.9880 -0.015 175.692 80535 1.1616 -0.313 0.05410 15288 0.9800 0.039 0.13402 15288 0.9800 -0.015
5q 30.665 15517 1.0018 -0.000 300.003 15530 0.9900 0.005
6p -33.774 80535 1.0116 -0.336 12.198 80535 1.0116 -0.336 0.04930 80535 1.0116 -0.287 0.03585 16197 1.1547 -0.590
6q -11.541 80535 1.0116 -0.287 84.625 16197 1.1905 -0.590
7p -11.564 15517 1.0001 0.000 -7.044 16197 1.1547 -0.590 -0.01124 15288 1.0051 0.026 0.01550 79973 1.0503 -0.693
TAPS summary: Total 1 TAP Adjusted #LowVolt=49 #HighVolt=43
7q -3.342 79479 1.0483 -0.221 9.668 16286 1.1496 -0.590
8p 3.485 79479 1.0441 -0.221 -0.816 16197 1.1503 -0.590 0.00393 79973 1.0503 -0.689 0.00544 15288 0.9964 0.028
8q 1.222 79479 1.0441 -0.220 1.059 15288 1.0010 0.028
9p -1.081 15288 0.9964 0.028 0.217 15288 0.9964 0.028 0.00219 15288 0.9964 0.030 0.00098 65664 0.9962 -0.310
9q -0.451 998266 0.9821 -0.376 0.601 65664 0.9972 -0.310
10p 0.445 15374 1.0278 -0.065 0.248 79975 1.0522 -0.207 0.00037 15311 0.9581 0.199 0.00098 65664 0.9962 -0.310
10q 0.435 15389 0.9864 -0.466 -0.400 15288 0.9907 0.030
PMWS_2026SUM_2025Series_Final_TaraStudio.raw. Fast Dec IF solved in 10 iterations. LargMism(MW) P=0.4352 Q=0.4083 Toln=1.0000

Swing bus dispatch summary
Bus# Bus Name Volt Area AreaName Zon ZoneName DispChan curPGen PrevPGen MinPGen MaxPGen curQGen MinQGen MaxQGen VltSched
94641 BUS_94641 13.8 667 MH 1652 NORTHEAST 0.00 98.62 98.62 0.00 102.00 30.64 -63.00 63.00 1.0100
91810 BUS_91810 230 997 MBDC-WECC 1003 WAPA_1003 -0.00 19.32 19.32 -250.00 250.00 1.28 -250.00 250.00 1.0200
84979 BUS_84979 245 999 NECC 999 NECC -0.00 451.20 451.20 -1000.00 1000.00 -133.04 -500.00 500.00 1.0000
84968 BUS_84968 24.0 998 ERCOT 998 Zon_998 -0.00 762.16 762.16 463.00 765.00 216.63 -200.00 275.00 1.0320
84958 BUS_84958 24.0 998 ERCOT 998 Zon_998 -0.00 401.61 401.61 175.00 670.00 87.82 -200.00 400.00 1.0350
65419 BUS_65419 22.0 347 TVA 1360 MUSCLE SHOAL 0.19 1284.61 1284.62 1225.00 1302.50 138.92 -150.00 280.00 1.0400
18020 BUS_18020 230 100 NL - ISLAND 185 ISLAND 0.00 548.59 548.59 -1000.00 1000.00 -54.56 -600.00 600.00 1.0000
15652 BUS_15652 120 104 TE 1151 INTERLG -0.00 -23.76 -23.76 -100.00 100.00 71.41 -100.00 100.00 1.0250
15515 BUS_15515 735 104 TE 1161 735LAVAL -0.01 -0.16 -0.15 -10.00 10.00 -12.82 -5.00 5.00 1.0000
Total Swing Dispatch change = 0.18
Select load flow solution or report function: (L2): [ 0 ]
  
```

What this shows

- The solved network is imported from TARA Studio.
- Each element is listed as the model is rebuilt.

Why it matters

- Verifies the solved model transferred without errors.
- Establishes the base case for contingency analysis.

TARA: Warning Summary

TARA warning summary after initial loading

WarnID	#Warn	Sever	Message	File
1906	1	2-error !	Continuous mode switched shunt with different Vmax and Vmin - shunt fixed	File Sample.raw
6160	20	2-error !	Transformer has high suspicious R/X ratio - make R smaller and X bigger to improve case convergence	File Sample.raw
6185	1	2-error !	Branch has extremely high R/X ratio - make R smaller and X bigger to improve case convergence	File Sample.raw
1200	9	1-info	Float Value out of range	File Sample.raw
1436	4	1-info	FACTS Device has mode online but no capability or it is unsupported mode or it has a data error.	File Sample.raw
1534	12	1-info	Incorrect voltage band width [Vband=0] with discrete switched shunt. Locked during shunt adjustments	File Sample.raw
1800	28	1-info	Bus defined as a generator bus but has no generators	
1830	2	1-info	PAR table used for LTC. Transformer impedance will not be adjusted with Tap ratio adjustments	
1831	2	1-info	LTC table used for PAR. PAR impedance will not be adjusted with PAR angle adjustments	
1923	2	1-info	Incorrect compounding resistance for two-terminal DC Line. Set RCom=RDc	
1925	1	1-info	Rectifier zero ALFMX or ALFMX<ALFMN for two-terminal DC Line	
1928	1	1-info	Inverter GAMMX<GAMMN for two-terminal DC Line	
1945	1	1-info	Reg plant Q range too small for discrete shunt controlling reactive power output of the plant at remote bus-fixed	
6155	1	1-info	Suspicious PAR has R=0 and small X. Increased X to improve flat start	
6159	8	1-info	Branch has high suspicious R/X ratio - make R smaller and X bigger to improve case convergence	File Sample.raw
1100	1	0-comment	Number of completed input files. See warnings details for # of lines read in	
1842	1	0-comment	Shutdown buses not connected to swing	
1878	81	0-comment	Transformer remote control bus is connected to its terminal via low impedance line - controlling terminal instead	
1911	1	0-comment	Switch shunt has mode not supported yet - fixed	

Severity Level: 1-info; 2-error; 3-potentially critical; 4-critical error

TARA: Warning Summary List

TARA warning list will provide more detail, file name and the line where the error was found

WarnID	SeverLvl	Message	File	Line
1906	2	752 Bus-752 continuous mode switched shunt with different Vmax [1.0450] and Vmin [1.0150] - shunt fixed.	File Sample.raw	400413
6160	2	2W Transformer [123 Bus-123 27.6 101 116 456 Bus-456 99.0 101 116] has high suspicious R/X ratio [11.55] > 10.00. R= 0.00578 X= 0.00050 Suggested R= 0.00500	File Sample.raw	398242
6185	2	Branch [12345 Bus-12345 69.0 233 268 23456 Bus-23456 69.0 233 268] has extremely high R/X ratio [173.00] > 100.00. R= 0.01730 X= 0.00010 Suggested R= 0.00100	File Sample.raw	198774
1200	1	machRSource Float Value 100000000.000000 is out of range [-999999.000000-9999999.000000]. Using default=0.000000	File Sample.raw	160454
1200	1	Float Value 34.500000 is out of range [0.000001-2.000000]. Using default=0.050000	File Sample.raw	399734
1436	1	FACTS Device has mode online but no capability or it is unsupported mode or it has a data error. [45 DVAR] Series link operating as a SSSC and shunt link is disabled by SHMX=0 and TRMX=0. Mode=1	File Sample.raw	399752
1534	1	Incorrect voltage band width [Vband=0] with discrete switched shunt at [500 Bus-500 69.0 235 289].	File Sample.raw	402412
1800	1	Bus 100 Bus-100 22.0 defined as a generator bus has no generators		
1830	1	PAR table 1 range [-60.00:60.00] used for LTC 667 Bus-667 260 Bus-260 1 with regul range [0.00:0.00]. change table# to zero		
1831	1	LTC table 88 range [1.00:1.00] used for PAR 703 Bus-703 665 Bus-665 1 with regul range [-120.00:120.00]		
1923	1	Compounding resistance(RComp)= 0.02500 > dc line resistance(RDC)= 0.00010 for two-terminal DC Line 31. Set RComp=RDc		
1923	1	Compounding resistance(RComp)= 0.02500 > dc line resistance(RDC)= 0.01000 for two-terminal DC Line 32. Set RComp=RDc		
1925	1	Rectifier ALFMX(0.31084) < ALFMN(0.38066) for two-terminal DC Line 11		
1928	1	Inverter has GAMMX(0.26494) < GAMMN(0.33475) for two-terminal DC Line 11		
1945	1	Reg plant Q range too small for Switch Shunt Mode 3 - discrete shunt at bus [660 Bus-660 680 XYZ] control MVAR output at remote plant [660 Bus-660]. Ffixed		
6155	1	Suspicious PAR [780 Bus-780 101 100 193 Bus-193 101 100] has R=0 and small X=0.00050 with Phase angle =30.000 Check data. Winding=1 Increased X to improve flat start		
6159	1	Branch [567 Bus-567 102 145 890 Bus-890 102 145] has high suspicious R/X ratio [20.00] > 10.00. R= 0.00020 X= 0.00001 Suggested R= 0.00010	File Sample.raw	183901
1100	0	Read in 408780 records from File [Sample.raw] (Lev=1)		
1842	0	Total shut down 2 buses not connected to swing. Total 109203 buses		
1878	0	Transformer [439 Bus-439 101 100 211 Bus-211] remotely controlled bus {416 Bus-416 } connected to fromBus via ZIL - changed to control fromBus		
1911	0	Switch shunt 750 Bus-750 101 BCD 100 ABC has mode 5 not supported by this version - fixed		

Thank You

Steady State Contingency File Creation/Maintenance Process at ATC

PRESENTED BY:

Kerry Marinar P.E.

Principal Transmission Planning Engineer


August 6, 2026

- ATC Proprietary -

atcllc.com

Introducing ATC

- Wisconsin-based company
- Over 5 million electric consumers in service area
- Over 500 employees making sure you have the energy you need, when you need it



Topics:

- 1. How are steady state contingency files developed at ATC?
- 2. How are steady state contingency files maintained at ATC?
- 3. How are steady state contingency files confirmed for completeness and accuracy?

How are the System Planning models maintained and developed at ATC

System Planning Model Development

1. The ATC Planning model development/model maintenance process begins with the establishment of a reference model.
 - a. The reference model is established once a year as the foundation from which all future year models are constructed from.
 - b. The reference model is based on the August MISO Model on Demand base case model.
 - c. All new future projects are written to work with the reference model and all projects that have been placed in service, prior to August, are archived.
2. Files to support the development of future models are updated and maintained. The following are a few of the key supporting files
 - a. A master ATC bus number list with all of the ATC area assigned bus numbers is maintained.
 - All existing bus numbers are documented with their powerflow 12-character name, English or long name, EMS reference point and NERC generator EIA code as applicable.
 - Unused bus numbers are assigned to projects as they are developed with the project file/name referenced, so that there is no potential of multiple projects assigning the same bus number.
 - b. Each future project file/lddev is named by “In-service date / geographic location / brief high-level description”.
 - This allows the files to be easily sorted by their planned in-service date, locate the general project area and identify the project type/description. (See the example file at the end of the presentation)

How are steady state contingency files maintained at ATC?

Steady State Contingency File Maintenance

- The ATC NERC TPL-001-5 steady state contingencies are maintained in spreadsheet form.
 - All as-built contingencies types are maintained on a separate spreadsheet tab and listed in order by voltage and substation or line name. Future contingency definitions are listed below the as-built definitions in order by decreasing voltage and alphabetically by substation or line name.
 - The names of future projects/ldes that result in new contingencies or changes to existing contingencies are listed on a separate tab that allows for the enabling or disabling of selected future contingencies by entering the letter “P” for the project status.
 - An effective date for the model is entered and the master file filters out existing and future contingencies based on the effective date and the project status. Since future projects/ldes are named with their in-service date, the date can be used to enable /disable future contingencies.
 - As-built and future contingencies are maintained on an ongoing basis.

Master Contingency File Example


Maintain this section with new Contingencies, project status changes and ISD changes										Output Contingency File		
STATUS										ES" Log	LL" Log	Output:
ex	COM	*****								FALSE	TRUE	COM **
ex	COM	***** BEGIN EXISTING 69kV Contingencies *****								FALSE	TRUE	COM **
ex	COM	*****								FALSE	TRUE	COM **
ex										FALSE	TRUE	
RT	Contingency	'NB22:69:ATC:STG69:1'/3 / STAGECOACH 69 kV BUS SECTION 1 FAULT	P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv						FALSE	TRUE	Contingency 'NB22:69:ATC:STG69
RT	OPEN LINE	FROM BUS 693889 TO BUS 698131 CKT 1 / Y-128 WALLY RD - STAGECOACH 69	P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv						FALSE	TRUE	OPEN LINE FROM BUS 693889 TC
RT	OPEN LINE	FROM BUS 698130 TO BUS 698131 CKT 1 / Y-62 BLACK EARTH - STAGECOACH 69	P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv						FALSE	TRUE	OPEN LINE FROM BUS 698130 TC
RT	OPEN LINE	FROM BUS 698131 TO BUS 698686 CKT 2 / Y-141 STAGECOACH - CROSS PLAINS 69	P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv						FALSE	TRUE	OPEN LINE FROM BUS 698131 TC
RT	OPEN LINE	FROM BUS 698131 TO BUS 698133 CKT 1 / 6927 STAGECOACH - TIMBERLANE TAP 69	P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv						FALSE	TRUE	OPEN LINE FROM BUS 698131 TC
RT	End		P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv						FALSE	TRUE	End
ex	Contingency	'NB22:69:ATC:WTN69:1'/3 / WEST TOWNE 69 kV BUS SECTION 1 FAULT								FALSE	TRUE	Contingency 'NB22:69:ATC:WTN69
ex	OPEN LINE	FROM BUS 698138 TO BUS 698167 CKT 1 / 6998 CROSS COUNTRY - WEST TOWNE 69								FALSE	TRUE	OPEN LINE FROM BUS 698138 TC
ex	OPEN LINE	FROM BUS 698674 TO BUS 698167 CKT 2 / WEST TOWN BUS TIE 69								FALSE	TRUE	OPEN LINE FROM BUS 698674 TC
ex	End									FALSE	TRUE	End
RT	Contingency	'NB22:69:ATC:W_MARINET:3'/4 / WEST MARINETTE 69 kV BUS SECTION 3 FAULT	0	20240930_24_T-D_WPS_Scott_Paper_SS_Rebuild.idv						FALSE	FALSE	COM Contingency 'NB22:69:ATC:W
RT	OPEN LINE	FROM BUS 698620 TO BUS 699658 CKT 1 / H-60 SPCT - WEST MARINETTE 69	0	20240930_24_T-D_WPS_Scott_Paper_SS_Rebuild.idv						FALSE	FALSE	COM OPEN LINE FROM BUS 69862
RT	OPEN LINE	FROM BUS 699659 TO BUS 699658 CKT 1 / WEM-T1 W.MARNET - W.MARNET 138 - 69	0	20240930_24_T-D_WPS_Scott_Paper_SS_Rebuild.idv						FALSE	FALSE	COM OPEN LINE FROM BUS 69965
RT	OPEN LINE	FROM BUS 699658 TO BUS 698621 CKT 1 / Y-299 W MARINETTE - WELLS ST 69 (1 Mi UG)	0	20240930_24_T-D_WPS_Scott_Paper_SS_Rebuild.idv						FALSE	FALSE	COM OPEN LINE FROM BUS 69965
RT	End		0	20240930_24_T-D_WPS_Scott_Paper_SS_Rebuild.idv						FALSE	FALSE	COM End
ex	COM	*****								FALSE	TRUE	COM **
ex	COM	***** BEGIN FUTURE 69 kV Contingencies *****								FALSE	TRUE	COM **
ex	COM	*****								FALSE	TRUE	COM **
f	Contingency	'NB22:69:ATC:STG69:1'/3 / STAGECOACH 69 kV BUS SECTION 1 FAULT	P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv						FALSE	FALSE	COM Contingency 'NB22:69:ATC:6
f	OPEN LINE	FROM BUS 693889 TO BUS 698131 CKT 1 / Y-128 WALLY RD - STAGECOACH 69	P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv						FALSE	FALSE	COM OPEN LINE FROM BUS 69388
f	OPEN LINE	FROM BUS 698154 TO BUS 698131 CKT 1 / Y-62 BLACK EARTH TAP2- STAGECOACH 69	P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv						FALSE	FALSE	COM OPEN LINE FROM BUS 69815
f	OPEN LINE	FROM BUS 698131 TO BUS 698686 CKT 2 / Y-141 STAGECOACH - CROSS PLAINS 69	P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv						FALSE	FALSE	COM OPEN LINE FROM BUS 69813
f	OPEN LINE	FROM BUS 698131 TO BUS 698133 CKT 1 / 6927 STAGECOACH - TIMBERLANE TAP 69	P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv						FALSE	FALSE	COM OPEN LINE FROM BUS 69813
f	End		P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv						FALSE	FALSE	COM End
i	Contingency	'NB22:69:ATC:W_MARINET:3'/4 / WEST MARINETTE 69 kV BUS SECTION 3 FAULT	0	20240930_24_T-D_WPS_Scott_Paper_SS_Rel 0 20251201_24_AM_WestMarinette_Tri						FALSE	FALSE	COM Contingency 'NB22:69:ATC:W
i	OPEN LINE	FROM BUS 693621 TO BUS 699658 CKT 1 / H-60 KC PAPER - WEST MARINETTE 69	0	20240930_24_T-D_WPS_Scott_Paper_SS_Rel 0 20251201_24_AM_WestMarinette_Tri						FALSE	FALSE	COM OPEN LINE FROM BUS 69362
i	OPEN LINE	FROM BUS 699659 TO BUS 699658 CKT 1 / WEM-T1 W.MARNET - W.MARNET 138 - 69	0	20240930_24_T-D_WPS_Scott_Paper_SS_Rel 0 20251201_24_AM_WestMarinette_Tri						FALSE	FALSE	COM OPEN LINE FROM BUS 69965
i	OPEN LINE	FROM BUS 699658 TO BUS 698621 CKT 1 / Y-299 W MARINETTE - WELLS ST 69	0	20240930_24_T-D_WPS_Scott_Paper_SS_Rel 0 20251201_24_AM_WestMarinette_Tri						FALSE	FALSE	COM OPEN LINE FROM BUS 69965
i	End		0	20240930_24_T-D_WPS_Scott_Paper_SS_Rel 0 20251201_24_AM_WestMarinette_Tri						FALSE	FALSE	COM End
f	Contingency	'NB22:69:ATC:W_MARINET:3'/4 / WEST MARINETTE 69 kV BUS SECTION 3 FAULT	0	20251201_24_AM_WestMarinette_Tri_Replacement.idv						FALSE	TRUE	Contingency 'NB22:69:ATC:W_MAF
f	OPEN LINE	FROM BUS 699658 TO BUS 698626 CKT 1 / G-59 WEST MARINETTE - MENOMINEE 69	0	20251201_24_AM_WestMarinette_Tri_Replacement.idv						FALSE	TRUE	OPEN LINE FROM BUS 699658 TC
f	OPEN LINE	FROM BUS 699659 TO BUS 699658 CKT 1 / WEM-T1 W.MARNET - W.MARNET 138 - 69	0	20251201_24_AM_WestMarinette_Tri_Replacement.idv						FALSE	TRUE	OPEN LINE FROM BUS 699659 TC
f	OPEN LINE	FROM BUS 699658 TO BUS 698621 CKT 1 / Y-299 W MARINETTE - WELLS ST 69	0	20251201_24_AM_WestMarinette_Tri_Replacement.idv						FALSE	TRUE	OPEN LINE FROM BUS 699658 TC
f	End		0	20251201_24_AM_WestMarinette_Tri_Replacement.idv						FALSE	TRUE	End

DEMO

How are steady state contingency files confirmed for completeness and accuracy

Steady State Contingency File Error Checking

One method for testing contingencies for errors using PSSE is to build a Distribution Factor Data file (DFAX) using PSSE and a Subsystem and Monitored Element file.



The resultant errors will show up in the progress window.

No contingency events specified--contingency "P12:138:ATC:836:OCCRK-2:OAKVIEW:NLL" skipped

** Record 653: OPEN LINE FROM BUS 699198 TO BUS 699955 CKT 1 / 8241 PLYMOUTH#5 - SAUKVILLE 4 138
Bus not found: 699198

No contingency events specified--contingency "P12:138:ATC:X-181:SUN138:JOHNSTOWN:NLL" skipped

** Record 3970: OPEN LINE FROM BUS 699963 TO BUS 699950 CKT 1 / 4434 JOHNSTOWN - LAKEHEAD DELEVAN TAP 138
Bus not found: 699963

Steady State Contingency File Error Checking Cont.

Another method for testing contingencies for errors using TARA is to load the model, Subsystem and Monitored Element files and review the “Warn_List” tab for Warning IDs “3071”.

10	WarnInd	WarnID	SeverLv1	Message
286	276	3071	2	Contingency 136 P12:138:ATC:8241:PLYMOUTH#5:SAUKVL4:NLL was added with 1 error(s)
358	348	3071	2	Contingency 932 P12:138:ATC:4434:JOHNSTOWN:WHTWTR3:NLL was added with 1 error(s)

Steady State Contingency File Error Checking Cont.

ATC has developed an in-house tool that will read in all the various contingency files associated with the model and perform error checking on them. A RAW version of the PSSE model and the contingency files are required.

The tool checks the connections in each contingency to ensure the match with the model topology and if not, a report can be generated containing the contingency name and the element that has failed the mapping test.

The tool also checks for ATC area branches that are not included in any of the ATC category P1 contingencies and creates a CSV that can be opened/filtered and reviewed to ensure proper category P1 contingency coverage.

DEMO



Contact info: kmarinan@atcllc.com



[illegible]

BAT_LOAD_DATA_6,698595,'1',1,696,1689,691,1,0,0,0,0,0,0,0,0,0,0,0,0,0," " / GENERIC SS Load #1 placeholder
BAT_LOAD_DATA_6,698595,'2',1,696,1689,691,1,0,0,0,0,0,0,0,0,0,0,0,0,0," " / GENERIC SS Load #2 placeholder

Steady State Contingency File Creation/Maintenance Process at ATC

PRESENTED BY:

Kerry Marinar P.E.

Principal Transmission Planning Engineer


August 6, 2026

- ATC Proprietary -

atcllc.com

Introducing ATC

- Wisconsin-based company
- Over 5 million electric consumers in service area
- Over 500 employees making sure you have the energy you need, when you need it



Topics:

- 1. How are steady state contingency files developed at ATC?
- 2. How are steady state contingency files maintained at ATC?
- 3. How are steady state contingency files confirmed for completeness and accuracy?

How are the System Planning models maintained and developed at ATC

System Planning Model Development

1. The ATC Planning model development/model maintenance process begins with the establishment of a reference model.
 - a. The reference model is established once a year as the foundation from which all future year models are constructed from.
 - b. The reference model is based on the August MISO Model on Demand base case model.
 - c. All new future projects are written to work with the reference model and all projects that have been placed in service, prior to August, are archived.
2. Files to support the development of future models are updated and maintained. The following are a few of the key supporting files
 - a. A master ATC bus number list with all of the ATC area assigned bus numbers is maintained.
 - All existing bus numbers are documented with their powerflow 12-character name, English or long name, EMS reference point and NERC generator EIA code as applicable.
 - Unused bus numbers are assigned to projects as they are developed with the project file/name referenced, so that there is no potential of multiple projects assigning the same bus number.
 - b. Each future project file/lddev is named by “In-service date / geographic location / brief high-level description”.
 - This allows the files to be easily sorted by their planned in-service date, locate the general project area and identify the project type/description. (See the example file at the end of the presentation)

How are steady state contingency files maintained at ATC?

Steady State Contingency File Maintenance

- The ATC NERC TPL-001-5 steady state contingencies are maintained in spreadsheet form.
 - All as-built contingencies types are maintained on a separate spreadsheet tab and listed in order by voltage and substation or line name. Future contingency definitions are listed below the as-built definitions in order by decreasing voltage and alphabetically by substation or line name.
 - The names of future projects/ldes that result in new contingencies or changes to existing contingencies are listed on a separate tab that allows for the enabling or disabling of selected future contingencies by entering the letter “P” for the project status.
 - An effective date for the model is entered and the master file filters out existing and future contingencies based on the effective date and the project status. Since future projects/ldes are named with their in-service date, the date can be used to enable /disable future contingencies.
 - As-built and future contingencies are maintained on an ongoing basis.

Master Contingency File Example


Maintain this section with new Contingencies, project status changes and ISD changes										Output Contingency File		
STATUS				20251201				SES" Log	LL" Log	Output:		
ex	COM	*****								FALSE	TRUE	COM
ex	COM	***** BEGIN EXISTING 69kV Contingencies *****								FALSE	TRUE	COM
ex	COM	*****								FALSE	TRUE	COM
RT	Contingency	'NB22:69:ATC:STG69:1' / 3	/ STAGECOACH 69 kV BUS SECTION 1 FAULT	P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv	FALSE	TRUE	Contingency 'NB22:69:ATC:STG69:1' / 3				
RT	OPEN LINE FROM BUS	XXXXX TO BUS XXXXX	CKT 1 / Y-128 WALLY RD - STAGECOACH 69	P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv	FALSE	TRUE	OPEN LINE FROM BUS 693889 TO				
RT	OPEN LINE FROM BUS	XXXXX TO BUS XXXXX	CKT 1 / Y-62 BLACK EARTH - STAGECOACH 69	P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv	FALSE	TRUE	OPEN LINE FROM BUS 698130 TO				
RT	OPEN LINE FROM BUS	XXXXX TO BUS XXXXX	CKT 2 / Y-141 STAGECOACH - CROSS PLAINS 69	P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv	FALSE	TRUE	OPEN LINE FROM BUS 698131 TO				
RT	OPEN LINE FROM BUS	XXXXX TO BUS XXXXX	CKT 1 / 6927 STAGECOACH - TIMBERLANE TAP 69	P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv	FALSE	TRUE	OPEN LINE FROM BUS 698131 TO				
RT	End			P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv	FALSE	TRUE	End				
ex	Contingency	'NB22:69:ATC:WTN69:1' / 3	/ WEST TOWNE 69 kV BUS SECTION 1 FAULT			FALSE	TRUE	Contingency 'NB22:69:ATC:WTN69:1' / 3				
ex	OPEN LINE FROM BUS	XXXXX TO BUS XXXXX	CKT 1 / 6998 CROSS COUNTRY - WEST TOWNE 69			FALSE	TRUE	OPEN LINE FROM BUS 698130 TO				
ex	OPEN LINE FROM BUS	XXXXX TO BUS XXXXX	CKT 2 / WEST TOWN BUS TIE 69			FALSE	TRUE	OPEN LINE FROM BUS 698674 TO				
ex	End					FALSE	TRUE	End				
RT	Contingency	'NB22:69:ATC:W MARINET:3' / 4	/ WEST MARINETTE 69 kV BUS SECTION 3 FAULT	0	20240930_24_T-D_WPS_Scott_Paper_SS_Rebuild.idv	FALSE	FALSE	COM Contingency 'NB22:69:ATC:W MARINET:3' / 4				
RT	OPEN LINE FROM BUS	XXXXX TO BUS XXXXX	CKT 1 / H-60 SPCT - WEST MARINETTE 69	0	20240930_24_T-D_WPS_Scott_Paper_SS_Rebuild.idv	FALSE	FALSE	COM OPEN LINE FROM BUS 69862				
RT	OPEN LINE FROM BUS	XXXXX TO BUS XXXXX	CKT 1 / WEM-T1 W.MARNET - W.MARNET 138 - 69	0	20240930_24_T-D_WPS_Scott_Paper_SS_Rebuild.idv	FALSE	FALSE	COM OPEN LINE FROM BUS 69965				
RT	OPEN LINE FROM BUS	XXXXX TO BUS XXXXX	CKT 1 / Y-299 W MARINETTE - WELLS ST 69 (1 Mi UG)	0	20240930_24_T-D_WPS_Scott_Paper_SS_Rebuild.idv	FALSE	FALSE	COM OPEN LINE FROM BUS 69965				
RT	End			0	20240930_24_T-D_WPS_Scott_Paper_SS_Rebuild.idv	FALSE	FALSE	COM End				
ex	COM	*****								FALSE	TRUE	COM
ex	COM	***** BEGIN FUTURE 69 kV Contingencies *****								FALSE	TRUE	COM
ex	COM	*****								FALSE	TRUE	COM
f	Contingency	'NB22:69:ATC:STG69:1' / 3	/ STAGECOACH 69 kV BUS SECTION 1 FAULT	P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv	FALSE	FALSE	COM Contingency 'NB22:69:ATC:STG69:1' / 3				
f	OPEN LINE FROM BUS	XXXXX TO BUS XXXXX	CKT 1 / Y-128 WALLY RD - STAGECOACH 69	P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv	FALSE	FALSE	COM OPEN LINE FROM BUS 693889 TO				
f	OPEN LINE FROM BUS	XXXXX TO BUS XXXXX	CKT 1 / Y-62 BLACK EARTH TAP2- STAGECOACH 69	P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv	FALSE	FALSE	COM OPEN LINE FROM BUS 698130 TO				
f	OPEN LINE FROM BUS	XXXXX TO BUS XXXXX	CKT 2 / Y-141 STAGECOACH - CROSS PLAINS 69	P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv	FALSE	FALSE	COM OPEN LINE FROM BUS 698131 TO				
f	OPEN LINE FROM BUS	XXXXX TO BUS XXXXX	CKT 1 / 6927 STAGECOACH - TIMBERLANE TAP 69	P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv	FALSE	FALSE	COM OPEN LINE FROM BUS 698131 TO				
f	End			P	20250601_23_T-D_BEEU_Black_Earth_2nd_Tap.idv	FALSE	FALSE	COM End				
i	Contingency	'NB22:69:ATC:W MARINET:3' / 4	/ WEST MARINETTE 69 kV BUS SECTION 3 FAULT	0	20240930_24_T-D_WPS_Scott_Paper_SS_Rel 0 20251201_24_AM_WestMarinette_Tri	FALSE	FALSE	COM Contingency 'NB22:69:ATC:W MARINET:3' / 4				
i	OPEN LINE FROM BUS	XXXXX TO BUS XXXXX	CKT 1 / H-60 KC PAPER - WEST MARINETTE 69	0	20240930_24_T-D_WPS_Scott_Paper_SS_Rel 0 20251201_24_AM_WestMarinette_Tri	FALSE	FALSE	COM OPEN LINE FROM BUS 693889 TO				
i	OPEN LINE FROM BUS	XXXXX TO BUS XXXXX	CKT 1 / WEM-T1 W.MARNET - W.MARNET 138 - 69	0	20240930_24_T-D_WPS_Scott_Paper_SS_Rel 0 20251201_24_AM_WestMarinette_Tri	FALSE	FALSE	COM OPEN LINE FROM BUS 69965				
i	OPEN LINE FROM BUS	XXXXX TO BUS XXXXX	CKT 1 / Y-299 W MARINETTE - WELLS ST 69	0	20240930_24_T-D_WPS_Scott_Paper_SS_Rel 0 20251201_24_AM_WestMarinette_Tri	FALSE	FALSE	COM OPEN LINE FROM BUS 69965				
i	End			0	20240930_24_T-D_WPS_Scott_Paper_SS_Rel 0 20251201_24_AM_WestMarinette_Tri	FALSE	FALSE	COM End				
f	Contingency	'NB22:69:ATC:W MARINET:3' / 4	/ WEST MARINETTE 69 kV BUS SECTION 3 FAULT	0	20251201_24_AM_WestMarinette_Tri_Replacement.idv	FALSE	TRUE	Contingency 'NB22:69:ATC:W MARINET:3' / 4				
f	OPEN LINE FROM BUS	XXXXX TO BUS XXXXX	CKT 1 / G-59 WEST MARINETTE - MENOMINEE 69	0	20251201_24_AM_WestMarinette_Tri_Replacement.idv	FALSE	TRUE	OPEN LINE FROM BUS 699650 TO				
f	OPEN LINE FROM BUS	XXXXX TO BUS XXXXX	CKT 1 / WEM-T1 W.MARNET - W.MARNET 138 - 69	0	20251201_24_AM_WestMarinette_Tri_Replacement.idv	FALSE	TRUE	OPEN LINE FROM BUS 699655 TO				
f	OPEN LINE FROM BUS	XXXXX TO BUS XXXXX	CKT 1 / Y-299 W MARINETTE - WELLS ST 69	0	20251201_24_AM_WestMarinette_Tri_Replacement.idv	FALSE	TRUE	OPEN LINE FROM BUS 699650 TO				
f	End			0	20251201_24_AM_WestMarinette_Tri_Replacement.idv	FALSE	TRUE	End				

DEMO

How are steady state contingency
files confirmed for completeness and
accuracy

Steady State Contingency File Error Checking

One method for testing contingencies for errors using PSSE is to build a Distribution Factor Data file (DFAX) using PSSE and a Subsystem and Monitored Element file.



The resultant errors will show up in the progress window.

No contingency events specified--contingency "P12:138:ATC:836:OCCRK-2:OAKVIEW:NLL" skipped

** Record 653: OPEN LINE FROM BUS 699198 TO BUS XXXXXX CKT 1 / 8241 PLYMOUTH#5 - SAUKVILLE 4 138
Bus not found: 699198

No contingency events specified--contingency "P12:138:ATC:X-181:SUN138:JOHNSTOWN:NLL" skipped

** Record 3970: OPEN LINE FROM BUS 699963 TO BUS XXXXXX CKT 1 / 4434 JOHNSTOWN - LAKEHEAD DELEVAN TAP 138
Bus not found: 699963

Steady State Contingency File Error Checking Cont.

Another method for testing contingencies for errors using TARA is to load the model, Subsystem and Monitored Element files and review the “Warn_List” tab for Warning IDs “3071”.

10	WarnInd	WarnID	SeverLv1	Message
286	276	3071	2	Contingency 136 P12:138:ATC:8241:PLYMOUTH#5:SAUKVL4:NLL was added with 1 error(s)
358	348	3071	2	Contingency 932 P12:138:ATC:4434:JOHNSTOWN:WHTWTR3:NLL was added with 1 error(s)

Steady State Contingency File Error Checking Cont.

ATC has developed an in-house tool that will read in all the various contingency files associated with the model and perform error checking on them. A RAW version of the PSSE model and the contingency files are required.

The tool checks the connections in each contingency to ensure the match with the model topology and if not, a report can be generated containing the contingency name and the element that has failed the mapping test.

The tool also checks for ATC area branches that are not included in any of the ATC category P1 contingencies and creates a CSV that can be opened/filtered and reviewed to ensure proper category P1 contingency coverage.

DEMO



Contact info: kmarinan@atcllc.com



Example Idev “20271115_Z1_T-D_Generic.idv”

```


VERSION 35
@!TEXT Author: kpm
@!TEXT
@!TEXT Project Name: New Generic 115 kV DIC
@!TEXT
@!TEXT MTEP PID:#####, Target Appendix A in MTEP26
@!TEXT LIRF:#####, PR:??????, ATC cost:$????, FP:???, WO:????
@!TEXT
@!TEXT Description:
@!TEXT -Construct a new substation and install two new 115/24.9kV, 33/38 MVA transformers with circuit breakers for high-side protection.
@!TEXT -Construct new 115kV loop through configuration at the new substation per ATC substation design standards.
@!TEXT -Install bus-side line disconnect switches on each incoming line at the substation. Provisions shall be made for future line circuit breakers
@!TEXT and line-side disconnect switches.
@!TEXT -Install two line circuit breakers at the substation. Provisions shall be made for a future bus-tie circuit breaker.
@!TEXT -Reroute the existing LINE1 Substation_A - Substation_B 115kV line and construct new double circuit 115kV transmission line (Approx. 0.3 miles)
@!TEXT to the new substation.
@!TEXT -Assumption: Cut LINE1 between structures 114 & 115 and construct 0.3 miles of double circuit 115 kV to the new GENERIC SS

```

[illegible]

BAT_LTOP,690008,690010,'1',0.6142,690009,'GENERIC SS ',115.0 / Tap GENERIC SS into LINE1 about 61.42% of the way from Substation_A
 BAT_BUS_CHNG_4,690009,0,,691,1999,690,,,,, 1.05, 0.95,,,,, / Set bus normal Vhi & Vlo per unit values
 BAT_BRANCH_CHNG_3,690009,690010,'1',,,,,,0.00123,0.00831,0.00101,,,,,1.45,,,,,205,279,,,,,,,'ATC:ATC:LINE1b:GENRC:SUB-B:115' / FN-FE-WN-WE-SPN-SPE = 228-292-243-304-220-291 MVA
 BAT_BRANCH_CHNG_3,690009,690008,'1',,,,,,0.00189,0.01245,0.00168,,,,,2.19,,,,,205,279,,,,,,,'ATC:ATC:LINE1a:GENRC:SUB-A:115' / FN-FE-WN-WE-SPN-SPE = 228-292-243-304-220-291 MVA

BAT_LOAD_DATA_6,698595,'1',1,696,1689,691,1,0,0,0,0,0,0,0,0,0,0,0,0,0," " / GENERIC SS Load #1 placeholder
BAT_LOAD_DATA_6,698595,'2',1,696,1689,691,1,0,0,0,0,0,0,0,0,0,0,0,0,0," " / GENERIC SS Load #2 placeholder



Contingency Presentation 2026 RF Planning Workshop


8/6/2026

Carter Leatherman


DLC Transmission Planning

Duquesne Light Company

Introduction




- Investor-owned Transmission and Distribution Utility in Southwestern PA
- Territory covers the City of Pittsburgh and nearby communities in Allegheny and Beaver Counties, 812 sq. miles in total
- ~600,000 customers
- ~150mi of 345kV & ~500mi of 138kV
- Peak load of ~2,700MW



Outline


- Background of Contingency Data
- Process for internal studies
 - PJM contingency format
 - TARA Contingency Wizard
 - Project Contingency Files
 - Contingency file creation script
- Process for external contingency submission
 - Contingency database spreadsheet
 - Future improvements
 - Node Breaker
- Pain-points/quirks/discussion



Background

What Are Contingencies?

- Contingency Analysis simulates the power system's state/response after failures of individual components of the system → The system must not exceed its limits or initiate cascading failures, even under unexpected stress
- NERC Standard TPL-001-5 lays out categories of contingency events that must be simulated by planners.
 - Numbered P0-P7
- Recorded in a text file (.con) to instruct software (PSS/E, TARA, etc.) what actions to take.




```
CONTINGENCY "DLC_P12_LINE-A"  
  OPEN BRANCH FROM BUS 123 TO BUS 456 CKT 1  
END
```

- Because we have to study the loss of *any* BES circuit, generator, transformer, etc., there are *many* individual events to record in the contingency file.

TPL-001 Category Summary*

Category	Sub-Category	Description
P1	P11	Loss of a generator
	P12	Loss of a transmission circuit
	P13	Loss of a transformer
	P14	Loss of a shunt device
P2	P21	Opening of a line section without a fault
	P22	Bus section fault
	P23	Breaker fault (non-bus-tie breaker)
	P24	Breaker fault (bus-tie breaker)
P3		P11 followed by P11, P12, P13, or P14
P4		Fault plus stuck breaker (Only distinct from P23/P24 for dynamic analysis)
P5		Fault plus failure of non-redundant protection system
P6		P12, P13, or P14 followed by P12, P13, or P14
P7		Loss of two circuits that share a common structure for at least 1 mile

*Categories relating to HVDC lines omitted for brevity, as DLC has no HVDC facilities




Internal Study Process

PJM Contingency Format

- Breakdown into 6 different files based on NERC category:

PJM File Name	TPL-001-5 Contingencies
Single	P1 (All)
P_2-1	P2.1
Bus	P2.2
Line_FB	P2.3, P2.4 P4 (All)
P5	P5
Tower	P7(All)



- P3 and P6 contingencies are made by combinations of P1 contingencies
- For steady-state applications, P23 and P24 cover all P4 contingencies
- Contingency name format:

[COMPANY]_[NERC-CATEGORY]_[EVENT-NAME]_SRT-[SUFFIX]

DLC_P12_Z-123_SRT-A

DLC_P24_DNTOWN-1-2_SRT-A

TARA Contingency Wizard Filter

TARA Monitor/Contingency Wizard

Monitor/Contingency File Creator Nearby Buses Subsystem File Creator

Select Filter Options

Subsystem/Area/Zone/Bus Layer kV/Generator Outage/kV Cutoff

Layer kV Selection (number of buses away from subsystem/area/zone/bus selection above)

Define voltage ranges and layers (number of buses away) per each voltage range. Layers should be numbers between 0 and 20.

8 layers < 60 kV <= 0 layers < 138 kV <= 3 layers < 345 kV <= 5 layers < 500 kV <= 7 layers

Contingency Event kV Cutoff

Enter kV Cutoff: 100

☒ Check for less than or equal OR ☐ ALL

☐ Check for both sides

Generator Outage Selection

Enter Generator Outage Pmax Cutoff: 100

☒ MW and above OR ☒ ALL

☐ Check for on-line generators only

☐ Check for plant level (only for generator contingency creation)

☒ Save New Con/Mon File (use as TARA input file) Please define the correct path here

Select Action

- Report Filtered Contingencies
- Create Single Branch Contingencies
- Create Generator Outage Contingencies
- Create Single Branch Monitor File
- Create Open End Branch (P21) Contingencies
- Create Shunt Outage (P14) Contingencies

Run ?

Cancel


- Running contingency analysis across a wide area is very time consuming. N-1-1 grows like N^2
- TARA Contingency Wizard filter excludes contingencies more than a certain # of buses away, variable cutoffs per kV level.
- We're a small territory with no ties <138kV, but nearby connections to the regional backbone 500kV & 765kV systems
- Large generators (100s of MW) are modeled on GSU low side buses. Should not be excluded.
- No perfect way to include all those without including at least *some* unimportant contingencies
 - err on the side of bloating the contingency list rather than excluding possibly significant external events
- Achieves a reduction of ~10x in number of conts, while including all EHV within ~100miles of us
- Makes reviewing .con files for errors easier

DLC P1's: ~100
PJM P1's: ~13,000
Filtered P1's: ~1,000


Contingency Preparation Scripts

Create individual files for projects, combine with starting contingency file, check for common contingency errors

- Draft .con files for each new project or solution
 - One for each PJM file type, per project
 - Include contingencies Added, Modified, or Removed by a project
 - Script recognizes [REMOVED] keyword in contingency name
- Compile ordered list of .con files
 - Start with “base” RTEP con file (typically filtered using TARA Cont Wizard)
 - Add project/solution con files in order
- Run contingency combiner script
 - Creates internal store (python dict) of contingencies (@dataclass objects)
 - Adds, modifies, or removes stored contingencies as specified by subsequent files
 - Outputs combined file reflecting internal state after all files are read
 - Also logs internal state and all changes made to internal state in JSON format
- Check for errors
 - TARA automatically runs a check on initial file ingest
 - PSS/E will skip any contingencies with unrecognized/erroneous instructions when running activity DFAX
 - Run DFAX at input file preparation time, parse PSSE progress output for “contingency [...] skipped”, and tabulate results for review.



```
"[REDACTED] Bus.con": {
  "added": [],
  "modified": [
    "DLC_P22 [REDACTED]",
    "DLC_P22 [REDACTED]"
  ],
  "removed": []
},
"[REDACTED] Line_FB.con": {
  "added": [
    "DLC_P23 [REDACTED]"
  ],
  "modified": [
    "DLC_P23 [REDACTED]",
    "DLC_P23 [REDACTED]",
    "DLC_P23 [REDACTED]",
    "DLC_P23 [REDACTED]",
    "DLC_P24 [REDACTED]",
    "DLC_P24 [REDACTED]",
    "DLC_P24 [REDACTED]"
  ],
  "removed": [
    "DLC_P23 [REDACTED]"
  ]
},
```



External Submission

Contingency Database

Current Method: Excel Spreadsheet

- Store lines of contingency file in excel spreadsheet rows, with columns to enable filtering by:
 - NERC category and sub-category
 - “In-service” and “retirement” dates
 - Make revisions of contingency with changes for various project states.

CONTINGENCY Description (Common)	Contingency Definition
DOWNTOWN-PENN HILLS Z-123	CONTINGENCY DLC_P12_Z-123
	OPEN BRANCH FROM BUS 123456 TO BUS 456789 CKT 1
	END

Comments	CONTINGENCY File to Export With Comments
/*DOWNTOWN-PENN HILLS Z-123	CONTINGENCY DLC_P12_Z-123 /*DOWNTOWN-PENN HILLS Z-123
/* 15DNTWN 138.0 - 15PNHILL 138.0 1	OPEN BRANCH FROM BUS 123456 TO BUS 456789 CKT 1 /* 15DNTWN 138.0 - 15PNHILL 138.0 1
	END

CONTINGENCY File to Export With Comments	Project ID	Out of Service Project ID	Start Date	End Date
CONTINGENCY DLC_P12_Z-123 /*DOWNTOWN-PENN HILLS Z-123		Lawrenceville	1/1/2023	12/31/2027
OPEN BRANCH FROM BUS 123456 TO BUS 456789 CKT 1 /* 15DNTWN 138.0 - 15PNHILL 138.0 1		Lawrenceville	1/1/2023	12/31/2027
END		Lawrenceville	1/1/2023	12/31/2027
CONTINGENCY DLC_P12_Z-123 /*DOWNTOWN-LAWRENCEVILLE Z-123	Lawrenceville		1/1/2028	
OPEN BRANCH FROM BUS 123456 TO BUS 789456 CKT 1 /* 15DNTWN 138.0 - 15LAWRNC 138.0 1	Lawrenceville		1/1/2028	
END	Lawrenceville		1/1/2028	
CONTINGENCY DLC_P12_Z-124 /*PENN HILLS-LAWRENCEVILLE Z-124	Lawrenceville		1/1/2028	
OPEN BRANCH FROM BUS 456789 TO BUS 789456 CKT 1 /* 15PNHILL 138.0 - 15LAWRNC 138.0 1	Lawrenceville		1/1/2028	
END	Lawrenceville		1/1/2028	

- Example: project looping in a line to a new substation. One contingency must be modified and another added. Old version is ended and new version starts on project ISD. Filter for required date.

Contingency Spreadsheet



Drawbacks and Future Improvements

- Creating new contingencies associated with projects is still a highly manual process.
 - Step through all lines, transformers, shunts, bus sections, breakers, and tower lines involved.
 - Check topology diagram for outaged branches/equipment for each fault
 - Use correct Bus and equipment IDs in written contingency definition
- Checks like bus-name lookup and error checking scripts speed up and clean up this work significantly
- Small number of projects reaching level of maturity to be submitted to PJM makes this a lighter burden and allows time for thorough review
- Standardize syntax, avoiding variations of same instructions, avoid “**open bus**” instructions.
- Implement facility name lookup to further simplify validation of manual input
- Use formats suited to python/scripted processing (JSON, SQL?)
- General direction we want to move in:
 - specify underlying data (bus numbers, substation names, lines, breakers, etc.),
 - then automatically generate contingency text syntax from that underlying data, using lookup/reference to load flow case data, rather than storing manually-written instruction lines
- End state of this...

Node Breaker

Full breaker topology of substations instead of single bus per voltage level, or “dummy” buses

- Bus Branch vs. Node Breaker



- Evaluate contingency topologies that split transmission buses
- Evaluate long-term outages that leave certain breakers open as a starting condition
- Enable automatic contingency specification using topology data → Ideally, development of new customer/sensitivity scenarios would only require development of new/proposed topology
- See EPRI “ARTS” Tool (NATF-NERC-EPRI Planning & Modeling Webinar 2024 Day 1)


Node Breaker – Automatic Contingency Specification (PSS/E)

- SINGLE ISOLATE BRANCH IN AREA [i]
 - P12, P13
- SINGLE ISOLATE BREAKER IN AREA [i]
 - P23, P24
- SINGLE OPEN TERMINAL IN AREA [i]
 - P11, P14, P21
- Python for loop over “Bus Section” node IDs: ISOLATE SUBSTATION [staid] NODE [nodid]
 - P22
- Need additional data for:
 - P7: List of lines sharing structure for >1 mile
 - P5: Detailed data of non-redundant protection elements and results of failure
 - (Should never have to add to this data once compiled, only delete)
- In general, probably more flexible to develop scripting to process topology data into individual contingency events rather than use PSS/E Automatic Specification
 - ISOLATE BRANCH [...], ISOLATE MACHINE [...], ISOLATE BREAKER [...], ISOLATE [...] NODE [...]

Edge Cases/Quirks

- PJM seasonal SRT-__ suffixes: Use project ISD filter to select contingencies which change over the future seasons in question
- TARA-only or MUST/ALA-only contingency instructions
 - SET PRECONTRATING / SET POSTCONTRATING for post-contingency ratings change.
 - We have a different approach:
Separate “S1” branches with identical impedance, but single-breaker ratings (DBDB)

OPEN BRANCH FROM BUS █81 TO BUS █02 CKT 1
CLOSE BRANCH FROM BUS █81 TO BUS █02 CKT S1
OPEN BRANCH FROM BUS █02 TO BUS █36 CKT 1
CLOSE BRANCH FROM BUS █02 TO BUS █36 CKT S1
OPEN BRANCH FROM BUS █92 TO BUS █02 CKT 1
CLOSE BRANCH FROM BUS █92 TO BUS █02 CKT S1
OPEN BRANCH FROM BUS █02 TO BUS █31 CKT 1
CLOSE BRANCH FROM BUS █02 TO BUS █31 CKT S1



- OPENFROM / OPENTO for P21 contingencies
- These and other incompatible instructions cause PSS/E to skip → Our ingest of external contingencies from RTEP files now recognizes and comments out these instructions when preparing files for PSS/E

Questions & Discussion


- Any questions?
- Any experiences/challenges handling automation/validation of contingency creation?
- Any experiences/challenges in building node breaker models or system topology data for contingency specification?



Contingency Creation Process

Will Sayers – SPP Planning Coordinator Assessments
August 2026

Overall Process



Auto Generated P1 Events

Auto Generated P1 Events

Standalone Python Script

Creates every possible P1 Event

Bus-Branch Model

Member & First Tier Contingencies

Member & First Tier Contingencies

SPP members & first tier entities submit contingencies each year

- P1, P2, P4, P5, P7, and Extreme Events

Each contingency is uploaded to a SQL database

Internal automation validates each contingency

- For any assessment model, the contingency definitions are deemed valid or invalid

Reports are created for invalid contingencies to be reviewed for accuracy

Member & First Tier Contingencies

TPL SS

Study Name:

2026_TPL_BR

Create Study

Models Location:

Browse...

Study Type:

TPL_STEADY_STATE

Study Description:

PSSE Version

35

Refresh

Con Verify

Con Builder

POM Importer and PSSE Verify

CAP Verify

Verify Contingencies Valid as of Date:

07/17/2026

Verify Contingencies Against Model

☐ 2026ITPPF-27L

☐ 2026ITPPF-27S

☐ 2026ITPPF-30S

☐ 2026ITPPF-35S

Verify

Save con verify reports here:

REQUIRED: Drag desired output directory here

Browse...

Generate Con Verify Reports

Member & First Tier Contingencies

Con Verify **Con Builder** POM Importer and PSSE Verify CAP Verify

Build Custom Contingency File(s)

Build Contingencies Valid as of Date: 07/17/2026

Models

- ☐ 2026ITPPF-27L: Con verify date 2026-01-22
- ☐ 2026ITPPF-27S: Con verify date 2026-01-22
- ☐ 2026ITPPF-30S: Con verify date 2026-01-22
- ☐ 2026ITPPF-35S: Con verify date 2026-01-22

Select All

Areas

Select Needed

P Event Type

- ☐ P1 ☐ P1.1 ☐ P1.2 ☐ P1.3 ☐ P1.4 ☐ P1.5
- ☐ P2 ☐ P2.1 ☐ P2.2 ☐ P2.3 ☐ P2.4
- ☐ P4 ☐ P4.1 ☐ P4.2 ☐ P4.3 ☐ P4.4 ☐ P4.5 ☐ P4.6
- ☐ P5 ☐ P5.1 ☐ P5.2 ☐ P5.3 ☐ P5.4 ☐ P5.5
- ☐ P7 ☐ P7.1 ☐ P7.2
- ☐ EE

kV Level

Selection Required

- ☐ HV
- ☐ EHV

Special Con Type

Selection Optional

- ☐ RBP - Risk Based Planning
- ☐ LLT - Long Lead Time

Complex P Event Type

- ☐ P3
- ☐ P6

OPTIONAL: Additional sub file to be included in P3 creation:


Sub File:

Save Contingency file(s) here: *REQUIRED: Drag desired output directory here*

Build Contingency File(s)

P3 and P6 Contingency Creation

P3 Contingency Creation



P6 Contingency Creation

Member Submitted P1 Combinations

Each member submitted P1 event is paired with another P1 event within the same model zone

Auto Generated P6s

Using V&R Energy's POM software, P6s are created using model data for elements within the same model zone

Questions?





Contact

SPP Planning Coordinator

Please feel free to contact us at
planningcoordinator@spp.org !

N-1 CONTINGENCY ANALYSIS

John Idzior, ReliabilityFirst

August 6, 2026



PURPOSE

We have a starting case with a topology, load, dispatch, and transaction schedule built in

We want to test various contingency scenarios, e.g.

- Line or transformer fault
- Bus fault
- Line fault plus stuck breaker
- Define these in CON file

After applying the contingency, which branches and buses are affected?

- Standard practice is to limit the set of branches and buses in the case that are monitored. Don't monitor all branches in the entire case.
- Define which branches and buses to monitor for contingency impacts in the MON file

INPUT FILES

- Loadflow Case
- Subsystem File
- Monitor File
- Contingency File(s)
- Exclude File (Optional)
- RAS/CS File (Optional)
- INCH file (Optional)

Input

Select TARA Application

☐ LF Case Viewer + Editor ☒ ContAnalysis + TARA Screen ☐ TARA Fgates Analysis

Load Flow Case (first case if list of additional cases is used)

Please define the correct path here

☐ Use as default path

LF case format

PTI RAW 35

Multiple Cases (use '*.raw', '*.epc', or '*.aux' in file name if all cases are in one folder)

☐ Add Cases 0 files

List of Additional Cases

☐ Apply INCH Files

List INCH Files

Load Input Files

Study Data File

Please define the correct path here

Monitor File

Please define the correct path here

☐ Do not read Contingency File ☒ Do not read Exclude File

RAS/Corrective Switching Mode RAS/CS is OFF

Contingency File

Please define the correct path here

Exclude File

Please define the correct path here

Select Contingency Analysis Mode (Reload Input Files if selection changed)

☒ Standard N-1 ☐ N-1-1 (or N-1 + Application)

Please define the correct path here

Print Options **Export Options File** **Import Options File** **Recent Options Files** **Add Project to History** **Change Initial Loading Options**

Exit TARA **Save Viewer with Options and Reports** **Close Main Menu (Save Options)** **Clear All Reports** **Cancel**

N-1 ANALYSIS

AC Flow

- Apply a contingency and do AC solve
- Reports on thermal branch impacts, bus voltage impacts
- Iterative AC solution so non-convergence is a possibility

DC Flow

- AC solved upon initial loading, NOT doing a DC loadflow solve post contingency
- Compute contingency event distribution factors
- Estimate post-cont flow based on pre-contingency event MW multiplied by contingency event factor
- Will not match the exact AC flow, much faster than AC solving each contingency
- Thermal branch impacts only. Does NOT report bus voltage impacts or non-convergence

N-1 DC WITH AC VERIFICATION

Identify contingencies that cause monitored branch loadings above value - such as 80-85%

- For these contingencies, do full post-contingency AC solve
 - Faster than full AC since number of AC solves is reduced
- Assuming that DC results are reasonably close to AC results, we should get a report very similar to the AC report
 - May not work well (or, at all) in instances of heavily overloaded systems, or other special circumstances

N-1 ANALYSIS

Input

Utils

CA

SCD

TrLim

FGScr

FGApp

CustApp

DC Contingency Analysis

AC Contingency Analysis

Mon Cont Reports

Flowgate Analysis

Run DC Cont Analysis.
See DCCONT report.

DC Cont with AC Verification

Run DC Cont with AC Verification
Analysis. See DCACVer report.

☒ Create DC AC Verification Voltage reports.
See VoltViol, PostContShuntAdj and all ACCont reports.

0

Voltage Magnitude Limit Adder (pu)

AC Post-Cont LF Options

Selected Ratings:
Base Case:Rate 1(A)
Post-Cont:Rate 2(B)

If you want to change Ratings, Cutoffs for contingency flow, change Initial Loading
options and reload input files

☐ Run only contingencies inside and near a selected subsystem of
buses. Applies to both first-level and second-level
contingencies

Select
Subsystem

Loading Cutoff

90 %

Report Manager

Dfax Reporting

N-1-1 Options

☐ Create N-1-1 Isolated Gen/Load
Buses report (N-1-1 Only)

DC Contingency Analysis

AC Contingency Analysis

Mon Cont Reports

Flowgate Analysis

Run AC Cont Analysis and
Create Selected Reports

Report Manager

Parallel Processing

N-1-1 Options

Dfax Reporting

☐ Enable Cascading Analysis

Options

AC LF Options

AC Post-Cont LF Options

If you want to change Ratings,
Cutoffs for contingency flow,
change Initial Loading options
and reload input files

Selected Ratings:
Base Case:Rate 1(A)
Post-Cont:Rate 2(B)

☐ Run only contingencies inside and near
a selected subsystem of buses. Applies
to both first-level and second-level
contingencies

Select
Subsystem

AC Cont Analysis Reports

Monitored branches AC violations

Monitored voltages violations

ACCONT Summary for all contingencies

ACCONT Summary - not converged contingencies

ACCONT Summary - violations only

ACCONT Summary - Bus Mismatch

Switched Shunt Adjustments Post-Contingency

N-1-1 Isolated Gen/Load Buses (N-1-1 Only)

Worst case branch loading (obsolete)

Worst case voltages violations (obsolete)

Loading Cutoff for branch violations

90 %

If you want to change Ratings,
Cutoffs for contingency flow,
change Initial Loading options
and reload input files

0

Voltage Magnitude Limit Adder (pu)

Create Reports without ACCont Rerun
(works only if N-1-1 Parallel Processing is OFF)

☐ Do NOT open BranchViol and VoltViol reports

Select All

Unselect All

N-1 ANALYSIS OPTIONS

Ratings

- Select pre and post contingent rating set
- TARA does not monitor post-contingency flow if Rating is zero
- % loading cutoff for reporting

Report Manager

- Branch Overloads/Voltage Reports
- Options to display data in results report

Other

- Initial loading solution parameters
- Parallel Processing
- AC Post Contingency solution options
- Multiple CONs impact monitored branch

RESULTS

1	POWER-GEM N-1 DC Monitored Facility Loadings[TARA Ver 2101.2.0.0 64-bit - Mon Oct 25 16:03:03 2021]																		
2																			
3	Loadflow Case: C:\files\TARA_v1902test\TrainingJuly2019\training.raw																		
4	Study Data File: C:\files\TARA_v1902test\TrainingJuly2019\training.sub																		
5	Contingency File: C:\files\TARA_v1902test\TrainingJuly2019\training.con (total 2415 contingencies)																		
6	Monitor File: C:\files\TARA_v1902test\TrainingJuly2019\training.mon (90.0% loading cutoff)																		
7	Exclude File: not provided																		
8	Pre/Post Contingency PAR Adjustment: Adjusted/Fixed																		
9																			
10	Monitored Facility		monType	Fr Bus	Fr Name	To Bus	To Name	CKT	kVs	Areas	Rate Base (MVA)	Rate Cont (MVA)	Cont Name						
11	45069	WHITE SULP~1	138	45058	MARLINTON 2	138	1	BES	45069	WHITE SULP~1	45058	MARLINTON 2	1	138	45	169	202.8	16262	WARM SPRIN~1
12	16272	WARM SPRIN~3	138	45058	MARLINTON 2	138	1	BES	16272	WARM SPRIN~3	45058	MARLINTON 2	1	138	15/45	176.5	211.8	16262	WARM SPRIN~1
13	16263	WARM SPRIN~4	138	16272	WARM SPRIN~3	138	1	BES	16263	WARM SPRIN~4	16272	WARM SPRIN~3	1	138	15	250	300	16262	WARM SPRIN~1
14	16297	FRONT ROYA~8	138	15069	FRONT ROYA~6	138	1	BES	16297	FRONT ROYA~8	15069	FRONT ROYA~6	1	138	15	175.8	211	16288	FRONT ROYA~7
15	45445	WEBSTER SP~2	69.0	45423	COWEN 4	69.0	1	NBES	45445	WEBSTER SP~2	45423	COWEN 4	1	69	45	62.5	75	16262	WARM SPRIN~1
16	15358	RICHMOND 7 3	138	16251	ASHLAND 7 2	138	1	BES	15358	RICHMOND 7 3	16251	ASHLAND 7 2	1	138	15	198.4	238.1	16250	ASHLAND 7 1
17	15069	FRONT ROYA~6	138	15066	FRONT ROYA~3	138	1	BES	15069	FRONT ROYA~6	15066	FRONT ROYA~3	1	138	15	195.8	235	16288	FRONT ROYA~7
18	45600	FRANKLIN ~22	69.0	45599	FRANKLIN ~21	138	1	BES	45600	FRANKLIN ~22	45599	FRANKLIN ~21	1	69/138	45	91.5	109.8	16262	WARM SPRIN~1
19	19237	HARTSVILL~24	138	19253	HARTSVILL~23	138	1	BES	19237	HARTSVILL~24	19253	HARTSVILL~23	1	138	19	250	300	19236	HARTSVILL~14
20	45424	CAMDEN ON ~1	69.0	45423	COWEN 4	69.0	1	NBES	45424	CAMDEN ON ~1	45423	COWEN 4	1	69	45	43.7	52.4	16262	WARM SPRIN~1
21	45445	WEBSTER SP~2	69.0	45444	WEBSTER SP~1	138	1	BES	45445	WEBSTER SP~2	45444	WEBSTER SP~1	1	69/138	45	77	92.4	16262	WARM SPRIN~1
22	45437	RICHWOOD 1	69.0	45424	CAMDEN ON ~1	69.0	1	NBES	45437	RICHWOOD 1	45424	CAMDEN ON ~1	1	69	45	43.8	52.6	16262	WARM SPRIN~1
23	45428	ROCK CAVE 2	69.0	45442	MILL CREEK~2	69.0	1	NBES	45428	ROCK CAVE 2	45442	MILL CREEK~2	1	69	45	67	80.4	16262	WARM SPRIN~1
24	45428	ROCK CAVE 2	69.0	45441	HUTTONSVIL~1	69.0	1	NBES	45428	ROCK CAVE 2	45441	HUTTONSVIL~1	1	69	45	72.2	86.6	16262	WARM SPRIN~1
25	45441	HUTTONSVIL~1	69.0	45048	ARBOVALE 1	69.0	1	NBES	45441	HUTTONSVIL~1	45048	ARBOVALE 1	1	69	45	75.7	90.8	16262	WARM SPRIN~1
26	16289	FRONT ROY~11	138	16297	FRONT ROYA~8	138	1	BES	16289	FRONT ROY~11	16297	FRONT ROYA~8	1	138	15	250	300	16288	FRONT ROYA~7
27	45069	WHITE SULP~1	138	15875	COVINGTON ~6	138	1	BES	45069	WHITE SULP~1	15875	COVINGTON ~6	1	138	45/15	173.6	208.3	16262	WARM SPRIN~1
28	16019	BREMO BLUF~6	138	16138	SCOTTSVILL~7	138	1	BES	16019	BREMO BLUF~6	16138	SCOTTSVILL~7	1	138	15	239.6	287.5	16227	NEW CANTON~3
29	16263	WARM SPRIN~4	138	16262	WARM SPRIN~1	500	1	BES	16263	WARM SPRIN~4	16262	WARM SPRIN~1	1	138/500	15	814.8	977.8	16262	WARM SPRIN~1
30	45382	RUPERT 1 1	69.0	45437	RICHWOOD 1	69.0	1	NBES	45382	RUPERT 1 1	45437	RICHWOOD 1	1	69	45	53.2	63.8	16262	WARM SPRIN~1

DCCONT

ConList

BranchFlows

VoltMonit

Warn_Sum

Warn_List

CaseSum

LogFile

ORA_OutList

ORA_OutSched

ORA_OutErrors

ORA ...

+

:

◀

▶

RESULTS

	F	G	H	I	J	K	L	M	N	O	P	Q	R
1	0211												
2													
3													
4													
5	es)												
6													
7													
8													
9													
10	To Name	CKT	kVs	Areas	Rate Base (MVA)	Rate Cont (MVA)	Cont Name	ContType	Cont ID	Base Flow (MW)	Cont Flow (MW)	Final DC %Loading	Severity Rank
11	MARLINTON 2	1	138	45	169	202.8	16262 WARM SPRIN~1 500	16271 WARM SPRIN~2 500 1	Single	555	-26.4	-931.7	459.4 1
12	MARLINTON 2	1	138	15/45	176.5	211.8	16262 WARM SPRIN~1 500	16271 WARM SPRIN~2 500 1	Single	555	37.1	942.4	444.94 1
13	WARM SPRIN~3	1	138	15	250	300	16262 WARM SPRIN~1 500	16271 WARM SPRIN~2 500 1	Single	555	75.4	1255.8	418.6 1
14	FRONT ROYA~6	1	138	15	175.8	211	16288 FRONT ROYA~7 500	16299 FRONT ROY~10 500 1	Single	561	33.4	853.3	404.48 1
15	COWEN 4	1	69	45	62.5	75	16262 WARM SPRIN~1 500	16271 WARM SPRIN~2 500 1	Single	555	26.5	301.6	402.14 1
16	ASHLAND 7 2	1	138	15	198.4	238.1	16250 ASHLAND 7 1 500	16259 ASHLAND 7 10 500 1	Single	550	-62	-937.7	393.87 1
17	FRONT ROYA~3	1	138	15	195.8	235	16288 FRONT ROYA~7 500	16299 FRONT ROY~10 500 1	Single	561	-7.5	812.4	345.76 1
18	FRANKLIN ~21	1	69/138	45	91.5	109.8	16262 WARM SPRIN~1 500	16271 WARM SPRIN~2 500 1	Single	555	30	369	336.07 1
19	HARTSVILL~23	1	138	19	250	300	19236 HARTSVILL~14 345	19255 HARTSVILL~26 345 1	Single	751	164.2	991.1	330.38 1
20	COWEN 4	1	69	45	43.7	52.4	16262 WARM SPRIN~1 500	16271 WARM SPRIN~2 500 1	Single	555	-6.1	-172.2	328.31 1
21	WEBSTER SP~1	1	69/138	45	77	92.4	16262 WARM SPRIN~1 500	16271 WARM SPRIN~2 500 1	Single	555	-26.5	-301.6	326.42 1
22	CAMDEN ON ~1	1	69	45	43.8	52.6	16262 WARM SPRIN~1 500	16271 WARM SPRIN~2 500 1	Single	555	-3.6	-169.6	322.74 1
23	MILL CREEK~2	1	69	45	67	80.4	16262 WARM SPRIN~1 500	16271 WARM SPRIN~2 500 1	Single	555	21.3	242.2	301.24 1
24	HUTTONSVIL~1	1	69	45	72.2	86.6	16262 WARM SPRIN~1 500	16271 WARM SPRIN~2 500 1	Single	555	-29	-249.9	288.43 1
25	ARBOVALE 1	1	69	45	75.7	90.8	16262 WARM SPRIN~1 500	16271 WARM SPRIN~2 500 1	Single	555	-38.3	-259.2	285.32 1
26	FRONT ROYA~8	1	138	15	250	300	16288 FRONT ROYA~7 500	16299 FRONT ROY~10 500 1	Single	561	33.4	853.3	284.43 1
27	COVINGTON ~6	1	138	45/15	173.6	208.3	16262 WARM SPRIN~1 500	16271 WARM SPRIN~2 500 1	Single	555	2.1	543.1	260.69 1
28	SCOTTSVILL~7	1	138	15	239.6	287.5	16227 NEW CANTON~3 500	16232 NEW CANTON~8 500 1	Single	541	128.3	705.5	245.38 1
29	WARM SPRIN~1	1	138/500	15	814.8	977.8	16262 WARM SPRIN~1 500	16271 WARM SPRIN~2 500 1	Single	555	-270	-2381.3	243.55 1
30	RICHWOOD 1	1	69	45	53.2	63.8	16262 WARM SPRIN~1 500	16271 WARM SPRIN~2 500 1	Single	555	1.7	-148.1	232.06 1

Live Demo



QUESTIONS & ANSWERS

John Idzior

john.idzior@rfirst.org




Power-Voltage Analysis: Contingency Selection

John Wiggins
Reliability Engineer

Agenda

- **PV Analysis**
 - Overview of voltage stability margins and why PV curves matter in transmission studies.
- **Why a Reduced Contingency List Is Essential**
 - Focusing computational effort on contingencies that meaningfully stress system voltage.
- **Contingency Selection Criteria**
 - Technical indicators of stressed conditions in both N-0 and N-1 cases.
- **Workflow & Automation**
 - A repeatable, traceable process for screening, combining .con files, and preparing PV-ready cases.

WHAT IS PV ANALYSIS?



- Voltage drops as MW transfer rises until it reaches the **nose point**, where the system can no longer support the load.
- The area **before** is the stable region.
- Every contingency shifts the curve - move the nose point and **decreasing** the stability margin

WHY A SMALLER CONTINGENCY LIST MATTERS

Steady State Contingency Analysis is Fast

- One Power Flow solution per contingency. Thousands of cases can run in **minutes**.

PV Analysis is Computational Heavy

- Each contingency requires **dozens of sequential power flow solutions** across a full transfer range. A complete N-1 list can take **hours or days**.

The Fix – Focus On Stressed Conditions

- Select contingencies by **voltage stress impact**, producing most critical contingency cases for PV.

Methodology & Automation Matters

- Smart screening makes PV analysis **practical at scale**, without sacrificing reliability or missing critical contingencies.

Contingency Selection

Stressed Voltage Conditions

Known Voltage Stability Conditions

- ☐ Known Voltage Stability Limits
- ☐ Defined Interconnection Reliability Operating Limits


Stressed Base Case Conditions

- ☐ Branches in proximity to low voltage buses
- ☐ Elements in proximity to poor numerical solutions
- ☐ Loss of reactive support
- ☐ Loss of Generation
- ☐ Branches with large angle separation

Stressed Contingency Conditions

- ☐ Non-converged contingency cases
- ☐ Contingencies resulting in low voltage across several buses
- ☐ Contingencies with a large voltage drop
- ☐ Contingencies resulting in branch overloads


Contingency Selection Workflow



Contingency Selection Workflow

Known Voltage Stability Limits



For N-1 studies on known IROL or voltage stability-limited paths, use the individual elements of the IROL or stability condition, organized by study region.



A well-maintained running list reduces build time at each study to a verification step, not a rebuild.


Contingency Selection Workflow

N-0 Screening




The screenshot displays a table with columns: Scenario, Sending Subsystem(s), and Receiving Subsystem(s). The table lists various scenarios and their associated subsystems.

Scenario	Sending Subsystem(s)	Receiving Subsystem(s)
2035SUM_ET107_Into-SERC-Central	All_Export_to_SERC_C	SERC_C_Import
2035SUM_ET110_Into-SERC-East	All_Export_to_SERC_E	SERC_E_Import
2035SUM_ET109_Into-SERC-Florida	All_Export_to_SERC_FL	SERC_FL_Import
2035SUM_ET108_Into-SERC-Southeast	All_Export_to_SERC_SE	SERC_SE_Import
2035SUM_E3_MISO-Central-SERC-Central	MISO_C_EX	SERC_C_Import
2035SUM_E41_MISO-SERC-Central	MISO_EX	SERC_C_Import
2035SUM_E41_MISO-SERC-Southeast	MISO_EX	SERC_SE_Import
2035SUM_E9_MISO-South-SERC-Central	MISO_S_EX	SERC_C_Import
2035SUM_E10_MISO-South-SERC-South	MISO_S_EX	SERC_SE_Import
2035SUM_E15_MISO-West-SERC-Central	MISO_W_EX	SERC_C_Import
2035SUM_E46_PJM-SERC-Central	PJM_EX	SERC_C_Import
2035SUM_E47_PJM-SERC-East	PJM_EX	SERC_E_Import
2035SUM_E29_PJM-South-SERC-East	PJM_S_EX	SERC_E_Import
2035SUM_E29_PJM-South-SERC-East	PJM_S_EX	SERC_SE_Import
2035SUM_E30_PJM-West-SERC-Central	PJM_W_EX	SERC_C_Import
2035SUM_E31_PJM-West-SERC-East	PJM_W_EX	SERC_E_Import
2035SUM_E32_SERC-Central-SERC-East	SERC_C_Export	SERC_C_Import
2035SUM_E32_SERC-Central-SERC-Southeast	SERC_C_Export	SERC_SE_Import
2035SUM_E32_SERC-East-SERC-Central	SERC_E_Export	SERC_C_Import
2035SUM_E36_SERC-East-SERC-Southeast	SERC_E_Export	SERC_SE_Import
2035SUM_E37_SERC-Florida-SERC-Southeast	SERC_FL_Export	SERC_FL_Import
2035SUM_E31_SERC-Southeast-SERC-Central	SERC_SE_Export	SERC_C_Import
2035SUM_E36_SERC-Southeast-SERC-East	SERC_SE_Export	SERC_E_Import
2035SUM_E37_SERC-Southeast-SERC-Florida-Peninsula	SERC_SE_Export	SERC_FL_Import
2035SUM_E34_SPP-North-SERC-Central	SPP_N_EX	SERC_C_Import
2035SUM_E35_SPP-South-SERC-Central	SPP_S_EX	SERC_C_Import
2035SUM_SPP_EX_SERC-Import	SPP_EX	SERC_C_Import





Contingency Selection Workflow

Contingency Screening




Contingency Selection Workflow

Combine .Con Files



Summary

- PV analysis is a core component of a complete transmission reliability assessment.
- Technically justified screening criteria allow planners to focus PV studies on the contingencies that truly stress system voltage, reducing study durations.
- Repeatable workflows and automation improve efficiency, consistency, and defensibility across studies.





FIRST CONTINGENCY INCREMENTAL TRANSFER CAPABILITY (FCITC)

John Idzior, ReliabilityFirst

August 6, 2026



PURPOSE

Primary objective of the transfer limit analysis is to identify transfer limits between power system areas

Use of transfer limit analysis

- Bottled generation or deliverability
- Must-run generation (load pocket)
- Evaluate Interfaces

TRANSFER PROCEDURE

- Scale up sending & Scale down receiving
- As transfer increases, keep track of MON/CON pairs that hit limit along the way
 - Only monitor pairs that have transfer Dfax above user-defined cutoff (pre-and/or post-cont)
- Will test up to user-defined max transfer amount
- Transfer continues even after generation runs out
 - For sanity check, check Subsystem Summary report for MW available
- For each mon/con pair that hits the limit, record amount of transfer required
- Select output using Report Manager

INPUT FILES

- Loadflow Case
- Subsystem File
- Monitor File
- Contingency File
- Exclude File (Optional)
- RAS/CS File (Optional)
- INCH file (Optional)

Input

Select TARA Application

☐ LF Case Viewer + Editor ☒ ContAnalysis + TARA Screen ☐ TARA Fgates Analysis

Load Flow Case (first case if list of additional cases is used)

Please define the correct path here

☐ Use as default path

LF case format

PTI RAW 35

☐ Multiple Cases (use '*.raw', '*.epc', or '*.aux' in file name if all cases are in one folder)

☐ Add Cases 0 files

☐ Apply INCH Files

Study Data File

Please define the correct path here

Monitor File

Please define the correct path here

☐ Do not read Contingency File ☒ Do not read Exclude File

RAS/CS is OFF

Contingency File

Please define the correct path here

Exclude File

Please define the correct path here

Select Contingency Analysis Mode (Reload Input Files if selection changed)

☒ Standard N-1 ☐ N-1-1 (or N-1 + Application)

Please define the correct path here

FCITC RESULTS

Significant factors that affect results

- Transfers built into the starting case
- Load levels and load profile
- Initial generation dispatch
- Participation factors defined by user

FCITC ANALYSIS

Input

Utils

CA

SCD

TrLim

AMB

FGScr

FGApp

CustApp

Opt MW Transfer

Proportional Scale Transfer

PV Analysis

QV Analysis

PathScreen

AreaTieImpacts

?

Run Single Transfer Limit Analysis

3000

Maximum transfer test level

5

Max times to report same branch under different contingencies

Distribution factors cutoff

☒ Same cutoff for pre-cont and post-cont

0.03

☐ Separate cutoffs for pre-cont and post-cont

0.03

Pre-Cont

0.2

Post-Cont

☐ Report Initial Overloads (negative transfer limit or negative Dfax)

☐ Ignore Initial Overloads which have negative Dfax such that increasing transfer will fix the overload

☐ Run TrLim for each system bus or tap of each system line (Multiple TrLim). Single case mode only

Additional Options

Sending System

Sending_APS

Find

Details

Receiving System

Import_Gen

Find

Exit TARA

Save Viewer with Options and Reports

Close Main Menu (Save Options)

Run Multiple Transfer Limit Analysis or Build New Multiple Transfer Case

☐ Enable AC Verification

Options

☐ Add extra columns user-selected each identifier

Select F

☐ Create Flowgate

☐ Create Subsystem

Do not transfer m

receiving total gen

Only applicable for scaling systems

Report Manager

TARA Multiple Transfer Limit Analysis

Select Source

Import_Gen

Import_LD

Inertia

MonSys

MyStudy

SCD_All

Sending_APS

Sending_NEV

Sending_PGE

Sending_SRP

ref_MySystem

sending_all

Select Sink

Import_Gen

Import_LD

Inertia

MonSys

MyStudy

SCD_All

Sending_APS

Sending_NEV

Sending_PGE

Sending_SRP

ref_MySystem

sending_all

Add to List of Defined Paths >>

Default Maximum transfer test level:

10000

Defined Paths and Max transfer

Sending_APS	Import_Gen	5000
Sending_APS	Import_LD	5000
Sending_NEV	Import_Gen	5000
Sending_NEV	Import_LD	5000
Sending_PGE	Import_Gen	5000
Sending_PGE	Import_LD	5000
Sending_SRP	Import_Gen	5000
Sending_SRP	Import_LD	5000
sending_all	Import_Gen	10000
sending_all	Import_LD	10000

Remove Selected Paths

Remove ALL Paths

Save Paths and Options (for future runs)

Update Max transfer for Selected Paths <<

New Max transfer test level:

2000

Save Paths. Create Batch Sheet

A new sheet named BatchProcessITRL_NN will be created every time. Please change Reports Root Directory if needed. All options for analysis will be taken from the Main Menu.

Paths File

C:\TARA_main\PathsSet3w12.csv

...

Save Defined Paths in File

Retrieve Defined Paths from File

Options

1

Maximum constraints per path

Parallel Processing

Run Multiple Transfer Limit Analysis for Defined Paths


Build New Case with Transfers Applied

Cancel

FORWARD TOGETHER  RELIABILITYFIRST

AC VERIFY

FORWARD TOGETHER  RELIABILITYFIRST



The screenshot displays the AC Verify software interface. The main window has a sidebar with tabs: Input, Utils, CA, SCD, **TrLim** (highlighted), AMB, FGScr, FGApp, and CustApp. The main area shows the 'Proportional Scale Transfer' tab. A red box highlights the 'Options' button under 'Enable AC Verification'. A red arrow points from this button to the 'AC Thermal TrLim Options' dialog box. A yellow box with the text 'Check to enable' is connected to the 'Options' button by a red line.

AC Thermal TrLim Options

Number of Limits to AC Verify

- ☐ ALL (everything on DC FCITC report will be AC verified)
- ☒ Top DC limits (AC verify a limited number of worst limits from DC report)

Number of limits

Save Options

AC Base and Post-Cont LF Options

Cancel

FCITC RESULTS

Send/Receive system names

Transfer level

Distribution factors

Loadflow Case: C:\TARA_Training\training.epc
Study Data File: C:\TARA_Training\training.sub
Contingency File: C:\TARA_Training\training.con (total 809 contingencies)
Monitor File: C:\TARA_Training\training.mon
Exclude File: not provided
Pre/Post Contingency PAR Adjustment: Adjusted/Fixed

Sending System	Receiving System	Monitored Facility	Area	TrLim	Dfax	Rate Bas	Rate Cont	Cont Name	Base Flow MW (No Transf)	Cont Flow MW (No Transf)	DC %Loadin g (No Transf)	HeadRoom		
Sending_AF Import_Gen	24374 REDBLUFF	500	29253 DVRS_RB_12	24	1281.7	0.14813	2598	2858 29255 DVRS_RB_22	500	24374 REDBLUFF	1501.3	2668.1	93.36	189.9
Sending_AF Import_Gen	24374 REDBLUFF	500	29253 DVRS_RB_12	24	1296.7	0.14813	2598	2858 24801 DEVERS	500	29254 DVRS_RB_21	1501.3	2665.9	93.28	192.1
Sending_AF Import_Gen	24374 REDBLUFF	500	29253 DVRS_RB_12	24	1296.7	0.14813	2598	2858 29254 DVRS_RB_21	500	29255 DVRS_RB_22	1501.3	2665.9	93.28	192.1
Sending_AF Import_Gen	29252 DVRS_RB_11	500	24801 DEVERS	24	1301	0.14813	2598	2858 29255 DVRS_RB_22	500	24374 REDBLUFF	1498.4	2665.3	93.26	192.7
Sending_AF Import_Gen	29252 DVRS_RB_11	500	24801 DEVERS	24	1315.9	0.14813	2598	2858 29254 DVRS_RB_21	500	29255 DVRS_RB_22	1498.4	2663.1	93.18	194.9
Sending_AF Import_Gen	29252 DVRS_RB_11	500	24801 DEVERS	24	1315.9	0.14813	2598	2858 24801 DEVERS	500	29254 DVRS_RB_21	1498.4	2663.1	93.18	194.9
Sending_AF Import_Gen	24374 REDBLUFF	500	29255 DVRS_RB_22	24	1632.8	0.14813	2598	2910 29253 DVRS_RB_12	500	24374 REDBLUFF	1501.3	2668.1	91.69	241.9
Sending_AF Import_Gen	24374 REDBLUFF	500	29255 DVRS_RB_22	24	1647.7	0.14813	2598	2910 24801 DEVERS	500	29252 DVRS_RB_11	1501.3	2665.9	91.61	244.1
Sending_AF Import_Gen	24374 REDBLUFF	500	29255 DVRS_RB_22	24	1647.7	0.14813	2598	2910 29252 DVRS_RB_11	500	29253 DVRS_RB_12	1501.3	2665.9	91.61	244.1
Sending_AF Import_Gen	29254 DVRS_RB_21	500	24801 DEVERS	24	1652	0.14813	2598	2910 29253 DVRS_RB_12	500	24374 REDBLUFF	1498.4	2665.3	91.59	244.7
Sending_AF Import_Gen	29254 DVRS_RB_21	500	24801 DEVERS	24	1667	0.14813	2598	2910 24801 DEVERS	500	29252 DVRS_RB_11	1498.4	2663.1	91.51	246.9
Sending_AF Import_Gen	29254 DVRS_RB_21	500	24801 DEVERS	24	1667	0.14813	2598	2910 29252 DVRS_RB_11	500	29253 DVRS_RB_12	1498.4	2663.1	91.51	246.9
Sending_AF Import_Gen	22472 MIGUELMP	500	22464 MIGUEL	22	2696.1	0.03254	1120	1329 22464 MIGUEL	230	22468 MIGUEL	718.4	1241.3	93.4	87.7
Sending_AF Import_Gen	22468 MIGUEL	500	22472 MIGUELMP	22	2696.1	0.03254	1120	1329 22464 MIGUEL	230	22468 MIGUEL	718.4	1241.3	93.4	87.7
Sending_AF Import_Gen	22468 MIGUEL	500	22464 MIGUEL	22	3510.1	0.03226	1120	1344 22464 MIGUEL	230	22472 MIGUELMP	695.4	1230.8	91.58	113.2
Sending_AF Import_Gen	22468 MIGUEL	500	22464 MIGUEL	22	3510.1	0.03226	1120	1344 22468 MIGUEL	500	22472 MIGUELMP	695.4	1230.8	91.58	113.2

Mon / con pair for each transfer level

Live Demo



QUESTIONS & ANSWERS

John Idzior

john.idzior@rfirst.org



CASCADE ANALYSIS

Brian Hallett, ReliabilityFirst

August 6, 2026



PURPOSE

Cascade analysis evaluates how an initial component outage (N-1, N-1-1, etc.) can trigger a domino effect of overloads, line tripping, and widespread blackouts across the BES.

A cascade event that results in a non-convergence in steady-state analysis, may be an indicator of a potential stability concern that should be further investigated using dynamic analysis.

You may select different triggers and intermediate actions, e.g.

- Kick-off cascade for thermal overloads greater than 115%, or 125%
- Subsequent tripping of lines loaded above 100%, 115%, or 125%
- Trip generators below V_{min}

INPUT FILES

- Loadflow case(s)
- Subsystem file
- Monitor file
- Contingency file(s)
- Exclude file (optional)
- RAS/CS file (optional)
- INCH file (optional)

Input

Select TARA Application

☐ LF Case Viewer + Editor ☒ ContAnalysis + TARA Screen ☐ TARA Fgates Analysis

POWERGEM

Load Flow Case (first case if list of additional cases is used)

Please define the correct path here

Use as default path

LF case format: PTI RAW 35

Multiple Cases (use *.raw, *.epc, or *.aux in file name if all cases are in one folder)

☐ Add Cases 0 files

☐ Apply INCH Files

List of Additional Cases

List INCH Files

Load Input Files

Study Data File

Please define the correct path here

Monitor File

Please define the correct path here

☐ Do not read Contingency File ☒ Do not read Exclude File

RAS/Corrective Switching Mode RAS/CS is OFF

Contingency File

Please define the correct path here

Exclude File

Please define the correct path here

Select Contingency Analysis Mode (Reload Input Files if selection changed)

☒ Standard N-1 ☐ N-1-1 (or N-1 + Application)


Please define the correct path here

Print Options Export Options File Import Options File Recent Options Files Add Project to History Change Initial Loading Options

Exit TARA Save Viewer with Options and Reports Close Main Menu (Save Options) Clear All Reports Cancel

N-1 ANALYSIS > CASCADE

FORWARD TOGETHER  **RELIABILITYFIRST**



Input | DC Contingency Analysis | **AC Contingency Analysis** | Mon Cont Reports | Flowgate Analysis

Uutils

CA | SCD | TrLim | FGScr | FGApp | CustApp

Run AC Cont Analysis and Create Selected Reports

Report Manager | Parallel Processing

N-1-1 Options | Dfax Reporting

☐ Enable Cascading Analysis | **Options**

AC LF Options

AC Post-Cont LF Options

If you want to change Ratings, Cutoffs for contingency flow, change Initial Loading options and reload input files

Selected Ratings:
Base Case:Rate 1(A)
Post-Cont:Rate 1(A)

Run only contingencies inside and near a selected subsystem of buses. Applies to both first-level and second-level contingencies

☐ Do NOT open BranchViol and VoltViol reports

AC Cont Analysis Reports

- Monitored branches AC violations
- Monitored voltages violations
- ACCONT Summary for all contingencies
- ACCONT Summary - not converged contingencies
- ACCONT Summary - violations only
- ACCONT Summary - Bus Mismatch
- Switched Shunt Adjustments Post-Contingency
- N-1-1 Isolated Gen/Load Buses (N-1-1 Only)
- Worst case branch loading (obsolete)
- Worst case voltages violations (obsolete)

Loading Cutoff for branch violations: 90 %

Voltage Magnitude Limit Adder (0)

Create Reports without ACCont Rerun (works only if N-1-1 Parallel Processing is used)

Select All | Unselect All

Cascading Analysis Options

Branches/Generators/Loads

- ☒ Open branches if branches are loaded above threshold
- ☒ Turn off generators if low voltage violations are identified at voltage regulated buses
- ☒ Also trip if low voltage violation is identified at the generator terminal bus
- ☒ Drop loads if low voltage violations are identified

Save Options | **Cancel**

5 Maximum cascading outage test

Branch tripping % Loading Cutoff

Define voltage ranges and % loading cutoff per each voltage range.

kV	kV	kV	kV
< 100 <=	< 200 <=	< 300 <=	< 400 <=
115	115	115	115
% Loading	% Loading	% Loading	% Loading

Save Cascading Outage Cases

☐ Save case at each outage step?

C:\TARA_main\cases\test | **Select Folder**

Live Demo



QUESTIONS & ANSWERS

Brian Hallett

brian.hallett@rfirst.org



PV ANALYSIS

Brian Hallett, ReliabilityFirst

August 6, 2026



PURPOSE

PV can be a concern under heavy transfers, particularly into heavily loaded load pockets.

PV can be a good compliment to thermal transfer analysis, because some interfaces may be more limited by voltage decline than by thermal overload.

May want to test various contingency scenarios, e.g.

- Line outages
- Generator outages
- Combinations of line + generator outages

INPUT FILES

- Loadflow case(s)
- Subsystem file
 - Define 'Sending' System
 - Define 'Receiving' System
- Monitor file

COM Monitor file for PV Training Example

```
COM Monitor a flowgate - all the flows into the area based on tie-lines
monitor flowgate 1 "Area 4" rating 4000 MW
monitor branch from bus 1280 to bus 1092 ckt 1
monitor branch from bus 1280 to bus 1092 ckt 2
monitor branch from bus 1282 to bus 1100 ckt 1
monitor branch from bus 1283 to bus 1100 ckt 1
monitor branch from bus 1270 to bus 1101 ckt 1
monitor branch from bus 1803 to bus 1104 ckt 1
monitor branch from bus 1306 to bus 1105 ckt 1
monitor branch from bus 1307 to bus 1106 ckt 1
monitor branch from bus 1314 to bus 1133 ckt 1
monitor branch from bus 1314 to bus 1135 ckt 1
end
```

```
COM Monitor specific bus in the study area
monitor voltage range bus 1183 0.90 1.03 /first attempt
monitor bus 1183 / random bus in Area 4 with no generation
end
```

- Contingency file(s)

Input

Select TARA Application

☐ LF Case Viewer + Editor ☒ ContAnalysis + TARA Screen ☐ TARA Fgates Analysis

Load Flow Case (first case if list of additional cases is used)

C:\Users\brianh\Desktop\TARA2503_3\PV_Training\bench2.raw

☒ Use as default path

LF case format

PTI RAW 35

Multiple Cases (use '*.raw', '*.epc', or '*.aux' in file name if all cases are in one folder)

☐ Add Cases 1 file

☐ Apply INCH Files

☐ List of Additional Cases

☐ List INCH Files

Load Input Files

Study Data File

C:\Users\brianh\Desktop\TARA2503_3\PV_Training\Training_Example.SUB

Monitor File

C:\Users\brianh\Desktop\TARA2503_3\PV_Training\PV_Example.MON

☐ Do not read Contingency File ☒ Do not read Exclude File

RAS/Corrective Switching Mode RAS/CS is OFF

Contingency File

C:\Users\brianh\Desktop\TARA2503_3\PV_Training\PV_Training.CON

Exclude File

Please define the correct path here

Select Contingency Analysis Mode (Reload Input Files if selection changed)

☒ Standard N-1 ☐ N-1-1 (or N-1 + Application)

Please define the correct path here

Print Options **Export Options File** **Import Options File** **Recent Options Files** **Add Project to History** **Change Initial Loading Options**

Exit TARA **Save Viewer with Options and Reports** **Close Main Menu (Save Options)** **Clear All Reports** **Cancel**

PV ANALYSIS

Input Opt MW Transfer Proportional Scale Transfer **PV Analysis** QV Analysis PathScreen AreaTieImpacts ?

Utils

CA

SCD

TrLim

FGScr

FGApp

CustApp

PV Screening

8000 Maximum Test MW **Run PV Screening**

0 Initial Test MW **Additional Options**

500 MW Step Size

PV Analysis

4000 Maximum PV Test MW **Run PV Analysis and Create Selected Reports** **Additional Options**

0 Initial Test MW

100 MW Step Size **Parallel Processing** **Report Manager**

10 Transfer Stop Tolerance MW

90 Branch %Loading Cutoff

0.05 Dfax Cutoff (p.u.)

☒ Run basecase PV study

☐ Report Only Violations (after applying Vlow/Vdrop limits). If unchecked, ALL Results are reported.

Select Reports

PV Summary
PV Voltages
PV Branch Flows
PV Flowgates
PV Shunts
Bus Dfax (created if Add Dfax is ON)

PV analysis was completed

Create Reports without rerun

Sending System

Sending Find Details

Receiving System

Receiving_Load Find Details

Exit TARA **Save Viewer with Options and Reports** **Close Main Menu (Save Options)** **Clear All Reports** **Cancel**

```
/File: Training_Examples.SUB
/Set-up Subsystems for PV Anaysis using generic PSSE sample case
```

```
Subsystem 'PV_Mon'
Area 4
End
```

```
Subsystem 'Sending'
Area 9
Area 10
Area 11
Area 16
Area 17
Area 18
Area 19
Area 47
scale all generation
End
```

```
/Sending areas are all West of the study area
/Total dispatched generation in these Areas = 39,870MW (PGen)
/Sample case has all Pmax set to 9999.9
```

```
Subsystem 'Receiving_Load'
Area 4
scale all load
End
```

```
/Receiving area load+losses = 3,899.95
```

```
Subsystem 'Receiving_Gen'
Area 22
Area 23
Area 24
Area 26
scale all generation
End
```

```
/Receiving areas area all East of the study area
```

PV ANALYSIS

Input **Utils** **CA** **SCD** **TrLim** **FGScr** **FGApp** **CustApp**

Opt MW Transfer | Proportional Scale Transfer | **PV Analysis** | QV Analysis | PathScreen | AreaTieImpacts

PV Screening

8000 Maximum Test MW

0 Initial Test MW

500 MW Step Size

Run PV Screening

Additional Options

PV Analysis

4000 Maximum PV Test MW

0 Initial Test MW

100 MW Step Size

10 Transfer Stop Tolerance MW

90 Branch %Loading Cutoff

0.05 Dfax Cutoff (p.u.)

☒ Run basecase PV study

☐ Report Only Violations (after applying Vlow/Vdrop limits). If unchecked, ALL Results are reported.

Run PV Analysis and Create Selected Reports

Parallel Processing

Report Manager

Select Reports

PV Summary
PV Voltages
PV Branch Flows
PV Flowgates
PV Shunts
Bus Dfax (created if Add Dfax is ON)

PV analysis was completed

Create Reports without rerun

Sending System

Sending Find Details

Receiving System

Receiving_Load Find Details

Exit TARA **Save Viewer with Options and Reports** **Close Main Menu (Save Options)** **Clear All Reports** **Cancel**

RFIRST PV Screening Summary [Sending System=Sending/Receiving System=Receiving_Load] [TARA Ver 2503.3.0.0 64-b:

Loadflow Case: C:\Users\brianh\Desktop\TARA2503_3\PV_Training\bench2.raw
Study Data File: C:\Users\brianh\Desktop\TARA2503_3\PV_Training\Training_Example.SUB
Contingency File: C:\Users\brianh\Desktop\TARA2503_3\PV_Training\PV_Training.CON (total 5 contingencies)
Monitor File: C:\Users\brianh\Desktop\TARA2503_3\PV_Training\PV_Example.MON
Exclude File: not provided
Solution Options (Pre/Post Contingency): Shunts[All Enabled/Disabled] PAR[Adjusted/Fixed] XFMR Tap[Adjusted/F:

Cont ID	Cont Name	Blown Up MW Transfer	MW Transfer at Vlow (V	Base Cont	Vmin	Volt	Volt
0	Base Case	5000	2500	4	0.9	0.83326	0.83326
1	PV-Test_1	4500	2000	4	0.9	0.9768	0.77188
2	PV-Test_2	4000	2000	4	0.9	0.9768	0.73596
3	PV-Test_3	4500	2000	4	0.9	0.9768	0.84653
4	PV-Test_4	< 5000.00	2500	4	0.9	0.83326	0.74379
5	PV-Test_5	< 5000.00	2500	4	0.9	0.83326	0.81066

Search the menus

- TARA Main Menu
- TARA Sort
- TARA Filter
- TARA Utilities
- TARA LF Case Editor
- Bus Functions
- Run PV Analysis...
- Contingency Analysis Functions
- TARA Help

Right-Click

TARA PV Analysis for Selected Contingencies

List of Selected Contingencies:

PV-Test_1

Select Reports

PV Summary
PV Voltages
PV Branch Flows
PV Flowgates
PV Shunts
Bus Dfax (created if Add Dfax is ON)

Run PV Analysis

Report Manager

Analysis Options

4000 Maximum PV Test MW

0 Initial Test MW

100 MW Step Size

10 Transfer Stop Tolerance MW

90 Branch %Loading Cutoff

0.05 Dfax Cutoff (p.u.):

☒ Run basecase PV study

☐ Report Only Violations (after applying Vlow/Vdrop limits). If unchecked, ALL Results are reported.

MW Backoff for Non Convergent Limit

☒ Do not Apply

☐ Multiplier times interface flow at the last converged point

☐ MW from interface flow at the last converged point

Save Transfer Cases

☐ Save case at each transfer point?

C:\TARA_main\inch_project_files

Select Folder

Transfer Limit Violations to Perform

☒ Low bus voltage violation ☒ Branch thermal violation

☒ Bus voltage drop violation ☐ Flowgate thermal violation

1 Q Scaling Ratio

☒ Distribute Transfer Losses to Sending System

AC Base and Post-Cont LF Options

Add Bus Dfax Options

Cancel

PV ANALYSIS

Input

Utils

CA

SCD

TrLim

FGScr

FGApp

CustApp

Opt MW Transfer

Proportional Scale Transfer

PV Analysis

QV Analysis

PathScreen

AreaTieImpacts

PV Screening

8000

Maximum Test MW

0

Initial Test MW

500

MW Step Size

Run PV Screening

Additional Options

PV Analysis

4000

Maximum PV Test MW

0

Initial Test MW

100

MW Step Size

10

Transfer Stop Tolerance MW

90

Branch %Loading Cutoff

0.05

Dfax Cutoff (p.u.)

☒ Run basecase PV study

☐ Report Only Violations (after applying Vlow/Vdrop limits). If unchecked, ALL Results are reported.

Run PV Analysis and Create Selected Reports

Additional Options

Parallel Processing

Report Manager

Select Reports

PV Summary

PV Voltages

PV Branch Flows

PV Flowgates

PV Shunts

Bus Dfax (created if Add Dfax is ON)

PV analysis was completed

Create Reports without rerun

Sending System

Sending

Find

Details

Receiving System

Receiving_Load

Find

Details

Exit TARA

Save Viewer with Options and Reports

Close Main Menu (Save Options)

Clear All Reports

Cancel

TARA PV Analysis Options

Select Contingencies

Enter contingency numbers separated by comma (or space), such as 2, 10, 66, or by dash, such as 10-25 (do not omit space before dash):

1, 2, 3, 4, 5

Select Contingencies

Save Options

AC Base and Post-Cont LF Options

Transfer Limit Violations to Perform

☒ Low bus voltage violation

☒ Bus voltage drop violation

☒ Branch thermal violation

☐ Flowgate thermal violation

1.1

Q Scaling Ratio

☒ Distribute Transfer Losses to Sending System

MW Backoff for Non-Convergent Limit

☒ Do not Apply

☐ Multiplier times interface flow at the last converged point

0.95

☐ MW from interface flow at the last converged point

100

Add Bus Dfax

Sending System

SCD_AllGens

Find Subsystem

Details

Receiving System

NWEST

Find Subsystem

Details

Dfax kV selection

345

Bus Dfax cutoff kV boundary

0.05

Bus Dfax cutoff applied to bus voltage LT kV boundary

0.02

Bus Dfax cutoff applied to bus voltage GTE kV boundary

Save Transfer Cases

☐ Save case at each transfer point?

C:\TARA_main\test1

Select Folder

Cancel

PV RESULTS - SUMMARY

RFIRST PV Summary [TARA Ver 2503.3.0.0 64-bit - Thu Jul 30 09:39:31 2026]

Loadflow Case: C:\Users\brianh\Desktop\TARA2503_3\PV_Training\bench2.raw

Study Data File: C:\Users\brianh\Desktop\TARA2503_3\PV_Training\Training_Example.SUB

Contingency File: C:\Users\brianh\Desktop\TARA2503_3\PV_Training\PV_Training.CON (total 5 contingencies)

Monitor File: C:\Users\brianh\Desktop\TARA2503_3\PV_Training\PV_Example.MON


Exclude File: not provided

Solution Options (Pre/Post Contingency): Shunts[All Enabled/Disabled] PAR[Adjusted/Fixed] XFMR Tap[Adjusted/Fixed] Area Interchange [Disabled/Disabled]


Sending System	Receiving System	Worst Limit Flag	Cont ID	Cont Name	Last Converged MW	FG Name (Last)	FGI	Ratir	Last Transfer Base MW	Last Transfer Cont MW	Last Transfer AC %Loading	Knee Flt	MW Transfer at Vlow	Bus # (Vmag)	Bus Nar	Base kV	Area	Vmin	Base Volt	Cont Volt	Limit Info	FG Baseflow at Vmag	FG Contflow at Vmag
Sending	Receiving_Load	LTrans	0	Base Case	4000	Area 4	1	4000	2682.23	2682.23	115.4	Knee	2312.5	1183	XXXXXXXX	345	4	0.9	0.9	-	Found	2603.48	2603.48
Sending	Receiving_Load		1	PV-Test_1	4000	Area 4	1	4000	2682.23	3105.68	132	Knee	1656.25	1183	XXXXXXXX	345	4	0.9	0.9905	0.9004	Found	1908.94	3137.26
Sending	Receiving_Load	Vmag	2	PV-Test_2	4000	Area 4	1	4000	2682.23	2922.32	125.4	Knee	1506.25	1183	XXXXXXXX	345	4	0.9	0.9945	0.9004	Found	1754.52	2978.65
Sending	Receiving_Load		3	PV-Test_3	4000	Area 4	1	4000	2682.23	3313.55	137.7	Knee	1831.25	1183	XXXXXXXX	345	4	0.9	0.985	0.9002	Found	2089.77	3304.89
Sending	Receiving_Load		4	PV-Test_4	4000	Area 4	1	4000	2682.23	2294.69	103.3	Knee	2062.5	1183	XXXXXXXX	345	4	0.9	0.9597	0.9003	Found	2331.85	2353.61
Sending	Receiving_Load		5	PV-Test_5	4000	Area 4	1	4000	2682.23	2612.56	112.4		2406.25	1183	XXXXXXXX	345	4	0.9	0.858	0.8538	Within	2707.97	2706.15

> PVcurves_test2 PVScrSum Warn_Sum Warn_List CaseSum LogFile PVcurves_test PVSummary PVPoltage PVBranchFlow PVFlowgate PVShunt BatchProcess_TrainingN1 BatchProcess_TrainingN11 +

Right Click



Plot Wizard



PV RESULTS - VOLTAGE

RFIRST PV Voltage Result [TARA Ver 2503.3.0.0 64-bit - Thu Jul 30 09:39:31 2026]



Loadflow Case: C:\Users\brianh\Desktop\TARA2503_3\PV_Training\bench2.raw

Study Data File: C:\Users\brianh\Desktop\TARA2503_3\PV_Training\Training_Example.SUB

Contingency File: C:\Users\brianh\Desktop\TARA2503_3\PV_Training\PV_Training.CON (total 5 contingencies)


Monitor File: C:\Users\brianh\Desktop\TARA2503_3\PV_Training\PV_Example.MON

Exclude File: not provided

Solution Options (Pre/Post Contingency): Shunts[All Enabled/Disabled] PAR[Adjusted/Fixed] XFMR Tap[Adjusted/Fixed] Area Interchange [Disabled/Disabled]

Sending System	Receiving System	Worst Limit Flag	MW Transf	Bus #	Bus Name	Base kV	Area	Bus Type	Pgen	Pload	G Shunt	B Shunt	Min Volt Limit	Max Volt Limit	Cont Name	Cont ID	Base Volt	Cont Volt	%Vdrop
Sending	Receiving_Load		0	1183	XXXXXXXX	345	4	Load	0	5	0	0	0.9	1.03	PV-Test_1	1	1.0164	1.01605	0.034
Sending	Receiving_Load		100	1183	XXXXXXXX	345	4	Load	0	5	0	0	0.9	1.03	PV-Test_1	1	1.01586	1.01538	0.048
Sending	Receiving_Load		200	1183	XXXXXXXX	345	4	Load	0	5	0	0	0.9	1.03	PV-Test_1	1	1.01532	1.0147	0.062
Sending	Receiving_Load		300	1183	XXXXXXXX	345	4	Load	0	5	0	0	0.9	1.03	PV-Test_1	1	1.01475	1.01319	0.156
Sending	Receiving_Load		400	1183	XXXXXXXX	345	4	Load	0	5	0	0	0.9	1.03	PV-Test_1	1	1.01409	1.01144	0.266
Sending	Receiving_Load		500	1183	XXXXXXXX	345	4	Load	0	5	0	0	0.9	1.03	PV-Test_1	1	1.01265	1.00977	0.287
Sending	Receiving_Load		600	1183	XXXXXXXX	345	4	Load	0	5	0	0	0.9	1.03	PV-Test_1	1	1.01117	1.00801	0.315
Sending	Receiving_Load		700	1183	XXXXXXXX	345	4	Load	0	5	0	0	0.9	1.03	PV-Test_1	1	1.00965	1.0062	0.344
Sending	Receiving_Load		800	1183	XXXXXXXX	345	4	Load	0	5	0	0	0.9	1.03	PV-Test_1	1	1.00809	1.00409	0.4
Sending	Receiving_Load		900	1183	XXXXXXXX	345	4	Load	0	5	0	0	0.9	1.03	PV-Test_1	1	1.00649	1.00163	0.486
Sending	Receiving_Load		1000	1183	XXXXXXXX	345	4	Load	0	5	0	0	0.9	1.03	PV-Test_1	1	1.00486	0.99655	0.83
Sending	Receiving_Load		1100	1183	XXXXXXXX	345	4	Load	0	5	0	0	0.9	1.03	PV-Test_1	1	1.00318	0.99096	1.222
Sending	Receiving_Load		1200	1183	XXXXXXXX	345	4	Load	0	5	0	0	0.9	1.03	PV-Test_1	1	1.00133	0.98182	1.951
Sending	Receiving_Load		1300	1183	XXXXXXXX	345	4	Load	0	5	0	0	0.9	1.03	PV-Test_1	1	0.99943	0.96791	3.152
Sending	Receiving_Load		1400	1183	XXXXXXXX	345	4	Load	0	5	0	0	0						
Sending	Receiving_Load		1500	1183	XXXXXXXX	345	4	Load	0	5	0	0	0						
Sending	Receiving_Load		1600	1183	XXXXXXXX	345	4	Load	0	5	0	0	0						

Cont Voltage vs. MWTransfer
Bus: 1183 XXXXXXXX 345



Right Click

Search the menus

- TARA Main Menu
- TARA Sort >
- TARA Filter >
- TARA Utilities >
- TARA LF Case Editor >
- Bus Functions >
- Create PV Plot for selected contingency...
- Create PV Plot for selected bus...**
- Contingency Analysis Functions >
- TARA Help >

Plot Wizard

Live Demo



QUESTIONS & ANSWERS

Brian Hallett

brian.hallett@rfirst.org



QV ANALYSIS

John Idzior, ReliabilityFirst

August 6, 2026




PURPOSE

We have a starting case with a topology, load, dispatch, and transaction schedule built in

We want to identify voltage stability violations and reactive power margin for study buses under various loading and with different contingencies. Used to determine the location of the most effective reactive support and the size and type of reactive devices.

- Show Reactive margin at study bus
- Determine location, size and type of reactive device needed
- Compare different sized Shunt devices

QV ANALYSIS



*Source: PowerGEM

INPUT FILES

- Loadflow Case
- Contingency File
- Subsystem File*
- Monitor File*

Input

Select TARA Application

☐ LF Case Viewer + Editor ☒ ContAnalysis + TARA Screen ☐ TARA Fgates Analysis

POWERGEM

Load Flow Case (first case if list of additional cases is used)

Please define the correct path here

Use as default path

LF case format: PTI RAW 35

Multiple Cases (use *.raw, *.epc, or *.aux in file name if all cases are in one folder)

☐ Add Cases 0 files

☐ Apply INCH Files

List of Additional Cases

List INCH Files

Load Input Files

Study Data File

Please define the correct path here

Monitor File

Please define the correct path here

☐ Do not read Contingency File ☒ Do not read Exclude File

RAS/Corrective Switching Mode RAS/CS is OFF

Contingency File

Please define the correct path here

Exclude File

Please define the correct path here

Select Contingency Analysis Mode (Reload Input Files if selection changed)

☒ Standard N-1 ☐ N-1-1 (or N-1 + Application)

Please define the correct path here

Print Options

Export Options File

Import Options File

Recent Options Files

Add Project to History

Change Initial Loading Options

Exit TARA

Save Viewer with Options and Reports

Close Main Menu (Save Options)

Clear All Reports

Cancel

*Not used for analysis but necessary to load TARA

QV ANALYSIS

Input

Utils

CA

SCD

TrLim

FGScr

FGApp

CustApp

Opt MW Transfer

Proportional Scale Transfer

PV Analysis

QV Analysis

PathScreen

AreaTieImpacts

Bus-Based QV Analysis

0.7

QV test minimum voltage

1.05

QV test maximum voltage

0.01

QV voltage step size

☒

Run QV basecase study

☒

Enable QV reactive margin voltage cutoff

0.925

QV reactive margin voltage cutoff [> 0.8]

Run Bus-Based QV Analysis and Create Selected Reports

Additional Options

Parallel Processing

Select Reports

QV Summary

QV Study Buses

QV analysis was NOT completed

Create Reports without rerun

Sending System

West

Find

Details

Receiving System

East

Find

Details

QV ANALYSIS

TARA QV Analysis Options ×

Select Contingencies
Enter contingency numbers separated by comma (or space), such as 2, 10, 66, or by dash, such as 10 -25 (do not omit space before dash!):

5,6,7,8,9

Select Contingencies

Select Study Buses
Enter bus numbers separated by comma:

11027,11036,11040,11050

Select Buses

☒ Study Bus Screening based on Close Proximity

Options

ACCont solution options

☒ Enable TAP adjustment

☐ Enable PAR adjustment

Enable shunt adjustment

☐ No

☐ All (Continuous and discrete)

☒ Continuous only

Enable area interchange control

☒ No

☐ Ties

☐ Ties and external load

☒ Enable DC lines TAP adjustments

☐ Set Generators to Local Voltage Regulation

0.1

Bus Mismatch Solution Tolerance (MW/MVAR)

0.1

Low voltage threshold to start scaling load down [0-1]

?

Save Options

Cancel


RESULTS

RFIRST QV Bus-Based Summary [TARA Ver 2502.2.0.0 64-bit - Mon Jul 27 15:00:20 2026]

Loadflow Case: C:\test\test.raw
 Study Data File: C:\test\test.sub
 Contingency File: C:\test\test.CON (total 4 contingencies)
 Monitor File: C:\test\test.MON
 Exclude File: not provided
 Pre/Post Contingency PAR Adjustment: Adjusted/Fixed

Bus #	Bus Name	Base kV	Area	Zone	Cont Name	Cont ID	Maximum Reactive Margin (MVAR)	Volt at Reactive Margin	Reactive Margin Rank	Base/Cont Volt W/O QV	Reactive Margin at VLimit (MVAR)	Low Volt Limit	Test Range Vlow	Test Range Vhigh
123546	TEST	138	123	1234	[ABC] Smith 765/345 kV and Unit 1	1	2107.95	0.7	1	1.009	829.8	0.925	0.7	1.05
123546	TEST	138	123	1234	Base Case	0	2300.7	0.7	2	1.0099	1044.1	0.925	0.7	1.05
123546	TEST	138	123	1234	[ABC] SmithB 345/138 kV and Unit 1	2	1377.26	0.7	1	0.9958	467.3	0.925	0.7	1.05
123546	TEST	138	123	1234	[ABC] SmithC									
123546	TEST	138	123	1234	[ABC] Smith									

Reg. Volt	Base Case	Reg. Volt	[ABC] Smith 765/345 kV and Unit 1	Reg. Volt	[ABC] SmithB 345/138 kV and Unit 1	Reg. Volt	[ABC] SmithC 765/345 kV and Unit 1	Reg. Volt	[ABC] Smith and SmithC 765/345 kV and Unit 1
0.7	-2300.7	0.7	-2107.95	0.7	-1377.26	0.7	-1960.98	0.7	-1313.44
0.71	-2269.51	0.71	-2076.63	0.71	-1354.3	0.71	-1931.93	0.71	-1292.32
0.72	-2235.45	0.72	-2042.94	0.72	-1330.05	0.72	-1902.27	0.72	-1268.88
0.73	-2198.95	0.73	-2005.93	0.73	-1304.45	0.73	-1868.04	0.73	-1244.2
0.74	-2164.75	0.74	-1967.04	0.74	-1276.98	0.74	-1831.88	0.74	-1218.22
0.75	-2126.45	0.75	-1927.23	0.75	-1247.78	0.75	-1793.68	0.75	-1190.82
0.76	-2084.01	0.76	-1884.45	0.76	-1217.26	0.76	-1753.38	0.76	-1162.2
0.77	-2036.98	0.77	-1839.64	0.77	-1185.37	0.77	-1712.47	0.77	-1132.24
0.78	-1993.22	0.78	-1792.95	0.78	-1151.7	0.78	-1668.44	0.78	-1100.81
0.79	-1945.56	0.79	-1743.88	0.79	-1115.95	0.79	-1622.56	0.79	-1067.79
0.8	-1897.39	0.8	-1692.76	0.8	-1077.64	0.8	-1574.43	0.8	-1033.53
0.81	-1847.47	0.81	-1639.6	0.81	-1037.2	0.81	-1524.48	0.81	-997.86
0.82	-1786.51	0.82	-1584.47	0.82	-995.38	0.82	-1472.48	0.82	-960.25
0.83	-1731.35	0.83	-1527.09	0.83	-952.16	0.83	-1418.38	0.83	-918.57
0.84	-1671.55	0.84	-1467.65	0.84	-907.46	0.84	-1362.25	0.84	-874.32
0.85	-1612.41	0.85	-1404.28	0.85	-861.33	0.85	-1304.33	0.85	-828.64
0.86	-1551.11	0.86	-1338.73	0.86	-813.74	0.86	-1244.42	0.86	-781.53
0.87	-1485.20	0.87	-1271.12	0.87	-764.72	0.87	-1182.75	0.87	-733.2



Live Demo



QUESTIONS & ANSWERS

John Idzior

john.idzior@rfirst.org



Dynamic Model In-Take Process

Ensuring model accuracy from design
to final construction stages

Generator Modeling & Dynamic
Studies, PJM

System dynamic behavior has become increasingly important to study, due to:

- **High penetration of inverter-based resources (IBRs)**, which significantly changes system dynamics and stability characteristics
- **Growing interconnection of large data center loads**, resulting in increased load magnitude, load dynamics, and more complex grid interactions
- **Expanded deployment of HVDC and FACTS devices**, which play a critical role in supporting grid operation and improving system dynamic performance

These developments make accurate dynamic models more critical than ever, as they are fundamental to meaningful and reliable power system dynamic studies, and to the credibility of study results.

Collecting and maintaining accurate dynamic models is not an easy task:

- **Dynamic model are constantly evolving:** Throughout the lifecycle of a generator or other dynamic device, models may change due to interconnection studies, as-built conditions, planned and unplanned equipment modifications, and model updates or corrections identified through MOD-026 and MOD-033 validation activities.
- **Dynamic models must support a wide range of studies, including interconnection, planning, operational, and event analysis applications:** While the models used for these studies may not always be identical due to differing objectives, assumptions, and study requirements, any differences should be technically justified, properly documented, and appropriate for the intended application. Regardless of the study type, the models should accurately represent plant behavior and maintain consistency with the actual facility configuration and performance.

Collecting and maintaining accurate dynamic models is not an easy task:

- **Dynamic model changes occur simultaneously across multiple departments and processes:** As equipment modifications, model updates, validation activities, compliance requirements, and study efforts often occur in parallel, identifying/collecting the most accurate and up-to-date model becomes increasingly complex. Maintaining **a single source of truth** for dynamic models throughout the generator lifecycle is therefore a significant challenge, requiring strong governance, version control, and coordination among interconnection, planning, operations, and asset management teams.
- **Effective dynamic model governance is fundamental:** to maintaining model integrity, version control, traceability, and enterprise-wide accessibility, ensuring that reliable and up-to-date models are available for all study and operational needs.


Goals for Dynamic Analysis and Model Change Control Process:

- **Ensure the dynamic model accurately represents the plant.** The dynamic model should faithfully reflect the equipment configuration, control systems, and electrical behavior of the generating facility or dynamic device throughout its lifecycle.
- **Maintain system reliability through dynamic security analysis.** Any proposed model or plant equipment change should undergo the necessary dynamic security assessments. If the change introduces reliability or security concerns, those issues must be resolved before the equipment change is implemented. This ensures that no model updates remain in an unstudied state and helps prevent unexpected operational impacts.
- **Approve model changes only after appropriate validation and studies.** Dynamic model updates should be released for operational, planning, or interconnection use only after completing the required validation, review, and study processes to confirm their accuracy and suitability.


Goals for Dynamic Analysis and Model Change Control Process:

- **Keep the as-built model current.** Following the implementation of plant modifications, the Generator Owner (GO) should update and submit the corresponding as-built dynamic model to ensure the model remains consistent with the actual plant configuration.
- **Maintain a single source of truth for dynamic models.** A controlled model governance process should ensure that the most accurate, validated, and up-to-date model is readily identifiable and available for all applicable studies and analyses.
- **Integrate dynamic model management and security assessments into a common workflow for interconnection, planning, and operation,** ensuring that all dynamic models are properly reviewed, verified, validated, secured/approved, and maintained as reliable study-ready models throughout their lifecycle.

Integrate dynamic model management and security assessments into a common workflow for interconnection, planning, and operation, ensuring that all dynamic models are properly reviewed, verified, validated, secured/approved, and maintained as reliable study-ready models throughout their lifecycle



PJM Dynamic Analysis and Model Change Sequence





PJM Processes and Tools for Dynamic Model Management

- **Interconnection Study Process:** The interconnection study process serves as the initial entry point for dynamic models and may occur either during the development of a new generating facility or later in the lifecycle of an existing facility when significant upgrades or modifications are proposed. Dynamic models submitted through this process are used to evaluate system performance and reliability impacts associated with the proposed project.
- **As-Built within the Interconnection Study Process:** During the as-built phase, the dynamic model is verified to ensure that it accurately reflects the equipment, control systems, protection settings, and operating characteristics that have actually been implemented at the plant. This process establishes the baseline model representing the installed facility.

- **Necessary Study Process:** The Necessary Study Process is intended for the post-commercial operation phase of a generating facility and supports dynamic model management throughout the remainder of the generator lifecycle. This process addresses changes that may affect the accuracy or applicability of the dynamic model, including:
 - Planned equipment modifications
 - Unplanned equipment modifications
 - Dynamic model corrections resulting from MOD 026 027 verification activities
 - Other plant or control system changes that may impact system performance
- **As-Built Verification within the Necessary Study Process:** As part of the Necessary Study Process, the dynamic model is verified against the actual plant implementation to ensure that it accurately reflects the installed equipment, control systems, settings, and operational characteristics. This verification establishes an updated as-built model that can be confidently used for operational, planning, and reliability studies.



PJM Processes and Tools for Dynamic Model Management

- **GenModel Window Process:** During the GenModel Window, dynamic models for all in-service generating units are posted for Generator Owner (GO) review and certification. If a GO identifies discrepancies between the posted model and the actual facility configuration or performance, the GO is required to submit model updates and corrections through the applicable MOD-026/MOD-027 processes.
- **MOD 026 027 Process:** Through the MOD 026 027 processes, GOs verify the accuracy of their generator excitation, turbine-governor, plant controller, and other applicable dynamic models. PJM then evaluates the submitted models to ensure they are usable and suitable for power system studies and reliability assessments.
- **MOD-033 (AGMV) Process:** During significant system events, dynamic model performance is validated against PMU through the Model Validation (AGMV) process. When model deficiencies are identified, PJM may require the GOs to investigate and update the model in accordance with MOD 026 027 R3 requirements, ensuring the model continues to accurately represent plant behavior and system response.



PJM Processes and Tools for Dynamic Model Management

Under-Development PJM Tools for Dynamic Model Management:

- **Dynamic Model Management (Hierarchy) Database:** This database is currently under development to support dynamic model governance throughout the generator lifecycle. It will establish a model hierarchy, version control, and traceability framework to help users identify and select the appropriate dynamic model snapshot for interconnection, planning, and operational studies. The objective is to ensure that the correct model is used for each application while maintaining **a single source of truth** for all dynamic model data and revisions.



PJM Processes and Tools for Dynamic Model Management

Under-Development PJM Tools for Dynamic Model Management:

- **Dynamic Model Event Management Process:** This process is currently under development to support future MOD 033 dynamic model validation activities. Under this framework, GOs will provide plant PMU measurements and other relevant disturbance data following qualifying system events. The collected data will be used to compare simulated and actual plant responses, validate model performance, identify model deficiencies, and facilitate timely model updates to maintain model accuracy and study reliability. Once developed, this process will be integrated with the existing MOD 033 AGMV framework, creating a more streamlined and comprehensive model validation workflow.

PERFORMING A DYNAMIC ASSESSMENT IN PSS/E

Parimal Saraf, Principal Engineer, Engineering and System Performance, RF

Aug. 6, 2026



OVERVIEW


- BASICS OF DYNAMIC SIMULATION IN ELECTRIC GRIDS
- PERFORMING DYNAMIC SIMULATIONS IN PSS/E
- POST-PROCESSING THE OUTPUT FILES

BASICS OF DYNAMIC SIMULATION IN ELECTRIC GRIDS

REPRESENTATION OF DIFFERENT POWER SYSTEM ELEMENTS



- In dynamic simulations, the power and voltages in the power system change with respect to time
- Elements in the power system can be categorized as either passive or active elements depending on whether they can be represented as impedances (passive) or as dynamic current injections that can change over time or be controlled (active)

Element	Representation	Controllable	Dynamic RMS Model
Synchronous machine	Active	Yes	Stator magnetic and electrical equations, mechanical (swing) equation
Induction machine	Active	Yes (if generator)	Stator and rotor equations, mechanical load / prime mover equation
Converter-interfaced generation	Active	Yes	Voltage source behind impedance, controllable current injection
Transformer	Passive	Yes	Series / shunt impedances
Lines and cables	Passive	No	Series / shunt impedances
Shunt reactive plant	Passive	No	Shunt impedance
SVC / FACTS	Active	Yes	Either voltage source behind impedance or equivalent shunt impedance
Load	Passive or Active	No	Passive: shunt impedance Active: current injection behind shunt impedance



CONTROLS

- Power system elements such as synchronous machines, wind turbines, solar PV plants, SVCs and power transformers are “controllable” in the sense that their current injections in a dynamic simulation can be adjusted via a control system
- Controllers are represented by their own dynamic models



MATHEMATICAL REPRESENTATION

Differential equations: $\frac{dx}{dt} = f(x, v)$

x is a vector of state variables

$[Y]$ is the network nodal admittance matrix

Algebraic equations: $0 = [Y]v - i(x, v)$

v is a vector of nodal voltages (algebraic variables)

i is a vector of (net) nodal current injections

- The differential equations represent all the modeled system (RMS) dynamics, e.g., synchronous machines and their controllers (AVRs, governors, PSS, etc.), converter-based generation, SVC/FACTS devices, transformer tap control, etc.
- The algebraic equations represent the static (passive) elements of the network, e.g. line and cable impedances, fixed shunt and series reactive plant and loads. For a network with n nodes:

$$\begin{bmatrix} 0 \\ \vdots \\ 0 \end{bmatrix} = \begin{bmatrix} Y_{11} & \cdots & Y_{1n} \\ \vdots & \ddots & \vdots \\ Y_{n1} & \cdots & Y_{nn} \end{bmatrix} \begin{bmatrix} v_1 \\ \vdots \\ v_n \end{bmatrix} - \begin{bmatrix} i_1 \\ \vdots \\ i_n \end{bmatrix}$$

- Except for very simple systems, a closed-form analytical solution for this DAE system is not possible and it must be solved using **numerical integration**.


NUMERICAL INTEGRATION

Consider the first-order differential equation:



$$\frac{dx}{dt} = f(x, t)$$

$$x_{n+1} = x_n + h * \frac{dx_n}{dt} = x_n + (h) * f(x_n, t_n)$$

Time step



DYNAMIC MODELS



$$dx_R/dt = [V_{\text{ref}} - V_T + V_{\text{PSS}} - x_R] / T_R$$

$$dE_{\text{FD},u}/dt = [K \cdot V_A - E_{\text{FD},u}] / T_E$$




$$d\delta/dt = \omega_b(\omega - 1)$$

$$d\omega/dt = [P_m - P_e - D(\omega - 1)] / (2H)$$


$$dE'_q/dt = [E_{\text{FD}} - E'_q - (X_d - X'_d)I_d] / T'_{do}$$

$$dE'_d/dt = [-E'_d + (X_q - X'_q)I_q] / T'_{qo}$$

State variables associated with = $\delta, \omega, E'_q, E'_d$




COUPLING BETWEEN DYNAMIC COMPONENTS AND NETWORK




At each simulation time step in PSS®E: dynamic states update → $I / P / Q$ sent to network → network solved → V, θ returned → repeat

PERFORMING DYNAMIC SIMULATIONS IN PSS/E

PSS/E DYNAMIC SIMULATION FLOWCHART






ACTIVITIES CONG/CONL/ORDR/FACT/TYSL




- CONG + CONL change device representation
- ORDR + FACT make the repeated voltage solution efficient
- TYSL prepares the network for fault/trip switching during the simulation
- PSS/E is now ready to repeatedly solve: $Y \cdot V = I$ while dynamic models update device currents and states

INITIALIZATION OF DYNAMIC MODELS






- It is good practice to check that your model flat starts by running the simulation without any disturbances / events and verifying that the outputs show no changes over time, i.e., are flat curves.



DYNAMIC SIMULATION USING PSSPY API



DYNAMIC SIMULATION - PSS/E GUI



	Bus	Id	Mbase
101 NUC-A	21.600	1	900.00
102 NUC-B	21.600	1	900.00
206 URBGEN	18.000	1	1000.00
211 HYDRO_G	20.000	1	725.00
3011 MINE_G	13.800	1	1000.00
3018 CATDOG_G	13.800	1	130.00

NOTES

- Any changes to power flow case such as adding a new transmission line or a generator should be made to .sav file and its corresponding dynamic data, if applicable, should be appended to the system .dyr file
- The following should be ensured before performing a dynamic simulation:
 - Converged power flow case (.sav)
 - No missing dynamic data corresponding to a dynamic device in the .dyr file
 - No missing DLLs as well as DLLs compatible with the working PSS/E version
 - Channels are added for monitoring
- If the simulation crashes midway after applying a disturbance, acceleration factor of network solution and/or simulation time step ("DELT") under the "Dynamic Solution Parameters" can be reduced for achieving numerical convergence

PYTHON SCRIPTS

```
import os, sys
import glob
from io import StringIO
work_dir = os.getcwd().replace('\\Events', '')
sys.path.append(work_dir)
# Import required functions
_i = psspy.getdefaultint()
_f = psspy.getdefaultreal()
_s = psspy.getdefaultchar()

CNVFILE = work_dir + "\savcnv.sav"
SNPFILE = work_dir + "\savnw.snp"
LOGFILE = work_dir + r"\Outs+Logs\Outage_3005-3007.log"
OUTFILE = work_dir + r"\Outs+Logs\Outage_3005-3007.out"

psspy.progress_output(2, LOGFILE, [0, 0])
psspy.prompt_output(2, LOGFILE, [0, 0])

# Load snapshot
psspy.time(0)
psspy.case(CNVFILE)
psspy.rstr(SNPFILE)

# Load dynamic DLLs
dll_files = []
dir_list = os.listdir(work_dir)
for name in dir_list:
    ext = name.split('.')[1]
    if ext == "dll" or ext == "DLL":
        dll_files.append(name)

for dllfile in sorted(dll_files):
    dllerr = psspy.addmodellibrary('%s'%dllfile)
    if dllerr != 0:
        psspy.progress("ERROR: %s library NOT loaded\n "%dllfile)

study_areas = [1, 2, 5]
psspy.bsys(0, 1, [0.0, 999.0], len(study_areas), study_areas, 0, [], 0, [], 0, [])
psspy.chsb(0, 0, [-1, -1, -1, 1, 1, 0])
psspy.chsb(0, 0, [-1, -1, -1, 1, 13, 0])

# Print section start tags
psspy.progress('\n')
psspy.progress('\n BEGIN DYNAMICS SIMULATION :-')
psspy.set_relang(1, 206, '1')
psspy.dynamics_solution_param_2([150, _i, _i, _i, _i, _i, _i], [0.5, 0.0001, 0.0041667, _f, _f, _f, _f])

psspy.progress("\n Solution started")
ierr = psspy.strt_2([1, 0], OUTFILE)
psspy.run(1, 10.0, 11, 11, 9)

# Exit PSSE
psspy.stop_2()
```

Flatstart

```
import os, sys
import glob
from io import StringIO
work_dir = os.getcwd().replace('\\Events', '')
sys.path.append(work_dir)
# Import required functions
_i = psspy.getdefaultint()
_f = psspy.getdefaultreal()
_s = psspy.getdefaultchar()

CNVFILE = work_dir + "\savcnv.sav"
SNPFILE = work_dir + "\savnw.snp"
LOGFILE = work_dir + r"\Outs+Logs\Outage_3005-3007.log"
OUTFILE = work_dir + r"\Outs+Logs\Outage_3005-3007.out"

psspy.progress_output(2, LOGFILE, [0, 0])
psspy.prompt_output(2, LOGFILE, [0, 0])

# Load snapshot
psspy.time(0)
psspy.case(CNVFILE)
psspy.rstr(SNPFILE)

# Load dynamic DLLs
dll_files = []
dir_list = os.listdir(work_dir)
for name in dir_list:
    ext = name.split('.')[1]
    if ext == "dll" or ext == "DLL":
        dll_files.append(name)

for dllfile in sorted(dll_files):
    dllerr = psspy.addmodellibrary('%s'%dllfile)
    if dllerr != 0:
        psspy.progress("ERROR: %s library NOT loaded\n "%dllfile)

study_areas = [1, 2, 5]
psspy.bsys(0, 1, [0.0, 999.0], len(study_areas), study_areas, 0, [], 0, [], 0, [])
psspy.chsb(0, 0, [-1, -1, -1, 1, 1, 0])
psspy.chsb(0, 0, [-1, -1, -1, 1, 13, 0])

# Print section start tags
psspy.progress('\n')
psspy.progress('\n BEGIN DYNAMICS SIMULATION :-')
psspy.set_relang(1, 206, '1')
psspy.dynamics_solution_param_2([150, _i, _i, _i, _i, _i, _i], [0.5, 0.0001, 0.0041667, _f, _f, _f, _f])

psspy.progress("\n Solution started")
ierr = psspy.strt_2([1, 0], OUTFILE)

psspy.run(1, 0.5, 11, 11, 9)
psspy.dist_bus_fault(3005, 1, 0, [0.0, -2E9])
psspy.run(1, 0.56667, 11, 11, 9)
psspy.dist_clear_fault(1)
psspy.dist_branch_trip(3005, 3007, '1')
psspy.run(1, 10.0, 11, 11, 9)

# Exit PSSE
psspy.stop_2()
```

Disturbance


RUNNING MULTIPLE DYNAMIC EVENTS

- Create multiple dynamic event files that can be automated to run sequentially using a batch (.bat) file

Name	Date modified	Type	Size
 Outage_201-151	7/23/2026 6:22 PM	JetBrains PyChar...	2 KB
 Outage_201-202	7/23/2026 6:21 PM	JetBrains PyChar...	2 KB
 Outage_3005-3007	7/23/2026 6:14 PM	JetBrains PyChar...	2 KB

- The corresponding .out and .log files generated for each event can be saved in a different folder
- Each of these files can later be post-processed through automation scripts to identify any dynamic stability issues, if any

EXAMPLE DISTURBANCE



POSTPROCESSING THE OUTPUT FILES

POSTPROCESSING .OUT FILES

- Dyntools module, that's part of PSS/E dynamics package, reads PSS/E .out files and converts recorded channels into Python-accessible time-series data
- Enables one script to process many dynamic events automatically instead of reviewing each case manually
- Supports calculation of key metrics such as minimum voltage, frequency nadir, recovery time, settling time, and threshold violations
- Results can be ranked, flagged, plotted, and exported to Excel or CSV for consistent reporting



QUESTIONS & ANSWERS

Parimal Saraf

parimal.saraf@rfirst.org